



**ERIE COUNTY DEPARTMENT OF PUBLIC WORKS
OFFICE OF THE COMMISSIONER**

Addendum No. 4

Project:

2019-955-02 SUNY ECC City Campus 2021 Ellicott Street Building Clay Tile Roof Repair

Location:

121 Ellicott Street
Buffalo, New York 14203

Date: December 7, 2022

This Addendum is being issued to clarify the bid documents and shall supersede and supplement all portions of previously issued bid documents with which it conflicts. It shall be made an integral part of the construction documents.

Changes to Project Manual:

Item No. 1.

PROJECT MANUAL

Section 073200 Clay Roof Tile, Section 2.02, B.1, a, b & c

B. Profile Interlocking Clay Roof Tile, Type 1: Delete reference to Ludowici's "Conosera" tile, and its nominal size of 10.0 inches wide by 16.25 inches long, and its average exposure of 9.125 inches wide by 13.375 inches long.

REPLACE WITH: Ludowici's "Spanish Barrel Tile", to match existing

b. Nominal Size: 9 ¾" wide by 13 ¼" long.

c. Average Exposure: 8 ¼" wide by 10 ¼" long.

End of Addendum No. 4