

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5  
JANUARY 2024 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>
	<b>0</b>		

UFPO's	D1	D4	D5
Responses	95	107	50
Stakeouts	41	33	2
<b>TOTAL STAKEOUTS</b>	<b>76</b>		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	580	13,046	0	<b>13,626</b>

Televising (feet)	D1	D4	D5	TOTAL
By Central Maint	0	0	0	<b>0</b>
By District				<b>0</b>

	D1	D4	D5	TOTAL
House Inspections	1			<b>1</b>
Reinspections	2			<b>2</b>
Violations				<b>0</b>
Dye Tests				<b>0</b>

Manhole Inspections	D1	D4	D5	TOTAL
	71	0	0	<b>71</b>

Manhole Repairs	D1	D4	D5	TOTAL
	1	4	0	<b>5</b>

Root Treatment (ft)	D1	D4	D5	TOTAL
Chemical Root Control	0	0	0	<b>0</b>
Mechanical Root Cut	0	0	0	<b>0</b>
Mechanically Cleaned	0	0	0	<b>0</b>

<b>Sewerline Repairs</b>	NONE
<b>Sanitary Sewer</b>	D1- 100 INTER /280 TOWERS /3497 BROADWAY/ 3270 CLINTON / 1300 INDIAN CHURCH
<b>Overflow</b>	D1-1270 FRENCH
<b>TOTAL-8</b>	D5- 6825 TRANSIT / D5 6085 GOTT CREEK /

CONSTRUCTION		
D1	D4	D5
CAR WASH - 2715 UNION	1352 COMMERCE PKWY	HARRIS HILL MIXED USE SITE
GARY LN. 2 LOT SUB.	BRADLEY EXTENSION	WOODLAND HILLS
SONWIL WAREHOUSE	11061 WALDEN AVE.	7149 TRANSIT
51 RANSIER	BIG DITCH	SPAULDING GREEN PH 8
	4510 BROADWAY APTS	DEER VALLEY ESTATES
	3620 WALDEN /NOCO CARWASH	LEGACY WOODS
	LANCASTER VILLAGE PH 2	9150 MAIN
	5153 TRANSIT - THEOS PL	CANNON WOODS
	FIELDSTREAM SUB.	CLARENCE HIGHWAY
	VALVOLINE OIL CHANGE	4199 TRANSIT COFFEE SHOP
	4781 TRANSIT	6625 TRANSIT MIXED USE
	PLEASANTVIEW GARDENS	
	ANGRY BUFFALO	
	HIDDEN MEADOWS PH 2	
	O REILLY AUTO PARTS	
<b>Plans Reviewed:</b>	SPRINGS OF WEST SENECA- D1	
	TROCAIRE COLLEGE ADDITION D4	

COMPLAINT SUMMARY ECSD # 1 JANUARY 2024

Notification	DATE	Description	Prob. code text	Functional Loc.
10173130	01/26/2024	BACK UP-3844 BROADWAY	OVERFLOW OBSERVED	E-S-N01-C-001-SL
10173083	01/26/2024	SEWER BACKUP - 272 TOWERS BLVD, CHEEKTOW	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-002-SL
10173091	01/26/2024	SEWER BACKUP - 280 TOWERS BLVD., CHEEK	OVERFLOW OBSERVED	E-S-N01-C-002-SL
10171908	01/01/2024	SEWER BACKUP - 26 MADEIRA DR, DEPEW	NO FURTHER WORK REQUIRED	E-S-N01-C-004-SL
10172074	01/19/2024	BACK UP-1233 BORDEN	HOMEOWNER'S PROBLEM	E-S-N01-C-004-SL
10172106	01/08/2024	BACK UP-28 S SEINE	HOMEOWNER'S PROBLEM	E-S-N01-C-005-SL
10172107	01/08/2024	BACK UP-70 GARDEN VILLAGE DRIVE APTS.	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-006-SL
10172051	01/02/2024	SEWER BACKUP - 1327 FRENCH RD, CHEEKTOWA	HOMEOWNER'S PROBLEM	E-S-N01-C-007-SL
10172371	01/18/2024	GASOLINE ODOR-71 FRANTZEN	ODOR	E-S-N01-C-007-SL
10173094	01/26/2024	BACK UP-1255-1331 French Rd	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-007-SL
10173095	01/26/2024	BACK UP-1295 FRENCH RD	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-007-SL
10173097	01/26/2024	BACK UP-1335 FRENCH RD	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-007-SL
10173099	01/26/2024	BACK UP-50 GARY LN	BASEMENT FACILITY	E-S-N01-C-007-SL
10173133	01/26/2024	BACK UP-54 S TRANSITHILL DR	BASEMENT FACILITY	E-S-N01-C-007-SL
10173215	01/30/2024	SEWER BACK UP - 34 GARY LANE	HOMEOWNER'S PROBLEM	E-S-N01-C-007-SL
10172397	01/25/2024	BACK UP-2773 CLINTON ST	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-008-SL
10173230	01/30/2024	MANHOLE ISSUE-2378 UNION RD	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-008-SL
10171016	01/04/2024	BACK UP-3562 CLINTON ST	HOMEOWNER'S PROBLEM	E-S-N01-C-009-SL
10172355	01/20/2024	SEWER BACKUP - 105 NORTH AVE, W SENECA	HOMEOWNER'S PROBLEM	E-S-N01-C-009-SL
10173135	01/26/2024	MANHOLE ISSUE-1300 MINERAL SPRINGS	OVERFLOW OBSERVED	E-S-N01-C-010-MH
10173231	01/30/2024	MANHOLE ISSUE-444 LEIN RD	NO FURTHER WORK REQUIRED	E-S-N01-C-010-MH
10173059	01/26/2024	SEWER BACKUP - 10 BRIAN LN, W SENECA	BASEMENT FACILITY	E-S-N01-C-010-SL
10173132	01/26/2024	BACK UP-217 SENECA CREEK	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-010-SL
10173150	01/26/2024	SEWER BACKUP - 857 SENECA CREEK RD, WS	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-010-SL

COMPLAINT SUMMARY ECSD # 4 JANUARY 2024

10173156	01/27/2024	SEWER BACK UP - 6 MAPLE DRIVE	MAIN SURCHARGED DUE TO WEATHER	E-S-N04-C-001-SL
10173214	01/30/2024	SEWER BACK UP - 7 MAPLE DR	HOMEOWNER'S PROBLEM	E-S-N04-C-001-SL
10173038	01/30/2024	STANDING WATER-625 HARRIS HILL RD	REFERRED TO OTHERS	E-S-N04-C-003-SL
10173098	01/26/2024	BACK UP-3 TRENTWOOD TRAIL	MAIN SURCHARGED DUE TO WEATHER	E-S-N04-C-006-SL
10173134	01/26/2024	MANHOLE ISSUE-11190 WALDEN AVE	MAIN SURCHARGED DUE TO WEATHER	E-S-N04-C-007-SL
10172385	01/21/2024	SEWER BACKUP - 1292 PENORA ST, DEPEW	HOMEOWNER'S PROBLEM	E-S-N04-C-008-SL
10173090	01/26/2024	SEWER BACKUP - 5200 BROADWAY, LANCASTER	NO FURTHER WORK REQUIRED	E-S-N04-C-009-SL
10171015	01/02/2024	SEWER BACKUP - 5137 WILLIAM	HOMEOWNER'S PROBLEM	E-S-N04-C-013-SL
10172094	01/07/2024	SEWER BACKUP - 10 FOX TRACE	BASEMENT FACILITY	E-S-N04-C-013-SL
10172389	01/22/2024	SEWER BACKUP - 16 CEMETERY RD, LANCASTE	HOMEOWNER'S PROBLEM	E-S-N04-C-014-SL
10173070	01/25/2024	BACK UP-53 HEMLOCK	HOMEOWNER'S PROBLEM	E-S-N04-C-016-SL
10173158	01/28/2024	P.S. VANDERBILT	TELEMETRY/PUMPING STATIONS	E-S-N04-F-VBT

COMPLAINT SUMMARY ECSD # 5 JANUARY 2024

10172372	01/18/2024	BACK UP-8240 CLARHERST	HOMEOWNER'S PROBLEM	E-S-N05-C-001-SL
10173092	01/26/2024	BACK UP-8345 CLARENCE CTR RD	MAIN SURCHARGED DUE TO WEATHER	E-S-N05-C-005-SL
10173096	01/26/2024	MANHOLE ISSUE-6101 CLARENCE LANE NORTH	MAIN SURCHARGED DUE TO WEATHER	E-S-N05-C-005-SL
10173137	01/26/2024	MANHOLE ISSUE-6142 BRIDLEWOOD	MAIN SURCHARGED DUE TO WEATHER	E-S-N05-C-005-SL
10173147	01/26/2024	SEWER BACKUP - 6040 NEWHOUSE RD, E AMHER	MAIN SURCHARGED DUE TO WEATHER	E-S-N05-C-005-SL
10172370	01/18/2024	BACK UP-6060 HERR RD	HOMEOWNER'S PROBLEM	E-S-N05-C-006-SL
10173131	01/26/2024	MANHOLE ISSUE-9445 BROOKSIDE	MAIN SURCHARGED DUE TO WEATHER	E-S-N05-C-006-SL
10172045	01/05/2024	MANHOLE COVER-SALT RD NEAR BIKE PATH	PUT ON LIST TO REPAIR	E-S-N05-C-009-MH

**JANUARY 2024 I&I DISTRICT # 1**

<b>Notification</b>	<b>DATE</b>	<b>Description</b>	<b>Act. code text</b>	<b>Functional Loc.</b>	<b>HANDLE</b>
10173183	01/31/2024	MANHOLE REPAIR @ 471 LEIN RD	REPAIRED FRAME/CONE JOINT LEAKS, MOD(4)	E-S-N01-C-010-MH	BA7B5

**JANUARY 2024 I&I DISTRICT # 4**

10172073	01/08/2024	LOCATE AND RAISE M.H. @ 9 MUIRFIELD LN	RAISED MANHOLE(4)	E-S-N04-C-014-MH	1A125D
10172084	01/11/2024	MANHOLE REPAIR @ 5077 TRANSIT RD	RAISED MANHOLE(4)	E-S-N04-C-011-MH	DF0E4
10171158	01/03/2024	RAISE MANHOLE @ 5929 BROADWAY	RAISED MANHOLE(4)	E-S-N04-C-014-MH	DE946
10171159	01/03/2024	RESET / RESEAL M.H. @ 5949 BROADWAY RD	REPAIRED FRAME/CONE JOINT LEAKS, SLT(3)	E-S-N04-C-014-MH	DE950

**JANUARY 2024 I&I DISTRICT # 5**

NONE

Month:	JANUARY 2024		NR Flow Summary			
Station	SD	Total	Daily Avg	GPM	GPH	Tot Gal
		Hrs				
Borden-Clinton	1	266	8.6	200	12000	3,192,000
Cayuga	1	405	13.1	1190	71400	17,350,200
Clint-Tran	1	151	4.9	350	21000	3,171,000
Industrial Park	1	416	13.4	3650	219000	63,772,800
Union	1	62	2.0	850	51000	3,162,000
Woodlands	1	56	1.8	39	2340	131,040
Aurora South	4	53	1.7	705	42300	2,241,900
Bowmansville	4	1333	43.0	1600	96000	127,968,000
Broadway	4	27	0.9	16000	960000	25,920,000
Depew	4	936	30.2	11000	660000	386,100,000
Forestream	4	61	2.0	1050	63000	3,843,000
Hall	4	90	2.9	130	7800	702,000
Haskell	4	37	1.2	590	35400	1,309,800
Iroquois	4	671	21.6	3000	180000	120,780,000
Pleasantview	4	66	2.1	950	57000	3,762,000
Vanderbilt	4	25	0.8	8000	480000	12,000,000
Warner	4	679	21.9	5000	300000	203,700,000
Zoeller	4	214	6.9	680	40800	8,731,200
Bryant	5	135	4.4	600	36000	4,860,000
Eastern Hills	5	140	4.5	625	37500	5,250,000
Forestview	5	38	1.2	554	33240	1,263,120
Creekwood	5	55	1.8	509	30540	1,679,700
Pinebreeze	5	263	8.5	325	19500	5,128,500
Stahley	5	76	2.5	720	43200	3,283,200
Transit Valley	5	103	3.3	450	27000	2,781,000
<b>Total NR Flow:</b>						<b>1,012,082,460</b>

**ERIE COUNTY - SEWER DISTRICT 1,4,5**  
**1/1/2024 TO 1/31/2024**  
**OPERATION REPORT**

<b>INSPECTIONS</b>	<b>D1</b>	<b>D4</b>	<b>D5</b>	<b>TOTAL</b>
Wyes	2	2	1	5
Taps	0	0	0	0
Disconnect	0	0	0	0
Repair	4	8	1	13
<b>TOTAL</b>	<b>6</b>	<b>10</b>	<b>2</b>	<b>18</b>

<b>CONNECTIONS</b>	<b>D1</b>	<b>D4</b>	<b>D5</b>	<b>TOTAL</b>
New Commercial (NC)	0	0	0	0
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	2	2	1	5
Exist Residential (ER)	0	0	0	0
<b>TOTAL</b>	<b>2</b>	<b>2</b>	<b>1</b>	<b>5</b>

<b>PERMITS</b>	<b>D1</b>	<b>D4</b>	<b>D5</b>	<b>TOTAL</b>
New Commercial Issued (NC)	0	0	0	0
Exist Commercial Issued (EC)	0	0	0	0
New Residential Issued (NR)	0	1	0	1
Exist Residential Issued (ER)	4	11	2	17
<b>TOTAL</b>	<b>4</b>	<b>12</b>	<b>2</b>	<b>18</b>

<b>PERMIT FEES</b>	<b>D1</b>	<b>D4</b>	<b>D5</b>	<b>TOTAL</b>
New Commercial Fees (NC)	\$0	\$0	\$0	\$0
Exist Commercial Fees (EC)	\$0	\$0	\$0	\$0
New Residential Fees(NR)	\$0	\$702	\$0	\$702
Exist Residential Fees (ER)	\$8	\$22	\$4	\$34
<b>TOTAL</b>	<b>\$8</b>	<b>\$724</b>	<b>\$4</b>	<b>\$736</b>

DISTRICT 1

CONNECTIONS/REPAIRS

District	Insp Date	#	Street	Town	New/Existing	Property Type	Permit Type	Tap Type
1	1/2/2024 9:00	16	Cannas Ct	Cheektowaga	Existing	Residential Single Unit	Repair	
	1/9/2024	13						
1	11:30	8	Vern Ln	Cheektowaga	Existing	Residential Single Unit	Repair	
	1/10/2024	26		Depew/Chkt				
1	13:00	0	Strasmer Rd	g	Existing	Residential Single Unit	Repair	
	1/29/2024	20						
1	14:00	1	Carriage Ln	West Seneca	New	Residential Single Unit	Connection	Wye
	1/29/2024	20						
1	13:00	4	Carriage Ln	West Seneca	New	Residential Single Unit	Connection	Wye
	1/3/2024	55	Seneca Creek			Residential Multiple		
1	13:00	0	Road	West Seneca	Existing	Units	Repair	

DISTRICT 4

CONNECTIONS/REPAIRS

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	Permit Type	Tap Type
	1/10/2024								
4	12:30	CP0409710	14	Bonita Dr	Depew	Existing	Residential Single Unit	Repair	
	1/23/2024								
4	13:30	CP0409714	40	Claude Dr	Depew	Existing	Residential Single Unit	Repair	
4	1/16/2024	CP0409711	141	Main St	Depew	Existing	Residential Single Unit	Repair	
4	1/5/2024 11:30	CP0409707	16	Hawthorne Tr	Depew/Lanc	Existing	Residential Single Unit	Repair	
	1/25/2024								
4	11:30	CP0406184	584	Columbia Ave	Lancaster	Existing	Residential Single Unit	Repair	
	1/23/2024				Lancaster				
4	11:30	CP0409712	43	Broezel Ave	(T)	Existing	Residential Multiple Units	Repair	
	1/30/2024				Lancaster				
4	14:00	CP0409678	11	Northfield Ln	(T)	New	Residential Single Unit	Connection	Wye
	1/11/2024				Lancaster				
4	14:00	CP0409669	14	Northfield Ln	(T)	New	Residential Single Unit	Connection	Wye
					Lancaster				
4	1/9/2024 13:00	CP0409708	49	Taft Ave	(T)	Existing	Residential Single Unit	Repair	
					Lancaster				
4	1/8/2024 13:00	CP0407407	14	Glendale	(V)	Existing	Residential Single Unit	Repair	

## January 2024 Maintenance

### District 1

---

Plowed and shoveled snow 5 different times.  
Installed a new creek pump for Cayuga ORF wash down pit.  
Washed Industrial Park wet well 2 different times after high wet wells.  
Moved snow at stations where needed with backhoe.  
Swapped pump #1 at Borden with a spare.  
Replaced heaters at Union Pump Station.  
Changed Parameters on VFD 5 at IPP.  
Replaced Manhole Monitor twice at Empire Drive.

### District 4

---

Plowed and shoveled snow 5 different times.  
Prepped and started painting the interior at Forestream.  
Pulled and cleaned pump #1 at Bowmansville 6 different times.  
Pulled and cleaned pump #2 at Bowmansville 5 different times.  
Moved snow at stations where needed with backhoe.  
Repaired a plugged seal water line on pump #1 at Iroquois.  
Pulled and cleaned pump #2 at Warner.  
Washed Bowmansville wet well after a high wet well.  
Washed Warner wet well after a high wet well.  
Replaced 2 heaters at Depew ORF  
Replaced Overload Switch on Boiler pump at Base.  
Replaced light in Back Garage at NR Base

### District 5

---

Plowed and shoveled snow 5 different times.  
Set up bypass pumping at Creekwood Meadows during power outage.

### All Districts

---

Check all fluids in station generators.  
Topped of generators with fuel that ran during power outages.

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	12-Jan	1913		18	154	86	26		-	135
Cayuga	1	Under Generator	1300	33	39.39	10-Jan	816		30	1182	91	118		-	975
Clinton	1	Under Generator	150	24	6.25	12-Jan	1818		21	131	88	19		-	113
Industrial Parkway	1	Under Generator	700	30	23.33	12-Jan	695		28	653	93	47		-	525
Union	1	Under Generator	400	26	15.38	12-Jan	819		24	369	92	31		-	300
Aurora North	4	Under Generator	325	24	13.54					0	0	325		X	244
Aurora South	4	Under Generator	285	21	13.57	12-Jan	1688		18	244	86	41		-	214
Bowmansville	4	Under Generator	700	26	26.92	12-Jan	896		22	592	85	108		-	525
Broadway	4	Above-Ground	1000	36	*	10-Jan	307		34	821	82	179		-	750
Depew	4	Above-Ground	3000	69	*	10-Jan	486		52	2277	76	723		-	2250
Iroquois	4	Under Generator	295	17	17.35	12-Jan	1020		15	260	88	35		-	221
Vanderbilt	4	Above-Ground	1000	36	*	10-Jan			34	821	82	179		-	750
Warner	4	Under Generator	700	26	26.92	12-Jan	1806		24	646	92	54		-	525
Bryant	5	Under Generator	180	22	8.18	12-Jan	691		17	139	77	41		-	135
Pinebreeze	5	Under Generator	275	44	*	12-Jan	1323		42	268	97	7		-	206
Stahley	5	Under Generator	150	25	6.00	12-Jan	1464		24	144	96	6		-	113
Transit Valley	5	Above Ground	275	44	*	12-Jan	552		42	268	97	7		-	206

\* Calculated

Refill at: 0.75



# 2024 January UFPO Numbers

(By District/Region)

Total UFPO Tickets:	841
Tickets Outside ECSD Boundary:	140

	Total Tickets	APR Code		Total %	Stakeout %
		10 - All Clear	30 - Staked Out		
District 1	95	54	41	11%	17%
District 4	107	74	33	13%	14%
District 5	50	48	2	6%	1%
<b>Total NR</b>	252	176	76	30%	32%
District 3	274	177	97	33%	40%
District 6	59	36	22	7%	9%
District 8	20	16	4	2%	2%
<b>Total CR</b>	353	229	123	42%	51%
District 2	96	54	42	11%	17%
<b>Total SR</b>	96	54	42	11%	17%
<b>Totals:</b>	701	459	241		

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5  
FEBRUARY 2024 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
<b>TOTAL</b>	<b>0</b>	<b>0</b>	<b>0</b>
	<b>0</b>		

UFPO's	D1	D4	D5
Responses	146	178	59
Stakeouts	54	74	8
<b>TOTAL STAKEOUTS</b>	<b>136</b>		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	3,890	14,158	273	<b>18,321</b>

Televising (feet)	D1	D4	D5	TOTAL
By Central Maint	0	0	0	<b>0</b>
By District	2,960	0	0	<b>2,960</b>

	D1	D4	D5	TOTAL
House Inspections	3			<b>3</b>
Reinspections				<b>0</b>
Violations				<b>0</b>
Dye Tests				<b>0</b>

Manhole Inspections	D1	D4	D5	TOTAL
	7	2	0	<b>9</b>

Manhole Repairs	D1	D4	D5	TOTAL
	1	2	0	<b>3</b>

Root Treatment (ft)	D1	D4	D5	TOTAL
Vapor Rooting	0	0	0	<b>0</b>
Cutting w/ Flusher	425	0	0	<b>425</b>
Mechanical Cleaning	0	0	0	<b>0</b>

<b>Sewerline Repairs</b>	NONE
<b>Sanitary Sewer Overflow</b>	2378 UNION ROAD

D1	D4	D5
CAR WASH - 2715 UNION	1352 COMMERCE PKWY	HARRIS HILL MIXED USE SITE
GARY LN. 2 LOT SUB.	BRADLEY EXTENSION	WOODLAND HILLS
SONWIL WAREHOUSE	11061 WALDEN AVE.	7149 TRANSIT
51 RANSIER	BIG DITCH	SPAULDING GREEN PH 8
THE SPRINGS AT WS	4510 BROADWAY APTS	DEER VALLEY ESTATES
	3620 WALDEN /NOCO CARWASH	LEGACY WOODS
	LANCASTER VILLAGE PH 2	9150 MAIN
	5153 TRANSIT - THEOS PL	CANNON WOODS
	FIELDSTREAM SUB.	CLARENCE HIGHWAY
	VALVOLINE OIL CHANGE	4199 TRANSIT COFFEE SHOP
	4781 TRANSIT	6625 TRANSIT MIXED USE
	PLEASANTVIEW GARDENS	NORTHWOODS PH 2B
	ANGRY BUFFALO	
	HIDDEN MEADOWS PH 2	
	O REILLY AUTO PARTS	

<b>Plans Reviewed:</b>	D1- 4814 TRANSIT ROAD
	D4- 5481 GENESEE SHOP STORAGE

**ERIE COUNTY - SEWER DISTRICT 1,4,5**  
**2/1/2024 TO 2/29/2024**  
**OPERATION REPORT**

<b>INSPECTIONS</b>	<b>D1</b>	<b>D4</b>	<b>D5</b>	<b>TOTAL</b>
Wyes	0	15	2	17
Taps	0	0	0	0
Disconnect	0	0	0	0
Repair	4	5	0	9
<b>TOTAL</b>	<b>4</b>	<b>20</b>	<b>2</b>	<b>26</b>

<b>CONNECTIONS</b>	<b>D1</b>	<b>D4</b>	<b>D5</b>	<b>TOTAL</b>
New Commercial (NC)	0	0	0	0
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	0	16	2	18
Exist Residential (ER)	0	0	0	0
<b>TOTAL</b>	<b>0</b>	<b>16</b>	<b>2</b>	<b>18</b>

<b>PERMITS</b>	<b>D1</b>	<b>D4</b>	<b>D5</b>	<b>TOTAL</b>
New Commercial Issued (NC)	0	0	1	1
Exist Commercial Issued (EC)	0	0	0	0
New Residential Issued (NR)	1	8	0	9
Exist Residential Issued (ER)	4	5	0	9
<b>TOTAL</b>	<b>5</b>	<b>13</b>	<b>1</b>	<b>19</b>

<b>PERMIT FEES</b>	<b>D1</b>	<b>D4</b>	<b>D5</b>	<b>TOTAL</b>
New Commercial Fees (NC)	\$0	\$0	\$1,952	<b>\$1,952</b>
Exist Commercial Fees (EC)	\$0	\$0	\$0	<b>\$0</b>
New Residential Fees(NR)	\$702	\$8,716	\$0	<b>\$9,418</b>
Exist Residential Fees (ER)	\$8	\$10	\$0	<b>\$18</b>
<b>TOTAL</b>	<b>\$710</b>	<b>\$8,726</b>	<b>\$1,952</b>	<b>\$11,388</b>

**DISTRICT 1**

**CONNECTIONS/REPAIRS**

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	Permit Type
1		CP0104998	75	East Cherbourg Dr	Cheektowaga	Existing	Residential Single Unit	Repair
1		CP0111213	2378	Union Rd	Cheektowaga	Existing	Residential Single Unit	Repair
1		CP0103961	33	Vita Ave.	Cheektowaga	Existing	Residential Single Unit Residential Multiple	Repair
1		CP0111903	3562	Clinton St	West Seneca	Existing	Units	Repair

**DISTRICT 4**

**CONNECTIONS/REPAIRS**

4	CP0409718	160	Elmwood Ave		Depew	Existing	Residential Multiple Units	Repair
4	CP0409651	102	Grambo Dr		Lancaster	New	Residential Single Unit	Connection Wye
4	CP0405960	53	Hemlock Ln		Lancaster	Existing	Residential Single Unit	Repair
4	CP0408086	356	Seneca Place		Lancaster	Existing	Residential Single Unit	Repair
4	CP0409720	6026	Broadway	Bldg 200	Lancaster (T)	New	Residential Multiple Units	Connection Wye
4	CP0409722	6026	Broadway	Bldg 400	Lancaster (T)	New	Residential Multiple Units	Connection Wye
4	CP0409723	6026	Broadway	Bldg 500	Lancaster (T)	New	Residential Multiple Units	Connection Wye
4	CP0409719	6026	Broadway	Bldg 100	Lancaster (T)	New	Residential Multiple Units	Connection Wye
4	CP0409721	6026	Broadway	Bldg 300	Lancaster (T)	New	Residential Multiple Units	Connection Wye
4	CP0409670	100	Grambo Dr		Lancaster (T)	New	Residential Single Unit	Connection Wye
4	CP0409663	98	Grambo Dr		Lancaster (T)	New	Residential Single Unit	Connection Wye

4	CP0409650	12	Hickory Ln		Lancaster (T)	New	Residential Single Unit	Connection	Wye
4	CP0409628	26	Hickory Ln		Lancaster (T)	New	Residential Single Unit	Connection	Wye
4	CP0409648	8	Hickory Ln		Lancaster (T)	New	Residential Single Unit	Connection	Wye
4	CP0409701	8	Kevwood Ln		Lancaster (T)	New	Residential Single Unit	Connection	Wye
4	CP0409658	28	Mary Rachel Place	Bldg 8	Lancaster (T)	New	Residential Single Unit	Connection	Wye
4	CP0409659	30	Mary Rachel Place		Lancaster (T)	New	Residential Single Unit	Connection	Wye
4	CP0409664	2	White Orchid Way	Bldg 12	Lancaster (T)	New	Residential Single Unit	Connection	Wye
4	CP0409667	8	White Orchid Way	Bldg 12	Lancaster (T)	New	Residential Single Unit	Connection	Wye
4	CP0409716	11	School St		Lancaster (V)	Existing	Residential Single Unit	Repair	
4	CP0409717	3567	Walden Ave		Lancaster (V)	Existing	Residential Single Unit	Repair	

**DISTRICT 5**

**CONNECTIONS/REPAIRS**

**NONE**

**CLARENCE TOWN DISTRICTS**

**CONNECTIONS**

5	6	CP0504268	8969	Willyoungs Overlook	Clarence	New	Residential Single Unit	Connection	Wye	Clarence Issued-DSM inspected
5	6	CP0504267	9035	Somerset Way	Clarence Center	New	Residential Single Unit	Connection	Wye	Clarence issued-DSM inspected

Month:	FEBRUARY	FEBRUARY 2024 FLOWS			
Station	SD	Daily Avg	GPM	GPH	Tot Gal
Borden-Clinton	1	19.8	200	12000	6,876,000
Cayuga	1	25.8	1190	71400	593,633,880
Clint-Tran	1	8.7	350	21000	5,292,000
Industrial Park	1	16.6	3650	219000	79,256,100
Union	1	2.8	850	51000	4,182,000
Woodlands	1	1.3	39	2340	86,580
Aurora South	4	2.3	705	42300	2,834,100
Bowmansville	4	31.6	1600	96000	88,032,000
Broadway	4	1.4	16000	960000	40,320,000
Depew	4	43.6	11000	660000	520,987,500
Forestream	4	3.1	1050	63000	5,607,000
Hall	4	5.2	130	7800	1,177,800
Haskell	4	1.9	590	35400	1,947,000
Iroquois	4	29.0	3000	180000	151,560,000
Pleasantview	4	7.3	950	57000	12,027,000
Vanderbilt	4	1.0	8000	480000	13,440,000
Warner	4	28.6	5000	300000	248,700,000
Zoeller	4	10.7	680	40800	12,607,200
Bryant	5	5.9	600	36000	6,192,000
Eastern Hills	5	7.1	625	37500	7,687,500
Forestview	5	1.6	554	33240	1,495,800
Creekwood	5	2.3	509	30540	2,076,720
Pinebreeze	5	2.5	325	19500	1,404,000
Stahley	5	3.2	720	43200	3,974,400
Transit Valley	5	4.9	450	27000	3,807,000
				<b>Total NR Flow:</b>	<b>1,815,203,580</b>

**COMPLAINT SUMMARY ECSD #1 FEBRUARY 2024**

<b>Notification</b>	<b>DATE</b>	<b>Description</b>	<b>Prob. code text</b>	<b>Functional Loc.</b>
10173375	02/05/2024	MANHOLE COVER OFF-10 BARNABAS	REFERRED TO OTHERS	E-S-N01
10173449	02/12/2024	SEWER BACK UP - 70 GARDEN VILLAGE DR	REFERRED TO OTHERS	E-S-N01-C
10173184	02/02/2024	BACK UP-560 CAYUGA CREEK RD	HOMEOWNER'S PROBLEM	E-S-N01-C-001-SL
10173607	02/20/2024	ODOR - 83 SANDY LN, CHEEKTOWAGA	ODOR	E-S-N01-C-001-SL
10173374	02/05/2024	BACK UP-129 HILLPINE	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-003-SL
10174348	02/28/2024	MANHOLE ISSUE - 293 N SEINE	HOMEOWNER'S PROBLEM	E-S-N01-C-005-MH
10173337	02/06/2024	MANHOLE COVER OFF-FRANTZEN & ZELLER	PUT ON LIST TO REPAIR	E-S-N01-C-007-MH
10173488	02/14/2024	BACK UP-50 NANCY	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-007-SL
10173037	02/01/2024	BACK UP-2378 UNION RD	HOMEOWNER'S PROBLEM	E-S-N01-C-008-SL
10173039	02/01/2024	BACK UP-2845 CLINTON ST	BASEMENT FACILITY	E-S-N01-C-008-SL
10173276	02/01/2024	SEWER BACKUP - 2845 CLINTON ST, WEST SEN	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-008-SL
10173283	02/01/2024	SEWER BACK UP - 2845 CLINTON	BASEMENT FACILITY	E-S-N01-C-008-SL
10173311	02/02/2024	SEWER BACKUP - 2845 CLINTON ST, WEST SEN	BASEMENT FACILITY	E-S-N01-C-008-SL
10173316	02/02/2024	MANHOLE SSO - 2378 UNION RD, CHEEKTOWAGA	OVERFLOW OBSERVED	E-S-N01-C-008-SL
10173483	02/13/2024	SINKHOLE-4 BRIAN LN	NO FURTHER WORK REQUIRED	E-S-N01-C-010-SL

**COMPLAINT SUMMARY ECSD #4 FEBRUARY 2024**

10173317	02/03/2024	MANHOLE MISSING - COMO PARK BLVD, LANCAS	REFERRED TO OTHERS	E-S-N04-C
----------	------------	--	--------------------	-----------

**COMPLAINT SUMMARY ECSD #5 FEBRUARY 2024**

10173377	02/07/2024	BACK UP-9235 CLARENCE CENTER RD	HOMEOWNER'S PROBLEM	E-S-N05-C-006-SL
10174381	02/29/2024	MANHOLE HIGH-5371 TRANSIT	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N05-C-007-SL

**FEBRUARY 2024 I&I DISTRICT # 1**

<i>Notification</i>	<i>DATE</i>	<i>Description</i>	<i>Act. code text</i>	<i>Functional Loc.</i>	<i>HANDLE</i>
10173347	02/08/2024	MANHOLE REPAIR @ ZELLER @ FRANTZEN	REPLACED FRAME AND COVER(5)	E-S-N01-C-007-MH	BAD9C

**FEBRUARY 2024 I&I DISTRICT # 4**

10173324	02/07/2024	MANHOLE REPAIR @ STONY ROAD	REPAIRED FRAME JOINT LEAKS, SEV(5)	E-S-N04-C-007-MH	DE814
10173322	02/05/2024	MANHOLE REPAIR @ STONY ROAD	REPAIRED FRAME/CONE JOINT LEAKS, MOD(4)	E-S-N04-C-007-MH	DE816

**FEBRUARY 2024 I&I DISTRICT # 5**

NONE



**2024 FEBRUARY MECHANICAL ROOTCUT DISTRICT # 1**

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10174268	02/21/2024	TELEWISE HILLPINE 8" PVC	MECHANICAL ROOT CUT	E-S-N01-C-003-SL	BB797	181
10173603	02/22/2024	TELEWISE SHARON 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-009-SL	BC009	244

**2024 FEBRUARY MECHANICAL ROOTCUT DISTRICT # 4**

NONE

**2024 FEBRUARY MECHANICAL ROOTCUT DISTRICT # 5**

NONE

**2024 FEBRUARY TELEVISIONING DISTRICT # 1**

<b>Notification</b>	<b>DATE</b>	<b>Description</b>	<b>Act. code text</b>	<b>Functional Loc.</b>	<b>HANDLE</b>	<b>L/F</b>
10174349	02/28/2024	TELEVISION CAYUGA CREEK 24" PVC	TELEVISIONED - (D)	E-S-N01-C-001-SL	BB6F3	379
10174267	02/21/2024	TELEVISION HILLPINE 8" PVC	TELEVISIONED - (D)	E-S-N01-C-003-SL	BB796	060
10174268	02/21/2024	TELEVISION HILLPINE 8" PVC	TELEVISIONED - (D)	E-S-N01-C-003-SL	BB797	181
10173602	02/21/2024	TELEVISION GARDEN VILLAGE 8" LINED	TELEVISIONED - (D)	E-S-N01-C-006-SL	BBC29	193
10173601	02/21/2024	TELEVISION GARDEN VILLAGE 8" LINED	TELEVISIONED - (D)	E-S-N01-C-006-SL	BBC2A	209
10174269	02/21/2024	TELEVISION NANCY 8" VTP	TELEVISIONED - (D)	E-S-N01-C-007-SL	BBD20	348
10174300	02/22/2024	TELEVISION CAYUGA CREEK 24" RCP	TELEVISIONED - (D)	E-S-N01-C-001-SL	BB6EE	153
10174372	02/26/2024	TELEVISION CAYUGA CREEK 24" PVC	TELEVISIONED - (D)	E-S-N01-C-001-SL	BB6EF	124
10174371	02/27/2024	TELEVISION CAYUGA CREEK 24" PVC	TELEVISIONED - (D)	E-S-N01-C-001-SL	BB6F1	498
10174370	02/27/2024	TELEVISION CAYUGA CREEK 24" PVC	TELEVISIONED - (D)	E-S-N01-C-001-SL	BB6F2	468
10174266	02/21/2024	TELEVISION HILLPINE 8" PVC	TELEVISIONED - (D)	E-S-N01-C-003-SL	BB795	057
10173603	02/22/2024	TELEVISION SHARON 8" VTP	TELEVISIONED - (D)	E-S-N01-C-009-SL	BC009	244
10174301	02/22/2024	TELEVISION CAYUGA CREEK 24" PVC	TELEVISIONED - (D)	E-S-N01-C-001-SL	10072625	046

**2024 FEBRUARY TELEVISIONING DISTRICT # 4**

NONE

**2024 FEBRUARY TELEVISIONING DISTRICT # 5**

NONE

## **February 2024 Maintenance**

### **District 1**

---

Washed Cayuga wet well after it was flooded returning ORF.  
Removed broken drive shaft from Cayuga pump 1 and dropped off for repairs.  
Installed new blank covers and air release on Cayuga ORF turrets.  
Swapped pump 1 at Cayuga with a spare and reinstalled repaired drive shaft.  
Replaced Empire Manhole Monitor with Hach Flowmeter from TECSmith.  
Replaced radiator and coolant on Clinton Genset.  
Repaired ORF Return Flowmeter.  
Reset Cayuga's cell modem 3 times.

### **District 4**

---

Completed painting interior floors and walls at Forestream.  
Washed Depew dry well floor with hose at station.  
Swapped pump 4 at Depew with a spare.  
Worked on rebuilding Depew spare pump that was removed.  
Removed valve operator at Depew station.  
Replaced grinder pump at Wherle Commons.  
Replaced contactor at 377 Harris Hill.  
Repaired gas detector with spare O2 sensor.  
Replaced last of the lights in the office area with LED's.  
Started replacing lights with LED's in cage areas.

### **District 5**

---

Wire up Whisper Watt generator for future use at CRP.  
  
Replace hydraulic lines that run underground for muffin monster at Eastern Hills.  
  
Verified gas line operation at Eastern Hills.

### **All Districts**

---

Checked all fluids in station generators and topped off fuel tanks where needed.

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	9-Feb	1917		17	146	81	34		-	135
Cayuga	1	Under Generator	1300	33	39.39	8-Feb	819		29	1142	88	158		-	975
Clinton	1	Under Generator	150	24	6.25	9-Feb	1824		20	125	83	25		-	113
Industrial Parkway	1	Under Generator	700	30	23.33	9-Feb	695		28	653	93	47		-	525
Union	1	Under Generator	400	26	15.38	9-Feb	868		24	369	92	31		-	300
Aurora North	4	Under Generator	325	24	13.54					0	0	325		X	244
Aurora South	4	Under Generator	285	21	13.57	9-Feb	1693		13	176	62	109		X	214
Bowmansville	4	Under Generator	700	26	26.92	9-Feb	901		22	592	85	108		-	525
Broadway	4	Above-Ground	1000	36	*	8-Feb	307		34	821	82	179		-	750
Depew	4	Above-Ground	3000	69	*	8-Feb	487		51	2230	74	770		X	2250
Iroquois	4	Under Generator	295	17	17.35	9-Feb	1024		14	243	82	52		-	221
Vanderbilt	4	Above-Ground	1000	36	*	8-Feb			33	821	82	179		-	750
Warner	4	Under Generator	700	26	26.92	9-Feb	1810		23	619	88	81		-	525
Bryant	5	Under Generator	180	22	8.18	9-Feb	691		17	139	77	41		-	135
Pinebreeze	5	Under Generator	275	44	*	9-Feb	1324		41	264	96	11		-	206
Stahley	5	Under Generator	150	25	6.00	9-Feb	1469		23	138	92	12		-	113
Transit Valley	5	Above Ground	275	44	*	9-Feb	555		41	264	96	11		-	206

\* Calculated

Refill at: 0.75