

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
SEPTEMBER 2024 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTALS	0	0	0
	0		

UFPO's	D1	D4	D5
Responses	224	307	142
Stakeouts	54	61	31
TOTAL STAKEOUTS	146		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	5,925	0	360	6,285

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint	5,699	0	0	5,699
By District	0	0	0	0

	D1	D4	D5	TOTALS
House Inspections	28			
Reinspections	6			
Violations	4			
Dye Tests				

Manhole Inspections	D1	D4	D5	TOTAL
	5	0	0	5

Manhole Repairs	D1	D4	D5	TOTAL
	11	3	1	15

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control	0	0	0	0
Mechanical Root Cut	855	0	0	855
Mechanically Cleaned	0	0	0	0

Sewerline Repairs	D1 MS 12-CASIMER - BC158- (CONTRACTOR)
	D1 MS 12-CASIMER - 10082658 -(CONTRACTOR)
	D1 MS 12-CASIMER - 10082659-(CONTRACTOR)
SSO	NONE

CONSTRUCTION		
D1	D4	D5
4814 TRANSIT	1352 COMMERCE PKWY	HARRIS HILL MIXED USE SITE
GARY LN. 2 LOT SUB.	BRADLEY EXTENSION	7149 TRANSIT
SONWIL WAREHOUSE	5050 O-REILLY AUTO	SPAULDING GREEN PH 8
51 RANSIER	BIG DITCH	DEER VALLEY ESTATES
THE SPRINGS AT WS	4510 BROADWAY APTS	9150 MAIN
2715 & 2725 CAR WASH -UNION	6140-6142 O REILLY AUTO PARTS	CLARENCE HIGHWAY
	LANCASTER VILLAGE PH 2	9150 MAIN
	5153 TRANSIT - THEOS PL	4199 TRANSIT COFFEE SHOP
	FIELDSTREAM SUB.	CLARENCE HIGHWAY
	VALVOLINE OIL CHANGE	6625 TRANSIT MIXED USE
	4781 TRANSIT	
	PLEASANTVIEW GARDENS	
	ANGRY BUFFALO	
	HIDDEN MEADOWS PH 2	

Plans Reviewed:	D4-3825 WALDEN BOW TIE PARK
	D5-6625 TRANSIT- TACO BELL
	D5-EAST GATE PLAZA

ERIE COUNTY - SEWER DISTRICT 1,4,5
9/1/2024 TO 9/30/2024
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	0	8	8
Taps	0	0	0	0
Disconnect	0	0	0	0
Repair	2	11	3	16
TOTAL	2	11	11	24

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	0	0	0
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	0	0	8	8
Exist Residential (ER)	0	0	0	0
TOTAL	0	0	8	8

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	0	0	0
Exist Commercial Issued (EC)	0	1	0	1
New Residential Issued (NR)	1	2	2	5
Exist Residential Issued (ER)	2	11	3	16
TOTAL	3	14	5	22

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$0	\$0	\$0	\$0
Exist Commercial Fees (EC)	\$0	\$2	\$0	\$2
New Residential Fees(NR)	\$702	\$1,404	\$1,404	\$3,510
Exist Residential Fees (ER)	\$4	\$22	\$6	\$32
TOTAL	\$706	\$1,428	\$1,410	\$3,544

DISTRICT #1

CONNECTIONS/REPAIRS

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	Permit Type	Tap Type
	9/6/2024				West				
1	13:00	CP0111918	52	Eldred Ave	Seneca	Existing	Residential Single Unit	Repair	
	9/24/2024				West				
1	13:00	CP0108861	627	Seneca Creek Road	Seneca	Existing	Residential Single Unit	Repair	Tap

DISTRICT #4

CONNECTIONS/REPAIRS

	9/11/2024								
4	14:00	CP0409768	98	Autumn Lea	Depew	Existing	Residential Single Unit	Repair	
	9/11/2024			Enchanted Forest					
4	13:00	CP0406338	175	S	Lancaster	New	Residential Single Unit	Repair	
	9/12/2024								
4	10:00	CP0408383	27	Middlebury	Lancaster	Existing	Residential Single Unit	Repair	
	9/18/2024								
4	14:30	CP0403438	14	Ravenwood Dr	Lancaster	Existing	Residential Single Unit	Repair	
	9/20/2024				Lancaster				
4	13:00	CP0401107	42	Bentley Cir	(T)	Existing	Residential Single Unit	Repair	
	9/4/2024				Lancaster		Non-Residential Single		
4	15:00	CP0408263	2	Benzel Ct	(T)	Existing	Unit	Repair	Tap
	9/16/2024				Lancaster				
4	10:00	CP0409770	410	Columbia Ave	(V)	Existing	Residential Single Unit	Repair	
	9/18/2024				Lancaster				
4	13:00	CP0409772	58	Lake Ave	(V)	Existing	Residential Single Unit	Repair	
	9/19/2024				Lancaster				
4	10:30	CP0409773	63	Park Blvd	(V)	Existing	Residential Single Unit	Repair	
	9/26/2024				Lancaster				
4	13:00	CP0409774	51	School St	(V)	Existing	Residential Single Unit	Repair	
	9/16/2024				Lancaster				
4	10:00	CP0409769	14	W Payne St	(V)	Existing	Residential Single Unit	Repair	

DISTRICT #5

CONNECTIONS/REPAIRS

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	Permit Type	Tap Type
	9/27/2024						Residential Single		
5	11:30	CP0501823	5707	Kippen	Clarence	Existing	Unit	Repair	
	9/10/2024						Residential Single		
5	13:30	CP0504301	5020	Salt Rd	Clarence	Existing	Unit	Repair	Wye
	9/18/2024						Residential Single		
5	11:30	CP0500579	5453	Village Station Cir	Clarence	Existing	Unit	Repair	

CLARENCE TOWN DISTRICTS

District	CTD	Insp Date	Permit	#	Street	Town	Permit Subtype	New/Existing	Property Type	Tap Type
5	2	9/4/2024 14:30	CP0504296	5618	Cannon Dr	Clarence Center	Clarence Iss	New	Residential Single Unit	Wye
5	2	9/27/2024 14:30	CP0504308	5654	Dorothy Cir	Clarence Center	Clarence Iss	New	Residential Single Unit	Wye
5	2	9/4/2024 14:00	CP0504298	5679	Dorothy Circle	Clarence Center	Clarence Iss	New	Residential Single Unit	Wye
5	2	9/9/2024 14:00	CP0504302	5711	Dorothy Circle	Clarence Center	Clarence Iss	New	Residential Single Unit	Wye
5	2	9/6/2024 14:30	CP0504300	5712	Dorothy Circle	Clarence Center	Clarence Iss	New	Residential Single Unit	Wye
5	4	9/11/2024 13:30	CP0504303	9731	Longleaf Tr	Clarence	Clarence Iss	New	Residential Single Unit	Wye
5	4	9/13/2024 14:00	CP0504304	5444	Waterlefe Dr	Clarence	Clarence Iss	New	Residential Single Unit	Wye
5	6	9/18/2024 11:00	CP0504305	8923	Country Club Dr	Clarence	Clarence Iss	New	Residential Single Unit	Wye

2024 SEPTEMBER MECHANICAL ROOTCUT DISTRICT # 1

<i>Notification</i>	<i>DATE</i>	<i>Description</i>	<i>Act. code text</i>	<i>Functional Loc.</i>	<i>HANDLE</i>	<i>L/F</i>
10181425	09/12/2024	TELEWISE CENTER 12" VTP	MECHANICAL ROOT CUT	E-S-N01-C-001-SL	BB50B	295
10182260	09/20/2024	TELEWISE CENTER 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-001-SL	BB514	350
10181421	09/19/2024	TELEWISE DENISE 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-005-SL	BBDCA	210

2024 SEPTEMBER MECHANICAL ROOTCUT DISTRICT # 4

NONE

2024 SEPTEMBER MECHANICAL ROOTCUT DISTRICT # 5

NONE

2024 SEPTEMBER TELEVISIONING DISTRICT #1 (CM)

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10181316	09/06/2024	TELEVISION CENTER 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB510	157
10181240	09/05/2024	TELEVISION ROWLEY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB54D	253
10181231	09/04/2024	TELEVISION ROWLEY HOLLOW 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB559	209
10181343	09/18/2024	TELEVISION WILLIAM 21" RCP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6B2	382
10182268	09/25/2024	TELEVISION HAWTHORNE 12" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB501	40
10182267	09/25/2024	TELEVISION HAWTHORNE 12" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB502	31
10182264	09/25/2024	TELEVISION HAWTHORNE 12" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB503	225
10182263	09/25/2024	TELEVISION HAWTHORNE 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB504	157
10182280	09/26/2024	TELEVISION HOMEWOOD 12" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB508	241
10181425	09/12/2024	TELEVISION CENTER 12" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB50B	295
10182261	09/24/2024	TELEVISION COMO PARK 8" ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB50E	165
10181318	09/24/2024	TELEVISION VITA 8" ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB50F	128
10182260	09/20/2024	TELEVISION CENTER 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB514	350
10181317	09/06/2024	TELEVISION CENTER 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB515	347
10182262	09/24/2024	TELEVISION VITA 8" ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB516	269
10181236	09/05/2024	TELEVISION ROWLEY HOLLOW 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB54E	136
10181235	09/05/2024	TELEVISION ROWLEY HOLLOW 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB54F	390
10181234	09/05/2024	TELEVISION ROWLEY HOLLOW 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB550	126
10181230	09/04/2024	TELEVISION ROWLEY HOLLOW 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB551	243
10181207	09/04/2024	TELEVISION ROWLEY HOLLOW 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB552	385
10181206	09/04/2024	TELEVISION ROWLEY HOLLOW 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB553	57
10181205	09/04/2024	TELEVISION ROWLEY HOLLOW 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB554	59
10181204	09/04/2024	TELEVISION ROWLEY HOLLOW 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB555	54
10181203	09/04/2024	TELEVISION ROWLEY HOLLOW 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB556	54
10181233	09/05/2024	TELEVISION ROWLEY HOLLOW 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB557	45
10181232	09/04/2024	TELEVISION ROWLEY HOLLOW 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB558	257

10181342	09/18/2024	TELEWISE UNION 21" RCP	TELEVISED - (CM)	E-S-N01-C-001-SL	BB4F0	397
10181426	09/11/2024	TELEWISE CENTER 8" ACP	TELEVISED - (CM)	E-S-N01-C-001-SL	10082668	37
10181421	9/19/2024	TELEWISE DENISE 8" VTP	TELEVISED - (CM)	E-S-N01-C-005-SL	BBDCA	210

SEPTEMBER 2024 I&I DISTRICT # 1

<i>Notification</i>	<i>DATE</i>	<i>Description</i>	<i>Act. code text</i>	<i>Functional Loc.</i>	<i>HANDLE</i>
10181281	09/12/2024	MANHOLE REPAIR @47 JEFFREY	REPAIRED FRAME JOINT LEAKS, MOD(4)	E-S-N01-C-004-MH	BA5CC
10181284	09/23/2024	MANHOLE REPAIR @ 82 LEMANS	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-004-MH	BA604
10181283	09/26/2024	MANHOLE REPAIR @ 74 LEMANS	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-004-MH	BA603
10181280	09/11/2024	MANHOLE REPAIR @ 59 JEFFREY	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-004-MH	BA5CB
10181282	09/19/2024	MANHOLE REPAIR @ 91 JEFFREY	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-004-MH	BA5C7
10179144	09/11/2024	MANHOLE REPAIR @ 51 GREGORY CT.	REPAIRED FRAME/CONE JOINT LEAKS, MOD(4)	E-S-N01-C-004-MH	BA5D8
10182152	09/06/2024	CASIMER -NSTALL NEW MH (CONT 46)	INSTALL NEW MANHOLE	E-S-N01-C-012-MH	10082660
10180095	09/17/2024	MANHOLE REPAIR @ 53 MARANN TERR.	REPAIRED FRAME JOINT LEAKS, MOD(4)	E-S-N01-C-012-MH	BAFBA
10182151	09/06/2024	CASIMER -REPLACE MH (CONT.46)	REPLACED FRAME AND COVER(5)	E-S-N01-C-012-MH	BAFA6
10182152	09/06/2024	CASIMER -NSTALL NEW MH (CONT 46)	REPLACED FRAME AND COVER(5)	E-S-N01-C-012-MH	10082660
10182151	09/06/2024	CASIMER -REPLACE MH (CONT.46)	REPLACED MANHOLE	E-S-N01-C-012-MH	BAFA6
10182153	09/06/2024	CASIMER - REPAIR 10" PIPE (CONT.46)	PIPE REPLACED - 10"	E-S-N01-C-012-SL	BC158
10182148	09/06/2024	CASIMER INSTALL 8" PVC (CONT. 46)	PIPE REPLACED - 8"	E-S-N01-C-012-SL	10082658
10182149	09/06/2024	ELECTRIC -INSTALL 8" PVC LINE (CONTR.46)	PIPE REPLACED - 8"	E-S-N01-C-012-SL	10082659

SEPTEMBER 2024 I&I DISTRICT # 4

10181125	09/05/2024	MANHOLE REPAIR @ 1164 PENORA	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N04-C-008-MH	DEDB0
10180132	09/10/2024	MANHOLE REPAIR @ 30 HICKORY LANE	RAISED MANHOLE(4)	E-S-N04-C-014-MH	10080322
10179165	09/10/2024	MANHOLE REPAIR @ 12 HICKORY	RAISED MANHOLE(4)	E-S-N04-C-014-MH	10080326

SEPTEMBER 2024 I&I DISTRICT # 5

10180027	09/13/2024	RAISE 6" CLEANOUT @ 5130 SALT RD	REPLACED	E-S-N05-C-009	
10178120	09/13/2024	LOCATE AND RAISE MH @ 9458 KRISTINA CIR.	RAISED MANHOLE(4)	E-S-N05-C-013-MH	1459

COMPLAINT SUMMARY ECSD #1 SEPTEMBER 2024

Notification	DATE	Description	Prob. code text	Functional Loc.
10181362	09/18/2024	BACK UP-11 DENISE	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-005-SL
10181219	09/17/2024	COMPLAINT NR DISTRICT 1	ODOR	E-S-N01-C-006-SL

COMPLAINT SUMMARY ECSD #4 SEPTEMBER 2024

10181272	09/24/2024	BACK UP-8230 WEHRLE	NO FURTHER WORK REQUIRED	E-S-N04-C-001-SL
10181218	09/11/2024	TOILET PAPER COMING OUT OF VENT	HOMEOWNER'S PROBLEM	E-S-N04-C-002-SL

COMPLAINT SUMMARY ECSD #5 SEPTEMBER 2024

10181321	09/11/2024	BACK UP - 8221 OLD POST RD, EAST AMHERST	REFERRED TO OTHERS	E-S-N05-C-001-SL
10182223	09/27/2024	SEWER BACKUP - 9250/9280 TRANSIT RD, AMH	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N05-C-004-SL

September 2024 Maintenance

District 1

Mowed and weed whacked 5 different times.
Completed painting interior floor, walls and ceiling at Nash Rd. meter pit building.
Trimmed bushes at Mineral Springs.
Rebuilt Cayuga spare pump, then delivered to station for storage.

District 4

Mowed and weed whacked 7 different times.
Added gear oil to Depew dry well hoist per the annual hoist inspections.
Replaced electric plug on lawn trailer.
Broke down and returned by pass pump from Warner.
Pulled and cleaned pump #2 at Bowmansville 3 different times.
Delivered Bowmansville's new spare pump to station.
Pulled and cleaned pump #1 at Iroquois.
Replaced air release on pump #4 at Depew.
Pulled and cleaned pump #1 at Bowmansville 2 different times.
Prepped Pleasantview drywell floor for painting, and began putting down a coat of primer.
Replaced HOA switch on Correctional Facility Muffin Monster.
Installed new Omni Unit at Pleasantview.
Installed new conduit at Pleasantview for alarm cabinet.
Redid control wiring at Pleasantview.
Calibrated gas detectors at base.
Swapped out bad omni unit at Zoeller with spare. Sent old unit out for repair.
Pulled wire for new HVAC unit at Depew.
Installed new breaker for new Depew HVAC.
Repaired temp sensor on portable godwin pump.
Installed new battery on pressure sensor for pump 5 at Depew.
Began running conduit for new meter pit at Depew.
Installed new thermostats at base for new HVAC Units.
Replaced lockset on Gas monitor at base.

District 5

Mowed and weed whacked at Cannon Woods.
Cleaned interior of station at Pinebreeze.
Replaced hour meter on Transit Valley Genset.
Replaced transducer at Bryant and Stratton.

All Districts

Checked generator fluids and topped off with fuel where needed on station generators.

Month:	September	2024	NR Flow Summary			
Station	SD	Total	Daily Avg	GPM	GPH	Tot Gal
		Hrs				
Borden-Clinton	1	454	15.1	200	12000	5,448,000
Cayuga	1	259	8.6	1190	71400	14,651,280
Clint-Tran	1	46	1.5	350	21000	966,000
Industrial Park	1	132	4.4	3650	219000	21,462,000
Union	1	42	1.4	850	51000	2,142,000
Woodlands	1	21	0.7	39	2340	49,140
Aurora South	4	32	1.1	705	42300	1,353,600
Bowmansville	4	623	20.8	1600	96000	59,808,000
Broadway	4	2	0.1	16000	960000	1,920,000
Depew	4	734	24.5	11000	660000	306,487,500
Forestream	4	40	1.3	1050	63000	2,520,000
Hall	4	55	1.8	130	7800	429,000
Haskell	4	16	0.5	590	35400	566,400
Iroquois	4	670	22.3	3000	180000	120,600,000
Pleasantview	4	114	3.8	950	57000	6,498,000
Vanderbilt	4	1	0.0	8000	480000	480,000
Warner	4	521	17.4	5000	300000	156,300,000
Zoeller	4	152	5.1	830	49800	7,569,600
Bryant	5	112	3.7	600	36000	4,032,000
Eastern Hills	5	131	4.4	625	37500	4,912,500
Forestview	5	23	0.8	554	33240	764,520
Creekwood	5	42	1.4	509	30540	1,282,680
Pinebreeze	5	40	1.3	325	19500	780,000
Stahley	5	49	1.6	720	43200	2,116,800
Transit Valley	5	72	2.4	450	27000	1,944,000
Total NR Flow:						725,083,020

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	10-Sep	1953		16	137	76	43		-	135
Cayuga	1	Under Generator	1300	33	39.39	5-Sep	826		30	1182	91	118		-	975
Clinton	1	Under Generator	150	24	6.25	10-Sep	1863		20	125	83	25		-	113
Industrial Parkway	1	Under Generator	700	30	23.33	10-Sep	703		28	653	93	47		-	525
Union	1	Under Generator	400	26	15.38	10-Sep	44		23	354	88	46		-	300
Aurora North	4	Under Generator	325	24	13.54					0	0	325		X	244
Aurora South	4	Under Generator	285	21	13.57	10-Sep	1731		17	231	81	54		-	214
Bowmansville	4	Under Generator	700	26	26.92	10-Sep	924		23	619	88	81		-	525
Broadway	4	Above-Ground	1000	36	*	5-Sep	310		32	770	77	230		-	750
Depew	4	Above-Ground	3000	69	*	5-Sep	490		53	2323	77	677		-	2250
Iroquois	4	Under Generator	295	17	17.35	10-Sep	1064		14	243	82	52		-	221
Vanderbilt	4	Above-Ground	1000	36	*	5-Sep			33	770	77	230		-	750
Warner	4	Under Generator	700	26	26.92	10-Sep	1830		23	619	88	81		-	525
Bryant	5	Under Generator	180	22	8.18	10-Sep	694		18	147	82	33		-	135
Pinebreeze	5	Under Generator	275	44	*	10-Sep	1328		40	259	94	16		-	206
Stahley	5	Under Generator	150	25	6.00	10-Sep	1512		20	120	80	30		-	113
Transit Valley	5	Above Ground	275	44	*	10-Sep			36	235	85	40		-	206

* Calculated

Refill at: 0.75

2024 September UFPO Numbers

(By District/Region)

Total UFPO Tickets:	2126
Tickets Outside ECSD Boundary	253

	Total Tickets	APR Code		Total %	Stakeout %
		10 - All Clear	30 - Staked Out		
District 1	224	170	54	11%	13%
District 4	307	246	61	14%	15%
District 5	142	111	31	7%	8%
Total NR	673	527	146	32%	36%

District 3	712	579	133	33%	33%
District 6	122	91	31	6%	8%
District 8	106	90	16	5%	4%
Total CR	940	760	180	44%	44%

District 2	260	178	82	12%	20%
Total SR	260	178	82	12%	20%

Totals:	1873	1465	408		
----------------	-------------	-------------	------------	--	--

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
OCTOBER 2024 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTALS	0	0	0
	0		

UFPO's	D1	D4	D5
Responses	235	307	234
Stakeouts	59	32	20
TOTAL STAKEOUTS	111		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	20,276	0	1,000	21,276

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint	7,961	0	1,000	8,961
By District	0	0	0	0

	D1	D4	D5	TOTALS
House Inspections	47			47
Reinspections	2			2
Violations	1			1
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
	39	6	0	45

Manhole Repairs	D1	D4	D5	TOTAL
	7	0	1	8

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control				0
Mechanical Root Cut	158	0	0	158
Mechanically Cleaned				0

Sewerline Repairs	D1 MS 9-TIMTAM (BBF0D)
	D1 MS 10-BROADWAY BACKLOT (BB46F)
	D1 MS 1- HOMEWOOD (BB508)
SSO	NONE

CONSTRUCTION		
D1	D4	D5
4814 TRANSIT	1352 COMMERCE PKWY	HARRIS HILL MIXED USE SITE
GARY LN. 2 LOT SUB.	BRADLEY EXTENSION	7149 TRANSIT
SONWIL WAREHOUSE	5050 O-REILLY AUTO	SPAULDING GREEN PH 8
51 RANSIER	BIG DITCH	DEER VALLEY ESTATES
THE SPRINGS AT WS	4510 BROADWAY APTS	9150 MAIN
2715 & 2725 CAR WASH -UNION	6140-6142 O REILLY AUTO PARTS	CLARENCE HIGHWAY
	LANCASTER VILLAGE PH 2	9150 MAIN
	5153 TRANSIT - THEOS PL	4199 TRANSIT COFFEE SHOP
	FIELDSTREAM SUB.	CLARENCE HIGHWAY
	VALVOLINE OIL CHANGE	6625 TRANSIT MIXED USE
	4781 TRANSIT	
	PLEASANTVIEW GARDENS	
	ANGRY BUFFALO	
	HIDDEN MEADOWS PH 2	
Plans Reviewed:	3881 BROADWAY LATERAL CONNECTION	
	UPSTATE NIAGARA EXPANSION	

ERIE COUNTY - SEWER DISTRICT 1,4,5
10/1/2024 TO 10/31/2024
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	4	8	12
Taps	0	0	0	0
Disconnect	0	0	1	1
Repair	3	5	1	9
TOTAL	3	9	10	22

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	0	0	0
Exist Commercial (EC)	0	0	1	1
New Residential (NR)	0	3	7	10
Exist Residential (ER)	0	1	0	1
TOTAL	0	4	8	12

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	0	0	0
Exist Commercial Issued (EC)	0	0	2	2
New Residential Issued (NR)	1	7	0	8
Exist Residential Issued (ER)	4	7	1	12
TOTAL	5	14	3	22

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$0	\$0	\$0	\$0
Exist Commercial Fees (EC)	\$0	\$0	\$704	\$704
New Residential Fees(NR)	\$702	\$2,814	\$0	\$3,516
Exist Residential Fees (ER)	\$8	\$364	\$2	\$374
TOTAL	\$710	\$3,178	\$706	\$4,594

DISTRICT #1

CONNECTIONS/REPAIRS

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	Permit Type
	10/11/2024							
1	12:00	CP0101986	1475	Borden Rd	Cheektowaga	Existing	Residential Single Unit	Repair
	10/3/2024			Mayberry Dr				
1	13:00	CP0104592	33	East	Cheektowaga	Existing	Residential Single Unit	Repair
	10/7/2024							
1	14:00	CP0111919	64	Bosse Ln	West Seneca	Existing	Residential Single Unit	Repair

DISTRICT #4

	10/15/2024						Residential Multiple		
4	14:00	CP0408816	1817	Como Park Blvd	Lancaster	Existing	Units	Repair	
				Enchanted Frst					
4	10/4/2024 13:00	CP0406266	262	N	Lancaster	Existing	Residential Single Unit	Repair	
4	10/2/2024 13:00	CP0404420	44	Pheasant Run	Lancaster	Existing	Residential Single Unit	Repair	
	10/25/2024								
4	14:00	CP0402261	53	Stutzman Rd	Lancaster	New	Residential Single Unit	Connection	Wye
	10/23/2024								
4	10:00	CP0401192	5225	William St.	Lancaster	Existing	Residential Single Unit	Connection	Wye
	10/22/2024				Lancaster				
4	14:00	CP0409727	18	Hickory Ln	(T)	New	Residential Single Unit	Connection	Wye
	10/21/2024				Lancaster				
4	14:00	CP0409731	18	Kevwood Ln	(T)	New	Residential Single Unit	Connection	Wye
	10/23/2024				Lancaster				
4	13:30	CP0409785	67	Holland Ave	(V)	Existing	Residential Single Unit	Repair	
	10/24/2024				Lancaster				
4	10:00	CP0409787	18	Laverack Ave	(V)	Existing	Residential Single Unit	Repair	

DISTRICT #5

CONNECTIONS/REPAIRS/DISCONNECT

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	Permit Type	Tap Type
5	10/24/2024 14:00	CP0504275	4927- 5105	Transit Rd	Clarence	Existing	Non-Residential Single Unit	Connection	Wye
5	10/21/2024 13:30	CP0500774	5017	Transit Rd	Clarence	Existing	Non-Residential Single Unit	Disconnect	
5	10/7/2024 10:30	CP0504282	6861	Transit Rd	Clarence	New	Residential Single Unit	Connection	Wye
5	10/7/2024 10:00	CP0504281	6863	Transit Rd	Clarence	New	Residential Single Unit	Connection	Wye
5	10/3/2024 14:00	CP0504280	6867	Transit Rd	Clarence	New	Residential Single Unit	Connection	Wye
5	10/3/2024 14:00	CP0504279	6869	Transit Rd	Clarence	New	Residential Single Unit	Connection	Wye
5	10/3/2024 14:00	CP0504278	6871	Transit Rd	Clarence	New	Residential Single Unit	Connection	Wye
5	10/22/2024 11:30	CP0500469	8340	West Point	Clarence	Existing	Residential Single Unit	Repair	

CLARENCE TOWN DISTRICTS

District	CTD	Insp Date	Permit	#	Street	New/Existing	Property Type	Permit Type	Tap Type	Comments
5	2	10/30/2024 14:30	CP0504294	5704	Dorothy Circle	New	Residential Single Unit	Connection	Wye	Clarence Issued-DSM Inspected
5	2	10/29/2024 14:00	CP0504309	5683	Dorothy Circle	New	Residential Single Unit	Connection	Wye	Clarence Issued-DSM inspected

COMPLAINT SUMMARY ECSD # 1 OCTOBER 2024

Notification	DATE	Description	Prob. code text	Functional Loc.
10180296	10/09/2024	BACK UP-92 BASSWOOD	BASEMENT FACILITY	E-S-N01-C-007-SL
COMPLAINT SUMMARY ECSD # 4 OCTOBER 2024				
10183158	10/22/2024	BACK UP-11 ROBINWOOD	HOMEOWNER'S PROBLEM	E-S-N04-C-003-SL
COMPLAINT SUMMARY ECSD # 5 OCTOBER 2024				
10182488	10/20/2024	MANHOLE - 6281 TRANSIT RD, EAST AMHERST	PUT ON LIST TO REPAIR	E-S-N05-C-004-MH

OCTOBER 2024 I&I DISTRICT # 1

<i>DATE</i>	<i>Description</i>	<i>Act. code text</i>	<i>Functional Loc.</i>	<i>HANDLE</i>
10/29/2024	SEWER REPAIR @ BROADWAY BACKLOT	PIPE REPLACED - 10"	E-S-N01-C-001-SL	BB46F
10/23/2024	SEWER REPAIR @ HOMEWOOD /COMO	PIPE REPLACED - 12"	E-S-N01-C-001-SL	BB508
10/16/2024	SEWER REPAIR @156 TIM TAM	PIPE REPLACED - 8"	E-S-N01-C-009-SL	BBF0D
10/28/2024	RAISE MANHOLE @ 861 SENECA CREEK	RAISED MANHOLE(4)	E-S-N01-C-010-MH	BB3F3
10/31/2024	MANHOLE REPAIR @ INDIAN CHURCH	RAISED MANHOLE(4)	E-S-N01-C-010-MH	BB07A
10/18/2024	MANHOLE REPAIR @ 120 SEBRING	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-004-MH	BA62D
10/23/2024	MANHOLE REPAIR @ 52 SEBRING	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-004-MH	BA624
10/02/2024	MANHOLE REPAIR @ 73 LEMANS	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-004-MH	BA602
10/28/2024	MANHOLE REPAIR @ VERONICA , SENECA CREEK	REPAIRED FRAME/CONE JOINT LEAKS, SEV(5)	E-S-N01-C-010-MH	3311
10/24/2024	MANHOLE REPAIR @ HOUGHTON PARK	REPLACED FRAME AND COVER(5)	E-S-N01-C-012-MH	BAAAA

OCTOBER 2024 I&I DISTRICT # 4

NONE

OCTOBER 2024 I&I DISTRICT # 5

10/20/2024	MANHOLE - 6281 TRANSIT RD, EAST AMHERST	REPLACED COVER	E-S-N05-C-004-MH	C079A
------------	---	----------------	------------------	-------

2024 OCTOBER MECHANICAL ROOTCUT DISTRICT # 1

<i>Notification</i>	<i>DATE</i>	<i>Description</i>	<i>Act. code text</i>	<i>Functional Loc.</i>	<i>HANDLE</i>	<i>L/F</i>
10182391	10/02/2024	TELEWISE FAIROAKS 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-001-SL	BB494	158

2024 OCTOBER MECHANICAL ROOTCUT DISTRICT # 4

NONE

2024 OCTOBER MECHANICAL ROOTCUT DISTRICT # 5

NONE

2024 OCTOBER TELEVISION DISTRICT # 1 (CM)

<i>Notification</i>	<i>DATE</i>	<i>Description</i>	<i>Act. code text</i>	<i>Functional Loc.</i>	<i>HANDLE</i>	<i>L/F</i>
10182343	10/02/2024	TELEVISION FAIROAKS 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB492	62
10182391	10/02/2024	TELEVISION FAIROAKS 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB494	158
10182364	10/08/2024	TELEVISION VERN 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB48D	348
10182363	10/08/2024	TELEVISION FAIRELM 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB48F	198
10182342	10/03/2024	TELEVISION SANDY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB490	79
10182344	10/03/2024	TELEVISION SANDY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB491	101
10182361	10/08/2024	TELEVISION FAIRELM 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB496	13
10182360	10/08/2024	TELEVISION FAIRELM 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB497	128
10182325	10/08/2024	TELEVISION WELLS 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB49B	319
10182324	10/04/2024	TELEVISION WELLS 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB498	43
10182362	10/08/2024	TELEVISION FAIRELM 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB495	43
10182365	10/08/2024	TELEVISION BINK 8"ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB4D2	356
10182409	10/09/2024	TELEVISION BINK 8"ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB4D3	430
10182408	10/09/2024	TELEVISION JANE 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB40C	327
10182407	10/09/2024	TELEVISION JANE 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB40D	347
10182405	10/09/2024	TELEVISION JANE 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6E6	349
10182397	10/11/2024	TELEVISION CEIL 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6E1	267
10182393	10/14/2024	TELEVISION CEIL 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6E3	266
10182394	10/11/2024	TELEVISION CEIL 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6DA	41
10182406	10/14/2024	TELEVISION CEIL 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6E2	311
10182395	10/11/2024	TELEVISION CEIL 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6E0	309
10182398	10/11/2024	TELEVISION JANE 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6DB	283
10182402	10/10/2024	TELEVISION JANE 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6DD	98
10182403	10/10/2024	TELEVISION JANE 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6DE	111
10182399	10/10/2024	TELEVISION JANE 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6DC	46
10182404	10/10/2024	TELEVISION JANE 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6E5	352
10182392	10/14/2024	TELEVISION JANE 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6DF	360

10182504	10/15/2024	TELEVISION ELLICOTT 8" ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB416	319
10182503	10/16/2024	TELEVISION ELLICOTT 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB417	288
10182502	10/16/2024	TELEVISION BROADWAY 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB418	252
10182501	10/16/2024	TELEVISION BROADWAY 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB419	238
10182507	10/16/2024	TELEVISION HOMEWOOD 12" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	73	178
10182506	10/15/2024	TELEVISION ELLICOTT 8" ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	14AC63	327
10182505	10/15/2024	TELEVISION OLD INDIAN 8" ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	14AC62	295
10182321	10/03/2024	TELEVISION FAIRELM 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	142CC2	61
10182322	10/03/2024	TELEVISION FAIRELM 8"VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	191795	258

2024 OCTOBER TELEVISIONING DISTRICT # 4 (CM)

NONE

2024 OCTOBER TELEVISIONING DISTRICT # 5 (CM)

10182279	10/01/2024	TELEVISION TRANSIT 8" PVC	TELEVISIONED - (CM)	E-S-N05-C-004-SL	C118E	355
10182340	10/01/2024	TELEVISION TRANSIT 8" PVC	TELEVISIONED - (CM)	E-S-N05-C-004-SL	C118F	271
10147578	10/01/2024	TELEVISION TRANSIT 8" PVC	TELEVISIONED - (CM)	E-S-N05-C-004-SL	C1190	374

October 2024 Maintenance

District 1

Completed VFD Inspection PM's at Cayuga and IPP.
Repaired Cayuga genset and installed new fuel filter with Penn Power.

District 4

Install new HVAC unit on Depew Pump Station roof.
Install New conduit at Depew for the new meter pit.
Install Omnisite at Foreststream.
Clean up control panel at Foreststream.
Completed VFD inspection PM's at Depew, Iroquois, Bowmansville, Warner, Vanderbilt, and Broadway.
Repaired Spare E-One pumps at Base and tested them.
Replaced temp sensor on Godwin pump NR4.
Installed dehumidifier at Nash road.
Adjusted thermostats at Warner.
Began designing drawings for Bowmansville and Warner soft start replacement.
Repaired the camera head on the TV truck.
Calibrated all gas detectors.

District 5

Install new power fail alarm at Transit Valley.
Replaced thermostat on Transit Valley control room heater.

All Districts

Tested all HWW floats.

October 2024 flows

Month:	October	2024	October 2023 Flows			
Station	SD	Total Hrs	Daily Avg	GPM	GPH	Tot Gal
Borden-Clinton	1	544	17.5	200	12000	6,528,000
Cayuga	1	305	9.8	1190	71400	16,707,600
Clint-Tran	1	48	1.5	350	21000	1,008,000
Industrial Park	1	136	4.4	3650	219000	23,454,900
Union	1	52	1.7	850	51000	2,652,000
Woodlands	1	34	1.1	39	2340	79,560
Aurora South	4	38	1.2	705	42300	1,607,400
Bowmansville	4	532	17.2	1600	96000	51,072,000
Broadway	4	0	0.0	16000	960000	0
Depew	4	870	28.1	11000	660000	358,875,000
Forestream	4	49	1.6	1050	63000	3,087,000
Hall	4	57	1.8	130	7800	444,600
Haskell	4	21	0.7	590	35400	743,400
Iroquois	4	840	27.1	3000	180000	151,200,000
Pleasantview	4	123	4.0	950	57000	7,011,000
Vanderbilt	4	0	0.0	8000	480000	0
Warner	4	544	17.5	5000	300000	163,200,000
Zoeller	4	187	6.0	830	49800	9,312,600
Bryant	5	127	4.1	600	36000	4,572,000
Eastern Hills	5	153	4.9	625	37500	5,737,500
Forestview	5	28	0.9	554	33240	930,720
Creekwood	5	52	1.7	509	30540	1,588,080
Pinebreeze	5	47	1.5	325	19500	916,500
Stahley	5	55	1.8	720	43200	2,376,000
Transit Valley	5	89	2.9	450	27000	2,403,000
Total NR Flow:						815,506,860

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	4-Oct	1958		18	154	86	26		-	135
Cayuga	1	Under Generator	1300	33	39.39	2-Oct	826		30	1182	91	118		-	975
Clinton	1	Under Generator	150	24	6.25	4-Oct	1868		21	131	88	19		-	113
Industrial Parkway	1	Under Generator	700	30	23.33	4-Oct	703		28	653	93	47		-	525
Union	1	Under Generator	400	26	15.38	4-Oct	48		21	323	81	77		-	300
Aurora North	4	Under Generator	325	24	13.54					0	0	325		X	244
Aurora South	4	Under Generator	285	21	13.57	4-Oct	1736		18	244	86	41		-	214
Bowmansville	4	Under Generator	700	26	26.92	4-Oct	924		23	619	88	81		-	525
Broadway	4	Above-Ground	1000	36	*	2-Oct	310		32	770	77	230		-	750
Depew	4	Above-Ground	3000	69	*	2-Oct	490		53	2323	77	677		-	2250
Iroquois	4	Under Generator	295	17	17.35	4-Oct	1069		15	260	88	35		-	221
Vanderbilt	4	Above-Ground	1000	36	*	2-Oct			33	770	77	230		-	750
Warner	4	Under Generator	700	26	26.92	4-Oct	1830		23	619	88	81		-	525
Bryant	5	Under Generator	180	22	8.18	4-Oct	694		18	147	82	33		-	135
Pinebreeze	5	Under Generator	275	44	*	4-Oct	1328		39	253	92	22		-	206
Stahley	5	Under Generator	150	25	6.00	4-Oct	1516		24	144	96	6		-	113
Transit Valley	5	Above Ground	275	44	*	4-Oct	3.8		41	264	96	11		-	206

* Calculated

Refill at: 0.75

2024 October UFPO Numbers

(By District/Region)

Total UFPO Tickets:	2207
Tickets Outside ECSD Boundary	284

	Total Tickets	APR Code		Total %	Stakeout %
		10 - All Clear	30 - Staked Out		
District 1	235	176	59	11%	18%
District 4	307	275	32	14%	10%
District 5	234	214	20	11%	6%
Total NR	776	665	111	35%	33%

District 3	766	645	121	35%	36%
District 6	114	85	29	5%	9%
District 8	94	81	13	4%	4%
Total CR	974	811	163	44%	49%

District 2	173	115	58	8%	17%
Total SR	173	115	58	8%	17%

Totals:	1923	1591	332		
----------------	-------------	-------------	------------	--	--

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
NOVEMBER 2024 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTALS	0	0	0
	0		

UFPO's	D1	D4	D5
Responses	125	163	90
Stakeouts	32	49	11
TOTAL STAKEOUTS	92		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	31,319	1,034	0	32,353

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint	5,468	0	0	5,468
By District	731	0	0	731

	D1	D4	D5	TOTALS
House Inspections	36	1		37
Reinspections	1			1
Violations				0
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
	40	53	0	93

Manhole Repairs	D1	D4	D5	TOTAL
	8	3	0	11

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control				0
Mechanical Root Cut	524	0	0	524
Mechanically Cleaned				0

Sewerline Repairs	D1 MS 1- OLD STONE -(BB69D) SEWER REPAIR 8"
SSO	
NONE	

CONSTRUCTION		
D1	D4	D5
4814 TRANSIT	1352 COMMERCE PKWY	HARRIS HILL MIXED USE SITE
GARY LN. 2 LOT SUB.	BRADLEY EXTENSION	7149 TRANSIT
SONWIL WAREHOUSE	5050 O-REILLY AUTO	SPAULDING GREEN PH 8
51 RANSIER	BIG DITCH	DEER VALLEY ESTATES
THE SPRINGS AT WS	4510 BROADWAY APTS	9150 MAIN
2715 & 2725 CAR WASH -UNION	6140-6142 O REILLY AUTO PARTS	CLARENCE HIGHWAY
	LANCASTER VILLAGE PH 2	9150 MAIN
	5153 TRANSIT - THEOS PL	4199 TRANSIT COFFEE SHOP
	FIELDSTREAM SUB.	CLARENCE HIGHWAY
	VALVOLINE OIL CHANGE	6625 TRANSIT MIXED USE
	4781 TRANSIT	
	PLEASANTVIEW GARDENS	
	ANGRY BUFFALO	
	HIDDEN MEADOWS PH 2	
PLAN REVIEWS	D4- 3972 WALDEN DOLLAR GENERAL	
	D4- JAGG ELECTRICAL /CONTROL	
	D4-SEIBEL MFG. CEMETARY RD.	
	D5- RESURGENCE TAP ROOM	

COMPLAINT SUMMARY ECSD # 1 NOVEMBER 2024

<i>Notification</i>	<i>DATE</i>	<i>Description</i>	<i>Prob. code text</i>	<i>Functional Loc.</i>
10183523	11/21/2024	MANHOLES HIGH W/SEWAGE-70 GARDEN VILLAGE	HOMEOWNER'S PROBLEM	E-S-N01-C-006
10183248	11/02/2024	BROKEN MANHOLE COVER - 2730 UNION RD, CH	OTHER (DESCRIBE IN LONG TEXT)	E-S-N01-C-001-SL
10184188	11/25/2024	ODOR - 102 YVETTE DR, CHEEKTOWAGA	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-006-SL
10183422	11/15/2024	MANHOLE - NR 3512 CLINTON, WEST SENECA	NO FURTHER WORK REQUIRED	E-S-N01-C-009-MH

COMPLAINT SUMMARY ECSD # 4 NOVEMBER 2024

NONE

COMPLAINT SUMMARY ECSD # 5 NOVEMBER 2024

10183488	11/23/2024	SEWER BACKUP - 8290 WEST POINT DR, E AMH	HOMEOWNER'S PROBLEM	E-S-N05-C-005-SL
----------	------------	--	---------------------	------------------

NOVEMBER 2024 I&I DISTRICT # 1

<i>Notification</i>	<i>DATE</i>	<i>Description</i>	<i>Act. code text</i>	<i>Functional Loc.</i>	<i>HANDLE</i>
10183272	11/04/2024	MANHOLE REPAIR @ 2730 UNION	REPLACED FRAME AND COVER(5)	E-S-N01-C-001-MH	BA89C
10181216	11/18/2024	SEWER REPAIR 84 OLD STONE RD	PIPE REPLACED - 8"	E-S-N01-C-001-SL	BB69D
10183181	11/01/2024	MANHOLE REPAIR @ 81 ZURBRICK	REPAIRED FRAME JOINT LEAKS, SEV(5)	E-S-N01-C-004-MH	BA4E7
10182450	11/18/2024	MANHOLE REPAIR @ WEST CAVALIER	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-007-MH	BAEE7
10182453	11/21/2024	MANHOLE REPAIR @ WEST CAVALIER	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-007-MH	BAEE5
10182450	11/18/2024	MANHOLE REPAIR @ WEST CAVALIER	REPLACED FRAME AND COVER(5)	E-S-N01-C-007-MH	BAEE7
10182453	11/21/2024	MANHOLE REPAIR @ WEST CAVALIER	REPLACED FRAME AND COVER(5)	E-S-N01-C-007-MH	BAEE5
10183424	11/15/2024	MANHOLE REPAIR @ 3512 CLINTON	REPLACED FRAME AND COVER(5)	E-S-N01-C-009-MH	BB148

NOVEMBER 2024 I&I DISTRICT # 4

10184172	11/25/2024	MANHOLE REPAIR @ 30 WARD	REPAIRED FRAME/CONE JOINT LEAKS, SLT(3)	E-S-N04-C-007-MH	DE736
10184171	11/25/2024	MANHOLE REPAIR @ 40 WARD	REPAIRED FRAME/CONE JOINT LEAKS, SLT(3)	E-S-N04-C-007-MH	DE735
10180405	11/08/2024	MANHOLE REPAIR @ 26 HUNTER	RAISED MANHOLE(4)	E-S-N04-C-007-MH	17A154

NOVEMBER 2024 I&I DISTRICT # 5

NONE

2024 NOVEMBER MECHANICAL ROOTCUT DISTRICT # 1

<i>Notification</i>	<i>DATE</i>	<i>Description</i>	<i>Act. code text</i>	<i>Functional Loc.</i>	<i>HANDLE</i>	<i>L/F</i>
10184248	11/25/2024	TELEWISE HOMEWOOD 10"VTP	MECHANICAL ROOT CUT	E-S-N01-C-001-SL	BB509	204
10184161	11/26/2024	TELEWISE 8" VTP @ 54 YVETTE	MECHANICAL ROOT CUT	E-S-N01-C-006-SL	BBC35	320

2024 NOVEMBER MECHANICAL ROOTCUT DISTRICT # 4

NONE

2024 NOVEMBER MECHANICAL ROOTCUT DISTRICT # 5

NONE

2024 NOVEMBER TELEVISION DISTRICT # 1 (CM)

<i>Notification</i>	<i>DATE</i>	<i>Description</i>	<i>Act. code text</i>	<i>Functional Loc.</i>	<i>Activity text</i>	<i>L/F</i>
10183514	11/14/2024	TELEVISION CAYUGA CREEK 8" ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6C0	270
10183513	11/14/2024	TELEVISION CAYUGA CREEK 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	10E571	69
10183274	11/01/2024	TELEVISION CAYUGA CREEK 8" ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6CB	383
10183429	11/06/2024	TELEVISION CAYUGA CREEK 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	10EE59	71
10183273	11/01/2024	TELEVISION COMO PARK 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB4A9	274
10183440	11/13/2024	TELEVISION CAYUGA CREEK 8"ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6C1	336
10183441	11/13/2024	TELEVISION CAYUGA CREEK 8"ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6C2	235
10183442	11/13/2024	TELEVISION CAYUGA CREEK 8"ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6C3	228
10183501	11/14/2024	TELEVISION CAYUGA CREEK 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6C9	344
10183426	11/12/2024	TELEVISION CAYUGA CREEK 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6CA	287
10183286	11/01/2024	TELEVISION CAYUGA CREEK 8" ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6CC	350
10183278	11/01/2024	TELEVISION CAYUGA CREEK 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6D7	357
10183333	11/01/2024	TELEVISION CAYUGA CREEK 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6E8	107
10183460	11/01/2024	TELEVISION CAYUGA CREEK 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6E9	246
10183427	11/08/2024	TELEVISION CAYUGA CREEK 8"ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6EA	356
10183428	11/06/2024	TELEVISION CAYUGA CREEK 8"PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6EB	421
10183425	11/13/2024	TELEVISION CAYUGA CREEK 8"PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	19BB5A	337
10182454	11/01/2024	TELEVISION CAYUGA CREEK 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	10082730	145
10183323	11/05/2024	TELEVISION JESSICA 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-007-SL	BBA1E	315
10179152	11/06/2024	TELEVISION 8" PVC @ 150 SEIBERT	TELEVISIONED - (CM)	E-S-N04-C-015-SL	DFB36	337

2024 NOVEMBER TELEVISIONING DISTRICT # 1 (DISTRICT)

<i>Notification</i>	<i>DATE</i>	<i>Description</i>	<i>Act. code text</i>	<i>Functional Loc.</i>	<i>HANDLE</i>	<i>L/F</i>
10184244	11/25/2024	TELEVISION WELLS 8"VTP	TELEVISIONED - (D)	E-S-N01-C-001-SL	BB49C	320
10184248	11/25/2024	TELEVISION HOMEWOOD 10"VTP	TELEVISIONED - (D)	E-S-N01-C-001-SL	BB509	204
10184246	11/25/2024	TELEVISION CENTER 8" VTP	TELEVISIONED - (D)	E-S-N01-C-001-SL	BB50A	207

2024 NOVEMBER TELEVISIONING DISTRICT # 4 (DISTRICT)

NONE

2024 NOVEMBER TELEVISIONING DISTRICT # 5 (DISTRICT)

NONE

ERIE COUNTY - SEWER DISTRICT 1,4,5
11/1/2024 TO 11/30/2024
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	0	1	1
Taps	1	0	0	1
Disconnect	0	0	0	0
Repair	4	8	4	16
TOTAL	5	8	5	18

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	1	0	1
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	1	0	1	2
Exist Residential (ER)	0	0	0	0
TOTAL	1	1	1	3

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	2	2	0	4
Exist Commercial Issued (EC)	0	0	0	0
New Residential Issued (NR)	0	1	1	2
Exist Residential Issued (ER)	6	11	4	21
TOTAL	8	14	5	27

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$1,404	\$3,606	\$0	\$5,010
Exist Commercial Fees (EC)	\$0	\$0	\$0	\$0
New Residential Fees(NR)	\$0	\$702	\$0	\$702
Exist Residential Fees (ER)	\$12	\$22	\$8	\$42
TOTAL	\$1,416	\$4,330	\$8	\$5,754

DISTRICT #1

CONNECTIONS/REPAIRS

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	Permit Type	Tap Type
1	11/25/2024 10:30	CP0111917	1052	Borden Rd	Cheektowaga	New	Residential Single Unit	Connection	Tap
1	11/26/2024 13:00	CP0100979	3886	Clinton St	Cheektowaga	Existing	Residential Single Unit	Repair	
1	11/21/2024 13:00	CP0105636	899	French Rd	Cheektowaga	Existing	Residential Single Unit	Repair	
1	11/15/2024 13:00	CP0101326	142	Cresthaven Drive	West Seneca	Existing	Residential Single Unit	Repair	
1	11/12/2024 1:30	CP0108663	205	Schultz Rd	West Seneca	Existing	Residential Single Unit	Repair	

DISTRICT #4

CONNECTIONS/REPAIRS

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	Permit Type
4	11/7/2024 14:00	CP0409793	105	Houston St	Depew	Existing	Residential Single Unit	Repair
4	11/11/2024 14:00	CP0409794	46	Wyandotte St	Depew	Existing	Residential Single Unit	Repair
4	11/15/2024 13:30	CP0406244	236	Enchanted Forest N	Lancaster	Existing	Residential Single Unit	Repair
4	11/27/2024 13:00	CP0409136	85	Laverack Ave	Lancaster	Existing	Residential Single Unit	Repair
4	11/29/2024 13:00	CP0403231	31	Spruceland	Lancaster	Existing	Residential Single Unit	Repair
4	11/13/2024 13:00	CP0409765	5057	Transit Rd	Lancaster (T)	New	Non-Residential Single Unit	Connection

4	11/11/2024 13:30	CP0409795	339	Aurora St	Lancaster (V)	Existing	Residential Single Unit	Repair
4	11/8/2024 13:30	CP0409796	63	Cotton St	Lancaster (V)	Existing	Residential Single Unit	Repair
4	11/7/2024 11:30	CP0409792	20	Kurtz Ave	Lancaster (V)	Existing	Residential Single Unit	Repair

DISTRICT #5

CONNECTIONS/REPAIRS

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	Permit Type
5	11/26/2024 13:30	CP0501591	5571	Pine Loch Lane	Clarence	Existing	Residential Single Unit	Repair
5	11/8/2024 13:00	CP0504311	9361	Roll Rd	Clarence	Existing	Residential Single Unit	Repair
5	11/14/2024 12:00	CP0501458	8180	Roseville Ln	Clarence	Existing	Residential Single Unit	Repair
5	11/15/2024 12:30	CP0500495	6700	Westminster Dr	Clarence	Existing	Residential Single Unit	Repair

CLARENCE TOWN DISTRICTS

District	CT D	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	Permit Type	Tap Type	Comments
5		11/7/2024 11:00	CP0504310	8931	Country Club Dr	Clarence	New	Residential Single Unit	Connection	Wye	Clarence Issued-DSM inspected

Month:	November	2024	NR Flow Summary			
Station	SD	Total	Daily Avg	GPM	GPH	Tot Gal
		Hrs				
Borden-Clinton	1	34220	1140.7	200	12000	410,640,000
Cayuga	1	268	8.9	1190	71400	15,079,680
Clint-Tran	1	33	1.1	350	21000	693,000
Industrial Park	1	148	4.9	3650	219000	25,601,100
Union	1	42	1.4	850	51000	2,142,000
Woodlands	1	18	0.6	39	2340	42,120
Aurora South	4	36	1.2	705	42300	1,522,800
Bowmansville	4	462	15.4	1600	96000	44,352,000
Broadway	4	0	0.0	16000	960000	0
Depew	4	724	24.1	11000	660000	302,775,000
Forestream	4	44	1.5	1050	63000	2,772,000
Hall	4	81	2.7	130	7800	631,800
Haskell	4	18	0.6	590	35400	637,200
Iroquois	4	671	22.4	3000	180000	120,780,000
Pleasantview	4	108	3.6	950	57000	6,156,000
Vanderbilt	4	1	0.0	8000	480000	480,000
Warner	4	412	13.7	5000	300000	123,600,000
Zoeller	4	156	5.2	830	49800	7,768,800
Bryant	5	109	3.6	600	36000	3,924,000
Eastern Hills	5	142	4.7	625	37500	5,325,000
Forestview	5	24	0.8	554	33240	797,760
Creekwood	5	41	1.4	509	30540	1,252,140
Pinebreeze	5	43	1.4	325	19500	838,500
Stahley	5	51	1.7	720	43200	2,203,200
Transit Valley	5	75	2.5	450	27000	2,025,000
Total NR Flow:						1,082,039,100

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	22-Nov	1966		16	137	76	43		-	135
Cayuga	1	Under Generator	1300	33	39.39	13-Nov	829		28	1103	85	197		-	975
Clinton	1	Under Generator	150	24	6.25	22-Nov	1877		20	125	83	25		-	113
Industrial Parkway	1	Under Generator	700	30	23.33	22-Nov	703		28	653	93	47		-	525
Union	1	Under Generator	400	26	15.38	22-Nov	57		25	385	96	15		-	300
Aurora North	4	Under Generator	325	24	13.54					0	0	325		X	244
Aurora South	4	Under Generator	285	21	13.57	22-Nov	1744		17	231	81	54		-	214
Bowmansville	4	Under Generator	700	26	26.92	21-Nov	924		23	619	88	81		-	525
Broadway	4	Above-Ground	1000	36	*	13-Nov	310		32	770	77	230		-	750
Depew	4	Above-Ground	3000	69	*	13-Nov	490		52	2277	76	723		-	2250
Iroquois	4	Under Generator	295	17	17.35	22-Nov	1077		13	226	76	69		-	221
Vanderbilt	4	Above-Ground	1000	36	*	13-Nov			33	770	77	230		-	750
Warner	4	Under Generator	700	26	26.92	22-Nov	1835		23	619	88	81		-	525
Bryant	5	Under Generator	180	22	8.18	21-Nov	694		18	147	82	33		-	135
Pinebreeze	5	Under Generator	275	44	*	21-Nov	1328		39	253	92	22		-	206
Stahley	5	Under Generator	150	25	6.00	21-Nov	1529		22	132	88	18		-	113
Transit Valley	5	Above Ground	275	44	*	21-Nov	10		39	253	92	22		-	206

* Calculated

Refill at: 0.75

November 2024 Maintenance

District 1

Cleaned up leaves at Woodlands and Union.
Assisted changing booster pump on Cayuga boiler.
Upgraded telemetry to OmniSite at Forestream.
Cleaned up control cabinet and ran new conduit for pump controls at Forestream.
Topped off glycol in Cayuga HVAC system.

District 4

Continued painting on Broadway interior walls.
Unjammed muffin monster at Prison.
Cleaned up fallen trees at Pleasantview.
Pulled and cleaned pump #1 at Bowmansville twice.
Pulled and cleaned pump #2 at Bowmansville twice.
Winterized cooling tower at base.
Replaced batteries on NR40.
Mowed and weed whacked at base.
Prepped plows for winter season.
Cleaned up leaves at Iroquois and Warner.
Completed end of year service on all 3 lawn mowers and put them in storage.
Replaced cutting edge on plow for NR54.
Fixed front garage heater at NR base.
Repaired pump 1 at boathouse and cleaned wet well.

District 5

Set up bypass pump and temporary fence at Eastern Hills.
Reset float back up alarm at Creekwood.
Replaced DO sensor at CRP

All Districts

Checked all fluids on station generators.
Installed plow stakes at stations for winter season.
Tested HWW floats at all pump stations.

2024 November UFPO Numbers

(By District/Region)

Total UFPO Tickets:	1310
Tickets Outside ECSD Boundary	224

	Total Tickets	APR Code		Total %	Stakeout %
		10 - All Clear	30 - Staked Out		
District 1	125	93	32	10%	11%
District 4	163	114	49	12%	16%
District 5	90	79	11	7%	4%
Total NR	378	286	92	29%	31%

District 3	423	334	89	32%	30%
District 6	82	50	32	6%	11%
District 8	64	53	11	5%	4%
Total CR	569	437	132	43%	44%

District 2	139	65	74	11%	25%
Total SR	139	65	74	11%	25%

Totals:	1086	788	298		
----------------	------	-----	-----	--	--

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
DECEMBER 2024 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTALS			

UFPO's	D1	D4	D5
Responses	116	174	58
Stakeouts	47	42	18
TOTAL STAKEOUTS	107		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	1,682	178	0	1,860

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint				0
By District	1,325	0	0	1,325

	D1	D4	D5	TOTALS
House Inspections	7			7
Reinspections				0
Violations				0
Dye Tests	6			6

Manhole Inspections	D1	D4	D5	TOTAL
	211	137	0	348

Manhole Repairs	D1	D4	D5	TOTAL
	7	3	4	14

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control	0	0	0	0
Mechanical Root Cut	1,325	0	0	1,325
Mechanically Cleaned				0

Sewerline Repairs	NONE
Sanitary Sewer Overflow	NONE

CONSTRUCTION		
DISTRICT 1	DISTRICT 4	DISTRICT 5
4814 TRANSIT	1352 COMMERCE PKWY	HARRIS HILL MIXED USE SITE
GARY LN. 2 LOT SUB.	BRADLEY EXTENSION	7149 TRANSIT
SONWIL WAREHOUSE	6781 TRANSIT	SPAULDING GREEN PH 8
51 RANSIER	BIG DITCH	DEER VALLEY ESTATES
THE SPRINGS AT WS	4510 BROADWAY APTS	9150 MAIN
2715 & 2725 CAR WASH -UNION	6140-6142 O REILLY AUTO PARTS	CLARENCE HIGHWAY
CHASE BANK - TRANSIT RD.	LANCASTER VILLAGE PH 2	9150 MAIN
UPSTATE NIAGARA 3300 N.AMERICA	5153 TRANSIT - THEOS PL	4199 TRANSIT COFFEE SHOP
3881 BROADWAY TIE IN	FIELDSTREAM SUB.	CLARENCE HIGHWAY
	VALVOLINE OIL CHANGE	6625 TRANSIT MIXED USE
	4781 TRANSIT	
	PLEASANTVIEW GARDENS	
	ANGRY BUFFALO	
	HIDDEN MEADOWS PH 2	
	3825 BOWTIE PARK	
	CEMETARY RD. SEIBEL	

Plans Reviewed:	
	DISTRICT 4- WOOD SPRING SANITARY EXTENSION

ERIE COUNTY - SEWER DISTRICT 1,4,5
12/1/2024 TO 12/31/2024
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	1	1	2
Taps	0	0	0	0
Disconnect	0	0	0	0
Repair	2	11	1	14
TOTAL	2	12	2	16

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	0	0	0
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	0	1	1	2
Exist Residential (ER)	0	0	0	0
TOTAL	0	1	1	2

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	1	0	1
Exist Commercial Issued (EC)	0	0	0	0
New Residential Issued (NR)	0	0	0	0
Exist Residential Issued (ER)	2	12	1	15
TOTAL	2	13	1	16

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$0	\$702	\$0	\$702
Exist Commercial Fees (EC)	\$0	\$0	\$0	\$0
New Residential Fees(NR)	\$0	\$0	\$0	\$0
Exist Residential Fees (ER)	\$4	\$24	\$2	\$30
TOTAL	\$4	\$726	\$2	\$732

DISTRICT 1
CONNECTIONS/REPAIRS

District	Insp Date	#	Street	Town	New/Existing	Property Type	Permit Type
1	12/12/2024 13:00	999	Losson Rd	Cheektowaga	Existing	Residential Single Unit	Repair
1	12/9/2024 13:30	153	Wetherstone Dr.	West Seneca	Existing	Residential Single Unit	Repair

DISTRICT 4
CONNECTIONS/REPAIRS

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	Permit Type	Tap Type
4	12/17/2024 8:00	CP040977 7	84	Alys Dr	Depew	Existing	Residential Single Unit	Repair	
4	12/20/2024 8:00	CP040980 1	10 9	Darwin Dr	Depew	Existing	Residential Single Unit	Repair	
4	12/18/2024 8:00	CP040977 8	39	Harvard Ave	Depew	Existing	Residential Single Unit	Repair	
4	12/16/2024 8:00	CP040977 6	72	Pamela Dr	Depew	Existing	Residential Single Unit	Repair	
4	12/4/2024 13:00	CP040328 8	5	Robins Nest Ct	Lancaster	Existing	Residential Single Unit	Repair	
4	12/30/2024 11:30	CP040041 6	16	Rose St	Lancaster	Existing	Residential Single Unit	Repair	
4	12/14/2024 8:00	CP040977 5	58	Taft Ave	Lancaster	Existing	Residential Single Unit	Repair	
4	12/9/2024 8:00	CP040978 3	62 6	Columbia Ave	Lancaster (T)	Existing	Residential Single Unit	Repair	

4	12/9/2024	CP040979		Greenmeadow	Lancaster					
	13:00	9	22	Dr	(T)	Existing	Residential Single Unit	Repair		
4	12/26/2024	CP040978			Lancaster		Residential Multiple			
	11:00	2	5	Hickory Ln	(T)	New	Units	Connection	Wye	
4	12/19/2024	CP040977	12		Lancaster					
	8:00	9	7	4th Ave	(V)	Existing	Residential Single Unit	Repair		
4	12/6/2024	CP040980			Lancaster					
	11:30	0	10	Grant St	(V)	Existing	Residential Single Unit	Repair		

DISTRICT 5

CONNECTIONS/REPAIRS

District	Insp Date	#	Street	Town	New/Existing	Property Type	Permit Type
5	12/26/2024					Residential Single	
	11:30	8355	Black Walnut Dr	Clarence	Existing	Unit	Repair

CLARENCE TOWN DISTRICTS

District	CTD	Insp Date	#	Street	Town	Permit Subtype	New/Existing	Property Type	Permit Type	Tap Type	Comments
5	4	12/20/2024		Longleaf							
		13:00	9741	Tr	Clarence	Clarence Iss	New	Residential Single Unit	Connection	Wye	Clarence Issued-DSM inspected

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	17-Dec	1970		15	129	71	51		X	135
Cayuga	1	Under Generator	1300	33	39.39	10-Dec	834		27	1064	82	236		-	975
Clinton	1	Under Generator	150	24	6.25	17-Dec	1886		19	119	79	31		-	113
Industrial Parkway	1	Under Generator	700	30	23.33	17-Dec	705		26	607	87	93		-	525
Union	1	Under Generator	400	26	15.38	17-Dec	61		24	369	92	31		-	300
Aurora North	4	Under Generator	325	24	13.54					0	0	325		X	244
Aurora South	4	Under Generator	285	21	13.57	17-Dec	1748		17	231	81	54		-	214
Bowmansville	4	Under Generator	700	26	26.92	17-Dec	924		23	619	88	81		-	525
Broadway	4	Above-Ground	1000	36	*	10-Dec	310		16	321	32	679		X	750
Depew	4	Above-Ground	3000	69	*	10-Dec	490		52	2277	76	723		-	2250
Iroquois	4	Under Generator	295	17	17.35	17-Dec	1080		12	208	71	87		X	221
Vanderbilt	4	Above-Ground	1000	36	*	10-Dec			33	321	32	679		X	750
Warner	4	Under Generator	700	26	26.92	17-Dec	1838		16	431	62	269		X	525
Bryant	5	Under Generator	180	22	8.18	17-Oct	694		18	147	82	33		-	135
Pinebreeze	5	Under Generator	275	44	*	17-Dec	13		38	248	90	27		-	206
Stahley	5	Under Generator	150	25	6.00	17-Dec			21	126	84	24		-	113
Transit Valley	5	Above Ground	275	44	*	17-Dec	1328		39	253	92	22		-	206

* Calculated

Refill at: 0.75

DECEMBER 2024 FLOWS

Month:	DECEMBER	2024	NR Flow Summary			
Station	SD	Total Hrs	Daily Avg	GPM	GPH	Tot Gal
Borden-Clinton	1	411	13.3	200	12000	4,932,000
Cayuga	1	667	21.5	1190	71400	32,986,800
Clint-Tran	1	111	3.6	350	21000	2,331,000
Industrial Park	1	360	11.6	3650	219000	88,300,800
Union	1	63	2.0	850	51000	3,213,000
Woodlands	1	21	0.7	39	2340	49,140
Aurora South	4	56	1.8	705	42300	2,368,800
Bowmansville	4	462	14.9	1600	96000	44,352,000
Broadway	4	12	0.4	16000	960000	11,520,000
Depew	4	870	28.1	11000	660000	367,537,500
Forestream	4	73	2.4	1050	63000	4,599,000
Hall	4	153	4.9	130	7800	1,193,400
Haskell	4	29	0.9	590	35400	1,026,600
Iroquois	4	648	20.9	3000	180000	116,640,000
Pleasantview	4	170	5.5	950	57000	9,690,000
Vanderbilt	4	3	0.1	8000	480000	1,440,000
Warner	4	499	16.1	5000	300000	149,700,000
Zoeller	4	200	6.5	830	49800	9,960,000
Bryant	5	135	4.4	600	36000	4,860,000
Eastern Hills	5	173	5.6	625	37500	6,487,500
Forestview	5	34	1.1	554	33240	1,130,160
Creekwood	5	53	1.7	509	30540	1,618,620
Pinebreeze	5	57	1.8	325	19500	1,111,500
Stahley	5	69	2.2	720	43200	2,980,800
Transit Valley	5	53	1.7	450	27000	1,431,000
Total NR Flow:						871,459,620

Notes

COMPLAINT SUMMARY ECSD # 1 DECEMBER 2024

<i>Notification</i>	<i>DATE</i>	<i>Description</i>	<i>Prob. code text</i>	<i>Functional Loc.</i>
10184228	12/06/2024	SEWER BACKUP - 740 CINDY LN, WEST SENECA	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-010-SL
10184483	12/31/2024	SINKHOLE-802 SENECA CREEK	REFERRED TO OTHERS	E-S-N01-C-010-SL

COMPLAINT SUMMARY ECSD # 4 DECEMBER 2024

10184275	12/03/2024	BACK UP-49 CHARLTON	HOMEOWNER'S PROBLEM	E-S-N04-C-005-SL
10184441	12/20/2024	BACK UP-626 COLUMBIA	NO FURTHER WORK REQUIRED	E-S-N04-C-005-SL
10184442	12/23/2024	BACK UP- 27 STONE HEDGE	HOMEOWNER'S PROBLEM	E-S-N04-C-007-SL
10184350	12/12/2024	SEWER BACKUP - 1 MONTAUK LN, LANCASTER	HOMEOWNER'S PROBLEM	E-S-N04-C-010-SL
10184290	12/06/2024	SEWER BACKUP - 36 HIDDEN TRL, LANCASTER	HOMEOWNER'S PROBLEM	E-S-N04-C-013-SL

COMPLAINT SUMMARY ECSD # 5 DECEMBER 2024

10184276	12/04/2024	HIGH MANHOLE-INTERSEC GREINER & BROOKHAV	NO FURTHER WORK REQUIRED	E-S-N05-C-009-MH
----------	------------	--	--------------------------	------------------

DECEMBER 2024 I&I DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE
10184251	12/27/2024	MANHOLE REPAIR @ GABRIELLE	RAISED MANHOLE(4)	E-S-N01-C-006-MH	BAEB5
10185245	12/27/2024	MANHOLE REPAIR @ CAPRICE	RAISED MANHOLE(4)	E-S-N01-C-007-MH	BB330
10184201	12/17/2024	MANHOLE REPAIR @ MORRIS CRES.	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-007-MH	1B95A6
10184200	12/17/2024	MANHOLE REPAIR @ 50 MORRIS CRES.	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-007-MH	19DB5D
10184199	12/17/2024	MANHOLE REPAIR @ 205 MARRANO	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-007-MH	BB2C3
10157730	12/19/2024	MANHOLE REPAIR @ 51 BRENTWOOD (RELIEF)	REPLACED FRAME AND COVER(5)	E-S-N01-C-005-MH	BAD01
10185245	12/27/2024	MANHOLE REPAIR @ CAPRICE	REPLACED FRAME AND COVER(5)	E-S-N01-C-007-MH	BB330

DECEMBER 2024 I&I DISTRICT # 4

10173604	12/19/2024	MANHOLE REPAIR @ HESS /KATHERINE	RAISED MANHOLE(4)	E-S-N04-C-005-MH	EABC7
10184250	12/20/2024	MANHOLE REPAIR @ 386 SENECA PL.	RAISED MANHOLE(4)	E-S-N04-C-006-MH	DEFCC
10184320	12/20/2024	MANHOLE REPAIR @ SENECA PL.	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N04-C-006-MH	DEFC5

DECEMBER 2024 I&I DISTRICT # 5

10184446	12/26/2024	MANHOLE REPAIR @ 8820 CLARENCE CENTER	REPLACED FRAME AND COVER(5)	E-S-N05-C-005-MH	123BAE
----------	------------	---------------------------------------	-----------------------------	------------------	--------

2024 DECEMBER MECHANICAL ROOTCUT DISTRICT # 1

<i>Notification</i>	<i>DATE</i>	<i>Description</i>	<i>Act. code text</i>	<i>Functional Loc.</i>	<i>HANDLE</i>	<i>L/F</i>
10185322	12/30/2024	TELEWISE HOMEWOOD 12" VTP	MECHANICAL ROOT CUT	E-S-N01-C-001-SL	BB507	117
10184351	12/09/2024	TELEWISE CINDY LN. 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-010-SL	BC306	155
10184353	12/09/2024	TELEWISE CINDY LN. 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-010-SL	BC310	227
10184336	12/09/2024	TELEWISE CINDY LN. 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-010-SL	BC311	359
10184348	12/11/2024	TELEWISE CRYSTAL 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-010-SL	BC318	315
10184352	12/09/2024	TELEWISE CINDY LN. 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-010-SL	BC328	152

2024 DECEMBER MECHANICAL ROOTCUT DISTRICT # 4

NONE

2024 DECEMBER MECHANICAL ROOTCUT DISTRICT # 5

NONE

2024 DECEMBER TELEVISIONING DISTRICT # 1

<i>Notification</i>	<i>DATE</i>	<i>Description</i>	<i>Act. code text</i>	<i>Functional Loc.</i>	<i>HANDLE</i>
10185322	12/30/2024	TELEVISION HOMEWOOD 12" VTP	TELEVISIONED - (D)	E-S-N01-C-001-SL	BB507
10184351	12/09/2024	TELEVISION CINDY LN. 8" VTP	TELEVISIONED - (D)	E-S-N01-C-010-SL	BC306
10184353	12/09/2024	TELEVISION CINDY LN. 8" VTP	TELEVISIONED - (D)	E-S-N01-C-010-SL	BC310
10184336	12/09/2024	TELEVISION CINDY LN. 8" VTP	TELEVISIONED - (D)	E-S-N01-C-010-SL	BC311
10184348	12/11/2024	TELEVISION CRYSTAL 8" VTP	TELEVISIONED - (D)	E-S-N01-C-010-SL	BC318
10184352	12/09/2024	TELEVISION CINDY LN. 8" VTP	TELEVISIONED - (D)	E-S-N01-C-010-SL	BC328

2024 DECEMBER TELEVISIONING DISTRICT # 4

NONE

2024 DECEMBER TELEVISIONING DISTRICT # 5

NONE

December 2024 Maintenance

District 1

Plowed and shoveled snow 4 different times.
Inspected pump 2 and reset tolerances at Cayuga.
Cut up fallen trees along driveway at Cayuga.
Picked up new pump shaft and delivered to Industrial Park.
Bled pump 4 at Industrial Park twice.
Transferred hypo from totes back into tank at Cayuga orf.
Repair heater at Clinton.
PM'd transformers at IPP.
Finished all dry well lights at IPP.

District 4

Plowed and shoveled snow 4 different times.
Pulled and cleaned pump 2 at Bowmansville 4 different times.
Replaced impeller on Bowmansville pump 2.
Repaired fencing at Vanderbilt.
Pulled and cleaned pump 1 at Bowmansville 8 different times.
Completed painting of Broadway interior.
Repaired man door at Depew station.
Began prepping and painting station interior at Warner.
Unjammed muffin monster at prison twice.
Replaced section of suction hose for Depew orf creek pump.
Repaired phone lines for collection supervisor at NR base.
Began programming station controls for Bowmansville.
Install conduit and hww float at Iroquois.
Relaced HWW float at Pleasantview.
Repaired wire on the camera at NR base.

District 5

Plowed and shoveled snow 3 different times.
Changed DO air valve at CRP.
Cut up fallen trees along driveway at CRP.
Programmed and installed PLC at CRP for valve control.
Wired and tested genset for CRP.

All Districts

Check all fluids in station generators and topped off with fuel where needed.

2024 December UFPO Numbers

(By District/Region)

Total UFPO Tickets:	962
Tickets Outside ECSD Boundary	124

	Total Tickets	APR Code		Total %	Stakeout %
		10 - All Clear	30 - Staked Out		
District 1	116	69	47	12%	15%
District 4	174	132	42	18%	13%
District 5	58	40	18	6%	6%
Total NR	348	241	107	36%	34%

District 3	271	175	96	28%	30%
District 6	82	32	50	9%	16%
District 8	38	29	9	4%	3%
Total CR	391	236	155	41%	49%

District 2	99	42	57	10%	18%
Total SR	99	42	57	10%	18%

Totals:	838	519	319		
----------------	------------	------------	------------	--	--
