

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
JANUARY 2026 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTAL	0	0	0
		0	

UFPO's	D1	D4	D5
Responses	82	112	47
Stakeouts	43	33	18
TOTAL STAKEOUTS	94		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	7,123	374	4,431	11,928

Televising (feet)	D1	D4	D5	TOTAL
By Central Maint	0	0	0	0
By District	0	0	0	0

	D1	D4	D5	TOTAL
House Inspections				0
Reinspections				0
Violations				0
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
	102	19	0	121

Manhole Repairs	D1	D4	D5	TOTAL
	5	2	0	7

Root Treatment (ft)	D1	D4	D5	TOTAL
Chemical Root Control	0	0	0	0
Mechanical Root Cut	0	0	0	0
Mechanically Cleaned	0	0	0	0

Sewerline Repairs	CATCO REPAIRED (2) LATERALS - 773 BORDEN / 567 BORDEN
Sanitary Sewer	D4 MS 11- SOUTH MILLER- 10083518
Overflow NONE	

CONSTRUCTION		
D1	D4	D5
4814 TRANSIT	BRADLEY EXTENSION	HARRIS HILL MIXED USE SITE
2715 & 2725 CAR WASH -UNION	NEXTERA ENERGY TRANS.	7145 TRANSIT
SONWIL WAREHOUSE	ANGRY BUFFALO	6625 TRANSIT MIXED USE
UPSTATE NIAGARA 3300 N.AMERICA	4106 WALDEN WAREHOUSE	LEGACY WOODS PS
395 WEST AVE.	VALVOLINE OIL CHANGE	JAMES RYAN PKWY
	4510 BROADWAY APARTMENTS	6260 GOOD RICH SANTORAS
	5841 GENESSE SHOP	KRAUS RD. EXTENSION
	WOOD SPRING EXTENSION	5695 & 5731 TRANSIT
	3825 BOWTIE PARK	
	NEXTERA ENERGY TRANS.	
	4412 JAGG ELECTRIC	
	ALDEN GROW FACILITY	
Plans Reviewed:		

COMPLAINT SUMMARY ECSD # 1 JANUARY 2026

Notification	DATE	Description	Prob. code text	Functional Loc.
10198981	01/01/2026	BACK UP - 31 BENZ DR, DEPEW	HOMEOWNER'S PROBLEM	E-S-N01-C-004-SL
10199065	01/07/2026	ECWA HIT SEWER MAIN - 50 DEWBERRY LN, CH	NO FURTHER WORK REQUIRED	E-S-N01-C-006-SL
10199292	01/20/2026	SEWER BACK UP 111 KELLY DR	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-007-SL
10199293	01/28/2026	BATHROOM BACK UP 111 KELLY DRIVE	FLUSHED LINE/NO BLOCKAGE	E-S-N01-C-007-SL

COMPLAINT SUMMARY ECSD # 4 JANUARY 2026

10199273	01/15/2026	MANHOLE COVER OFF MH 6370 TRANSIT RD	REFERRED TO OTHERS	E-S-N04-C-004-SL
10199334	01/15/2026	MANHOLE COVER OFF - 6370 TRANSIT RD, CHE	REFERRED TO OTHERS	E-S-N04-C-004-SL
10199343	01/16/2026	BACK UP IN BSMT 423 CENTRAL AVE, LANCAST	HOMEOWNER'S PROBLEM	E-S-N04-C-005-SL
10200125	01/29/2026	RING ON MH BROKEN 21 EDWARD ST	FOLLOW-UP REQUIRED	E-S-N04-C-005-SL
10200052	01/22/2026	MH FOUL ODOR AURORA/AMERICO CORNER	ODOR	E-S-N04-C-015-MH
10198989	01/07/2026	BSMT AND OUTSIDE VENT BSKUP 225 SIEBERT	BASEMENT FACILITY	E-S-N04-C-015-SL

COMPLAINT SUMMARY ECSD # 5 JANUARY 2026

NONE

JANUARY 2026 I&I DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE
10185284	01/06/2026	MANHOLE REPAIR @ CAPRICE (EPOXY)	REPAIRED BARREL JOINT LEAKS, MOD(4)	E-S-N01-C-007-MH	BB32F
10172078	01/06/2026	MANHOLE REPAIR @ 150 STEVEN DRIVE -EPOXY	REPAIRED BARREL, NOT JOINT LEAKS, MOD(4)	E-S-N01-C-007-MH	BB352
10185283	01/06/2026	MANHOLE REPAIR @ EILEEN (EPOXY)	REPAIRED BARREL, NOT JOINT LEAKS, SLT(3)	E-S-N01-C-007-MH	BB2D9
10200098	01/17/2026	SEWER BCK UP 773 BORDEN	REPAIRED PIPE - LEAKING LATERAL	E-S-N01-C-007-SL	
10200099	01/19/2026	SEWER BCK UP 567 BORDEN	REPAIRED PIPE - LEAKING LATERAL	E-S-N01-C-007-SL	
10197405	01/07/2026	MANHOLE REPAIR @ INNSBROOK (EXCAVATE)	REPAIRED CONE, NOT JOINT LEAKS, SEV(5)	E-S-N01-C-008-MH	BAA79
10199283	01/13/2026	ROOTMASS EXCAVATION @ LAKESIDE	PIPE PATCHED - 1 JOINT	E-S-N01-C-008-SL	BC138
10199240	01/12/2026	MANHOLE REPAIR @ CLINTON	REPAIRED CONE/BARREL JOINT LEAKS, MOD(4)	E-S-N01-C-009-MH	BB2A5

JANUARY 2026 I&I DISTRICT # 4

10188560	01/14/2026	MANHOLE REPAIR @ MAIN STREET	RAISED MANHOLE(4)	E-S-N04-C-001-MH	DE55A
10199028	01/09/2026	INSTALL INFLOW PROTECTOR @ 26 HASKELL	INSTALLED INFLOW PROTECTOR (4)	E-S-N04-C-003-MH	DE69F
10199031	01/02/2026	SEWER REPAIR @ SOUTH MILLER	PIPE REPLACED - 8"	E-S-N04-C-011-SL	10083518

JANUARY 2026 I&I DISTRICT # 5

NONE

2026 January UFPO Numbers

(By District/Region)

Total UFPO Tickets:	840
Tickets Outside ECSD Boundary:	122

	Total Tickets	APR Code		Other APR Codes	
		10 - All Clear	30 - Staked Out	31	51
District 1	82	39	43		
District 4	112	79	33		
District 5	47	29	18		
Total NR	241	147	94		
District 3	290	204	86		
District 6	72	31	41		
District 8	28	21	7		
Total CR	390	256	134		
District 2	87	37	50		
Total SR	87	37	50		
Totals:	718	440	278		

Month:	JANUARY 2026		NR FLOW SUMMARY 2026			
Station	SD	Total Hrs	Daily Avg	GPM	GPH	Tot Gal
Borden-Clinton	1	1051	33.9	200	12000	12,614,400
Cayuga	1	1379	44.5	1190	71400	75,398,400
Clint-Tran	1	284	9.2	350	21000	5,972,400
Industrial Park	1	721	23.2	3650	219000	136,038,420
Union	1	135	4.3	850	51000	6,859,500
Woodlands	1	48	1.5	39	2340	111,384
Aurora South	4	107	3.4	705	42300	4,509,180
Bowmansville	4	1183	38.2	1600	96000	113,568,000
Broadway	4	14	0.5	16000	960000	13,440,000
Depew	4	1902	61.4	11000	660000	812,625,000
Forestream	4	136	4.4	1050	63000	8,536,500
Hall	4	291	9.4	130	7800	2,266,680
Haskell	4	55	1.8	590	35400	1,939,920
Iroquois	4	1410	45.5	3000	180000	253,728,000
Pleasantview	4	386	12.5	950	57000	22,007,700
Vanderbilt	4	12	0.4	8000	480000	5,760,000
Warner	4	1081	34.9	5000	300000	324,300,000
Zoeller	4	502	16.2	830	49800	24,999,600
Bryant	5	304	9.8	600	36000	10,940,400
Eastern Hills	5	354	11.4	625	37500	13,293,750
Forestview	5	66	2.1	554	33240	2,203,812
Cannonwoods	5	10	0.3	173	10380	101,724
Creekwood	5	129	4.2	509	30540	3,933,552
Pinebreeze	5	137	4.4	325	19500	2,667,600
Stahley	5	199	6.4	720	43200	8,579,520
Transit Valley	5	328	10.6	450	27000	8,858,700
Total NR Flow:					1,875,254,142	

ERIE COUNTY - SEWER DISTRICT 1,4,5
1/1/2026 TO 1/31/2026
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	1	4	5
Taps	0	0	0	0
Disconnect	0	0	0	0
Repair	4	5	4	13
TOTAL	4	6	8	18

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	0	0	0
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	0	1	4	5
Exist Residential (ER)	0	0	0	0
TOTAL	0	1	4	5

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	0	0	0
Exist Commercial Issued (EC)	0	0	0	0
New Residential Issued (NR)	0	5	1	6
Exist Residential Issued (ER)	5	5	2	12
TOTAL	5	10	3	18

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$0	\$0	\$0	\$0
Exist Commercial Fees (EC)	\$0	\$0	\$0	\$0
New Residential Fees(NR)	\$0	\$3,510	\$0	\$3,510
Exist Residential Fees (ER)	\$10	\$10	\$4	\$24
TOTAL	\$10	\$3,520	\$4	\$3,534

DISTRICT 1

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
1	1/15/2026 13:00		CP0111960	567	Bordon Rd	Cheektowaga	Existing	Residential Single Unit	125.12-4- 1	Repair
1	1/12/2026 14:00	Final	CP0105759	29	Gaby Ln	Cheektowaga	Existing	Residential Single Unit	125.09- 15-3	Repair
1	1/22/2026 11:30	Final	CP0106699	79	Knollwood Dr	Cheektowaga	Existing	Residential Single Unit	125.07-3- 12	Repair
1	1/12/2026 13:30	Final	CP0107275	13	Lynnette Ct	Cheektowaga	Existing	Residential Single Unit	125.16-3- 3	Repair
1	1/9/2026 13:00	Final	CP0103745	133	Whitney Pl.	Cheektowaga	Existing	Residential Single Unit	114.18-6- 17	Repair

DISTRICT 4

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type	Tap Type
4	1/26/2026 14:00	Final	CP041002	7	Fieldstream Ln	Lancaster (T)	New	Residential Single Unit	116.15-1-37	Connection	Wye
4	1/9/2026 13:00	Final	CP040599	7	Haskell Dr	Lancaster (T)	Existing	Residential Single Unit	93.07-1-5	Repair	
4	1/7/2026 13:00	Final	CP040339	9	Redlein Dr	Lancaster (T)	Existing	Residential Single Unit	93.10-3-10	Repair	
4	1/23/2026 12:30	Final	CP041011	6	Ronald dr	Lancaster (T)	Existing	Residential Single Unit	104.07-6-5	Repair	
4	1/8/2026 13:30	Final	CP041011	5	Newell Ave	Lancaster (V)	Existing	Residential Single Unit	104.15-10-8	Repair	
4	1/2/2026 10:30	Final	CP041011	1	Sawyer Ave	Lancaster (V)	Existing	Residential Single Unit	104.11-10-23	Repair	

DISTRICT 5

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
5	1/2/2026 11:30	Final	CP0502502	6251	Cloverleaf Cir	Clarence	Existing	Residential Single Unit	43.11-1-14	Repair
5	1/27/2026 13:30	Final	CP0502530	6369	Cloverleaf Cir	Clarence	Existing	Residential Single Unit	43.11-1-88	Repair
5	1/5/2026 14:00	Final	CP0501256	8305	Stahley Rd Woods Edge	Clarence	Existing	Residential Single Unit	43.06-2-7	Repair
5	1/5/2026 11:00	Final	CP0500376	5566	Ct	Clarence	Existing	Residential Single Unit	57.10-4-32	Repair

DISTRICT 5 CLARENCE TOWN DISTRICTS

District	CTD	Insp Date	Permit	#	Street	Town	Permit Subtype	New/Existing	Property Type	SBL	Permit Type	Tap Type	Comments
5	2	1/8/2026 14:00	CP0504393	9534	Deer Valley Dr	Clarence	Clarence Iss	New	Residential Single Unit	44.11-5-13	Connection	Wye	Clarence issued. DSM inspected.
5	2	1/16/2026 13:00	CP0504398	9553	Deer Valley Dr	Clarence	Clarence Iss	New	Residential Single Unit	44.11-5-18	Connection	Wye	Clarence issued. DSM inspected.
5	2	1/9/2026 9:00	CP0504396	9568	Deer Valley Dr	Clarence	Clarence Iss	New	Residential Single Unit	44.11-5-16	Connection	Wye	Clarence Issued. DSM inspected.
5	4	1/23/2026 13:00	CP0504397	9752	Longleaf Trl	Clarence	Clarence Iss	New	Residential Single Unit	58.16-5-10	Connection	Wye	Clarence issued. DSM inspected.

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	5-Jan	2032.5		16.125	178	99	2	40	-	135
Cayuga	1	Under Generator	1300	33	39.39	5-Jan	842.9		29.125	1147	88	153		-	975
Clinton	1	Under Generator	150	24	6.25	5-Jan	1956.5		20	147	98	3	22	-	113
Industrial Parkway	1	Under Generator	700	30	23.33	5-Jan	711.6		27.125	633	90	67		-	525
Union	1	Under Generator	400	26	15.38	5-Jan	144.8		23.125	356	89	44		-	300
Zoeller	4	Under Generator				5-Jan	9.5		23.25	0	#DIV/0!	0		-	0
Aurora South	4	Under Generator	285	21	13.57	5-Jan	1802		17.5	253	89	33	15	-	214
Bowmansville	4	Under Generator	700	26	26.92	5-Jan	962		22.5	671	96	29	65	-	525
Broadway	4	Above-Ground	1000	36	*	5-Jan	321		30.875	716	72	284		X	750
Depew	4	Above-Ground	3000	69	*	5-Jan	508		45.25	1936	65	1064	100	X	2250
Iroquois	4	Under Generator	295	17	17.35	5-Jan	1116.8		16.25	282	96	13		-	221
Vanderbilt	4	Above-Ground	1000	36	*	5-Jan	8-Jun		32.5	716	72	284		X	750
Warner	4	Under Generator	700	26	26.92	5-Jan			22.875	658	94	42	42	-	525
Bryant	5	Under Generator	180	22	8.18	5-Jan	698.6		17.25	141	78	39		-	135
Pinebreeze	5	Under Generator	275	44	*	5-Jan	1328.5		38.75	248	90	27		-	206
Stahley	5	Under Generator	150	25	6.00	5-Jan	1600		22.25	134	89	17		-	113
Transit Valley	5	Above Ground	275	44	*	5-Jan	71.7		37.75	241	88	34		-	206

* Calculated

Refill at: 0.8

January 2026 Maintenance

District 1

Plowed and shoveled snow 6 different times.
Installed new fence post for gate at Old Cayuga and reattached gate.
Cut up fallen tree on fence at Cayuga.
Cut up fallen tree on fence at Union.
Manually bled air out of pump 4 at Industrial Park and put back in service.
Repaired broken water line in hypo room at Cayuga.
Repaired Level sensor at Cayuga twice.
Adjusted LWW level at IPP.

District 4

Plowed and shoveled snow 6 different times.
Worked on rebuilding Depew spare pump twice.
Continued painting interior walls at Depew station.
Pulled and cleaned pump #1 at Bowmansville twice.
Pulled and cleaned pump #2 at Bowmansville twice.
Picked up Bowmansville spare pump from vendor and delivered to station for storage.
Scanned Depew's VFD Cabinets with IR.
Repaired load bank at Depew.
Replaced line fuse in VFD 4 at Depew.
Continued work on Warner Soft starts.
Calibrated gas detector for ST.

District 5

Plowed and shoveled snow 6 different times.
Cut up fallen trees at CRP.
Set up and broke down and returned bypass pump for Transit Valley.
Removed old controls from transit valley and rewired everything to work off of the MPE.

All Districts

Check all fluids in station generators and topped off with fuel where needed.

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
FEBRUARY 2026 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTAL	0	0	0
	0		

UFPO's	D1	D4	D5
Responses	87	135	70
Stakeouts	31	53	28
TOTAL STAKEOUTS	112		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	6,238	983	506	7,727

Televising (feet)	D1	D4	D5	TOTAL
By Central Maint	0	0	0	0
By District				0

	D1	D4	D5	TOTAL
House Inspections				0
Reinspections				0
Violations				0
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
	136	26	0	162

Manhole Repairs	D1	D4	D5	TOTAL
	5	4	1	10

Root Treatment (ft)	D1	D4	D5	TOTAL
Vapor Rooting				0
Cutting w/ Flusher				0
Mechanical Cleaning	0	0	0	0

Sewerline Repairs	739 BORDEN - REPAIR LATERAL -(CATCO)
Sanitary Sewer Overflow	NONE

D1	D4	D5
4814 TRANSIT	BRADLEY EXTENSION	HARRIS HILL MIXED USE SITE
2715 & 2725 CAR WASH -UNION	NEXTERA ENERGY TRANS.	7145 TRANSIT
SONWIL WAREHOUSE	ANGRY BUFFALO	6625 TRANSIT MIXED USE
UPSTATE NIAGARA 3300 N.AMERICA	4106 WALDEN WAREHOUSE	WOODLAND HILLS PH 3
395 WEST AVE.	VALVOLINE OIL CHANGE	JAMES RYAN PKWY
	4510 BROADWAY APARTMENTS	CREEKWOOD PUMP HOUSE
	5841 GENESSE SHOP	KRAUS RD. EXTENSION
	WOOD SPRING EXTENSION	5695 & 5731 TRANSIT
	3825 BOWTIE PARK	PEANUT LINE INTERCEPTOR
	NEXTERA ENERGY TRANS.	
	4412 JAGG ELECTRIC	
	ALDEN GROW FACILITY	

Plans Reviewed:	
	DISTRICT 5
	PEANUT LINE PARRALLEL INTERCEPTOR

COMPLAINT SUMMARY ECSD # 1 FEBRUARY 2026

Notification	DATE	Description	Prob. code text	Functional Loc.
10200182	02/19/2026	SEWER BACK UP - 739 BORDEN RD	HOMEOWNER'S PROBLEM	E-S-N01-C-007-SL
10200482	02/17/2026	BACK UP - 63 MAPLEWOOD AVE, WEST SENECA	HOMEOWNER'S PROBLEM	E-S-N01-C-009-SL
10200523	02/18/2026	BACK UP - 67 ELECTRIC AVE, WEST SENECA	HOMEOWNER'S PROBLEM	E-S-N01-C-012-SL

COMPLAINT SUMMARY ECSD # 4 FEBRUARY 2026

10200255	02/18/2026	BACK UP - 1179 PENORA ST, LANCASTER	BASEMENT FACILITY	E-S-N04-C-008-SL
----------	------------	-------------------------------------	-------------------	------------------

COMPLAINT SUMMARY ECSD # 5 FEBRUARY 2026

10200394	02/13/2026	ODOR COMPLAINT - 10390 MAIN ST, CLARENCE	HOMEOWNER'S PROBLEM	E-S-N05-C-009-SL
----------	------------	--	---------------------	------------------

FEBRUARY 2026 I&I DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE
10200541	02/23/2026	MANHOLE REPAIR @ COMO PARK	REPAIRED FRAME/CONE JOINT LEAKS, MOD(4)	E-S-N01-C-004-MH	BA522
10200543	02/23/2026	MANHOLE REPAIR @ COMO PARK	REPAIRED BARREL JOINT LEAKS, SEV(5)	E-S-N01-C-004-MH	BA524
10200542	02/23/2026	MANHOLE REPAIR @ COMO PARK	REPAIRED BARREL JOINT LEAKS, MOD(4)	E-S-N01-C-004-MH	BA523
10184239	02/23/2026	MANHOLE REPAIR @ LOIS (EPOXY)	REPAIRED CONE/BARREL JOINT LEAKS, MOD(4)	E-S-N01-C-007-MH	BB2D5
10200182	02/26/2026	SEWER BACK UP - 739 BORDEN RD	REPAIRED PIPE - LEAKING LATERAL	E-S-N01-C-007-SL	BB88C
10200414	02/17/2026	MANHOLE REPAIR @ SENECA CREEK	REPAIRED FRAME JOINT LEAKS, SEV(5)	E-S-N01-C-010-MH	BB39E

FEBRUARY 2026 I&I DISTRICT # 4

10184231	02/19/2026	MANHOLE REPAIR @ 34 TRENTWOOD	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N04-C-006-MH	DEFDA
10199099	02/20/2026	MANHOLE REPAIR @ WALDEN	REPAIRED FRAME JOINT LEAKS, SEV(5)	E-S-N04-C-007-MH	DE8A4
10185550	02/20/2026	MANHOLE REPAIR @ 3111 OLD WENDE	RAISED MANHOLE(4)	E-S-N04-C-007-MH	DE8E0
10185550	02/20/2026	MANHOLE REPAIR @ 3111 OLD WENDE	REPLACED FRAME AND COVER(5)	E-S-N04-C-007-MH	DE8E0

FEBRUARY 2026 I&I DISTRICT # 5

10200274	02/17/2026	MANHOLE REPAIR @ 720 AURORA RD	REPAIRED FRAME JOINT LEAKS, MOD(4)	E-S-N04-C-015-MH	DED40
----------	------------	--------------------------------	------------------------------------	------------------	-------

2026 February UFPO Numbers

(By District/Region)

Total UFPO Tickets:	951
Tickets Outside ECSD Boundary	137

	Total Tickets	APR Code		Other APR C
		10 - All Clear	30 - Staked Out	31
District 1	87	56	31	
District 4	135	82	53	
District 5	70	42	28	
Total NR	292	180	112	
District 3	296	172	124	
District 6	58	25	33	
District 8	31	17	14	
Total CR	385	214	171	
District 2	137	51	86	
Total SR	137	51	86	
Totals:	814	445	369	

Late Tickets

NR	CR	SR

2005 PS Flows

Month:	FEBUARY 2026		NR Flow Summary 2026			
Station	SD	Total Hrs	Daily Avg	GPM	GPH	Tot Gal
Borden-Clinton	1	429	13.8	200	12000	5,148,000
Cayuga	1	556	17.9	1190	71400	27,803,160
Clint-Tran	1	147	4.7	350	21000	3,078,600
Industrial Park	1	202	6.5	3650	219000	57,978,060
Union	1	65	2.1	850	51000	3,309,900
Woodlands	1	22	0.7	39	2340	51,714
Aurora South	4	46	1.5	705	42300	1,941,570
Bowmansville	4	480	15.5	1600	96000	46,080,000
Broadway	4	9	0.3	16000	960000	8,640,000
Depew	4	912	29.4	11000	660000	381,150,000
Forestream	4	59	1.9	1050	63000	3,685,500
Hall	4	124	4.0	130	7800	964,860
Haskell	4	39	1.3	590	35400	1,380,600
Iroquois	4	674	21.7	3000	180000	121,284,000
Pleasantview	4	171	5.5	950	57000	9,729,900
Vanderbilt	4	13	0.4	8000	480000	6,240,000
Warner	4	485	15.6	5000	300000	145,500,000
Zoeller	4	417	13.5	830	49800	20,776,560
Bryant	5	115	3.7	600	36000	4,143,600
Eastern Hills	5	155	5.0	625	37500	5,823,750
Forestview	5	31	1.0	554	33240	1,040,412
Cannonwoods	5	24	0.8	173	10380	250,158
Creekwood	5	56	1.8	509	30540	1,719,402
Pinebreeze	5	58	1.9	325	19500	1,134,900
Stahley	5	83	2.7	720	43200	3,581,280
Transit Valley	5	147	4.7	450	27000	3,960,900
Total NR Flow:						866,396,826

ERIE COUNTY - SEWER DISTRICT 1,4,5
2/1/2026 TO 2/28/2026
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	3	8	11
Taps	0	0	0	0
Disconnect	0	0	0	0
Repair	5	5	7	17
TOTAL	5	8	15	28

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	0	0	0
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	0	3	8	11
Exist Residential (ER)	0	0	0	0
TOTAL	0	3	8	11

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	0	0	0
Exist Commercial Issued (EC)	1	1	1	3
New Residential Issued (NR)	0	0	0	0
Exist Residential Issued (ER)	4	7	4	15
TOTAL	5	8	5	18

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$0	\$0	\$0	\$0
Exist Commercial Fees (EC)	\$2	\$2	\$2	\$6
New Residential Fees (NR)	\$0	\$0	\$0	\$0
Exist Residential Fees (ER)	\$8	\$14	\$8	\$30
TOTAL	\$10	\$16	\$10	\$36

DISTRICT 1
CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
1	2/24/2026 11:00	Final	CP0101862	739	Borden Rd	Cheektowaga	Existing	Residential Single Unit	114.20-6-14	Repair
1	2/19/2026 13:00	Final	CP0105285	11	Frantzen Ter	Cheektowaga	Existing	Residential Single Unit	125.08-9-2	Repair
1	2/19/2026 12:00	Final	CP0105701	1449	French Rd	Cheektowaga	Existing	Non-Residential Single Unit	126.09-2-2.2	Repair
1	3/4/2026 11:00		CP0104463	104	Martinique Dr	Cheektowaga	Existing	Residential Single Unit	125.06-19-41	Repair
1	2/17/2026 11:00	Final	CP0108966	67	Samantha Way	Cheektowaga	Existing	Residential Single Unit	125.11-11-20	Repair
1	3/5/2026 13:00		CP0103495	2920	William St.	Cheektowaga	Existing	Non-Residential Multiple Units	113.15-1-2	Repair
1	2/19/2026 11:00	Final	CP0109105	199	Sharon Dr	West Seneca	Existing	Residential Single Unit	125.13-4-1964	Repair

DISTRICT 4
CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type	Tap Type
4	3/5/2026 13:30		CP0410125	61	Ledyard Ave	Depew/Chktg	New	Residential Single Unit	103.12-13-29	Repair	
4	2/24/2026 14:00	Final	CP0410029	33	Fieldstream Ln	Lancaster (T)	New	Residential Single Unit	116.15-1-17	Connection	Wye
4	2/20/2026 14:00	Final	CP0410026	35	Fieldstream Ln	Lancaster (T)	New	Residential Single Unit	116.15-1-18	Connection	Wye
4	3/9/2026 13:00		CP0407040	37	Greenmeadow Dr	Lancaster (T)	Existing	Residential Single Unit	93.18-5-13	Repair	
4	3/3/2026 13:00	Final	CP0405500	58	Impala Pkwy	Lancaster (T)	Existing	Residential Single Unit	93.19-4-10	Repair	
4	2/12/2026 13:00	Final	CP0402887	35	Steinfeldt Rd	Lancaster (T)	Existing	Residential Single Unit	116.05-3-7.1	Repair	

4	2/5/2026 11:00	Final	CP0401627	12	Village Vw	Lancaster (T)	Existing	Residential Single Unit	115.16-1-48	Repair	
4	2/23/2026 14:00	Final	CP0410017	5502	William St	Lancaster (T)	New	Residential Single Unit	116.15-1-22	Connection	Wye
4	2/20/2026 13:30	Final	CP0410124	12	4th Ave	Lancaster (V)	Existing	Residential Multiple Units	115.11-5-16	Repair	
4	3/4/2026 14:00		CP0408338	170	Aurora St	Lancaster (V)	Existing	Residential Single Unit	115.07-10-1.1	Repair	
4	2/10/2026 13:30	Final	CP0410123	5476	Broadway St	Lancaster (V)	Existing	Non-Residential Multiple Units	104.83-2-17	Repair	
4	2/2/2026 14:00	Final	CP0410122	48	Lombardy ST	Lancaster (V)	Existing	Residential Single Unit	115.27-5-19	Repair	

DISTRICT 5

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type	Tap Type
5	2/6/2026 11:00	Final	CP0502027	8646	Golden Rod Ct	Clarence	Existing	Residential Single Unit	43.11-2-13	Repair	
5	2/11/2026 11:00	Final	CP0500065	6100	Meadowlakes Dr	Clarence	Existing	Residential Single Unit	43.14-4-10	Repair	
5	2/27/2026 11:00	Final	CP0500132	8952	Michael Douglas Dr	Clarence	Existing	Residential Single Unit	43.16-2-34	Repair	
5	2/25/2026 13:00	Final	CP0500920	7041	Transit Rd	Clarence	Existing	Non-Residential Single Unit	29.01-1-17	Repair	
5	2/23/2026 13:00	Final	CP0500565	6157	Walnut Creek Ct	Clarence	Existing	Residential Single Unit	43.14-7-24	Repair	
5	2/5/2026 14:00	Final	CP0504369	6813	Windsor Ln	Clarence	New	Residential Single Unit	29.18-5-11	Connection	Wye

DISTRICT 5 CLARENCE TOWN DISTRICTS

District	CTD	Insp Date	Permit	#	Street	Town	Permit Subtype	New/Existing	Property Type	SBL	Permit Type	Tap Type
5		2/9/2026 13:00	CP0504428	5993	Corinne Ln	Clarence	Clarence Iss	Existing	Residential Single Unit	44.17-4-6	Repair	
5		2/25/2026 13:30	CP0504418	9538	Deer Valley Dr	Clarence	Clarence Iss	New	Residential Single Unit	44.11-5-14	Connection	Wye
5		2/10/2026	CP0500064	6091	Meadowlakes Dr	Clarence	Clarence Iss	Existing	Residential Single Unit	43.14-3-18	Repair	Tap

5	2	2/2/2026 13:00 2/26/2026	CP0504407	9506	Deer Valley Dr	Clarence	Clarence Iss	New	Residential Single Unit	000	Connection	Wye
5	2	13:00 2/26/2026	CP0504405	9533	Deer Valley Dr	Clarence	Clarence Iss	New	Residential Single Unit	44.11-5- 23	Connection	Wye
5	2	13:30 2/19/2026	CP0504416	9549	Deer Valley Dr	Clarence	Clarence Iss	New	Residential Single Unit	44.11-5- 19	Connection	Wye
5	4	11:00 2/17/2026	CP0504402	9764	Longleaf Trl	Clarence	Clarence Iss	New	Residential Single Unit	58.16-5- 13	Connection	Wye
5	4	14:00 2/25/2026	CP0504356	5511	Serenity Ct	Clarence	Clarence Iss	New	Residential Single Unit	58.15-10- 12	Connection	Wye
5	6	11:00	CP0504395	5315	Briannas Nook	Clarence	Clarence Iss	New	Residential Single Unit	58.17-13- 3	Connection	Wye

February 2026 Maintenance

District 1

Plowed and shoveled snow twice.
Repaired broken plumbing in hypo room at Cayuga.
Replaced spring on #2 check valve at Borden.
Installed new safety shower in hypo room at Cayuga.
Reset pump #1 at Borden multiple times.
Troubleshoot valve operator at Vanderbilt.
Began control upgrade at Borden.
Reset pump 1 at cayuga once.
Reset pump 4 at cayuga twice.

District 4

Plowed and shoveled snow twice.
Worked on painting interior at Depew 4 different times.
Reset Warner muffin monster.
Reset Prison muffin monster.
Swapped pump #1 at Zoeller with spare.
Set up and ran bypass pump at Zoeller.
Dropped spare Zoeller motor at Volland for repair.
Broke down and returned bypass pump from Zoeller.
Pulled and cleaned pump #1 at Bowmansville.
Pulled and cleaned pump #2 at Bowmansville.
Swapped out #2 muffin monster at Depew with spare.
Repair heater at NR base.
Finished installing soft starts at Warner.
Wired portable generator at Depew for genset repairs.
Repaired wire on vacuum at NR base.
Unjammed second vacuum of debris at NR base.
Installed wire mold in collections office for hdmi cables.

District 5

Plowed and shoveled snow twice.

Repaired control panel at Transit Valley.

All Districts

Checked fluids in station generator and topped off with fuel where needed.

Obtained and verified all electrical account numbers for pump stations.

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	27-Feb	2038.3		18.25	156	87	24		-	135
Cayuga	1	Under Generator	1300	33	39.39	27-Feb	843		29.25	1152	89	148		-	975
Clinton	1	Under Generator	150	24	6.25	27-Feb	1963.2		21.25	133	89	17		-	113
Industrial Parkway	1	Under Generator	700	30	23.33	27-Feb	711.6		27.5	642	92	58		-	525
Union	1	Under Generator	400	26	15.38	27-Feb	150.6		22.5	346	87	54		-	300
Aurora South	4	Under Generator	285	21	13.57	27-Feb	1808		18	244	86	41		-	214
Bowmansville	4	Under Generator	700	26	26.92	27-Feb	969		24	646	92	54		-	525
Broadway	4	Above-Ground	1000	36	*	27-Feb	321		30	716	72	284		X	750
Depew	4	Above-Ground	3000	69	*	27-Feb	509		46.125	1986	66	1014		X	2250
Iroquois	4	Under Generator	295	17	17.35	27-Feb	1116		16.25	282	96	13		-	221
Vanderbilt	4	Above-Ground	1000	36	*	27-Feb	160.6		32.25	716	72	284		X	750
Warner	4	Under Generator	700	26	26.92	27-Feb			23.5	633	90	67		-	525
Zoeller	4	Under Generator	680	32	21.25	27-Feb	9.5		21	446	66	234		X	510
Bryant	5	Under Generator	180	22	8.18	27-Feb	698.6		17.5	143	80	37		-	135
Pinebreeze	5	Under Generator	275	44	*	27-Feb	1328.5		38.5	248	90	27		-	206
Stahley	5	Under Generator	150	25	6.00	27-Feb	1610		20	120	80	30		-	113
Transit Valley	5	Above Ground	275	44	*	27-Feb	80.4		36	235	85	40		-	206

* Calculated

Refill at: 0.75