

ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5

MARCH 2026 MONTHLY OPERATION REPORT

| INSPECTIONS | D1 | D4 | D5 |
|---------------|----------|----------|----------|
| MH Connection | | | |
| Grinder | | | |
| TOTALS | 0 | 0 | 0 |
| | 0 | | |

| UFPO's | D1 | D4 | D5 |
|------------------------|------------|-----|-----|
| Responses | 211 | 360 | 109 |
| Stakeouts | 40 | 107 | 35 |
| TOTAL STAKEOUTS | 182 | | |

| Sewer Flushing (feet) | D1 | D4 | D5 | TOTAL |
|-----------------------|--------|-----|----|---------------|
| | 21,279 | 210 | 0 | 21,489 |

| Televising (feet) | D1 | D4 | D5 | TOTALS |
|-------------------|-----|----|----|------------|
| By Central Maint | | | | 0 |
| By District | 344 | 0 | 0 | 344 |

| | D1 | D4 | D5 | TOTALS |
|-------------------|----|----|----|--------|
| House Inspections | | | | 0 |
| Reinspections | | | | 0 |
| Violations | | | | 0 |
| Dye Tests | | | | 0 |

| Manhole Inspections | D1 | D4 | D5 | TOTAL |
|---------------------|-----|----|----|------------|
| | 113 | 55 | 0 | 168 |

| Manhole Repairs | D1 | D4 | D5 | TOTAL |
|-----------------|----|----|----|-----------|
| | 8 | 5 | 0 | 13 |

| Root Treatment (ft) | D1 | D4 | D5 | TOTAL |
|---------------------|-----|----|----|------------|
| Vapor Rooting | | | | 0 |
| Cutting w/ Flusher | 247 | 0 | 0 | 247 |
| Mechanical Cleaning | | | | 0 |

| Sewerline Repairs | |
|-------------------|--|
| | |
| SSO | 1314 MINERAL SPRINGS 3270 CLINTON 280 TOWERS |

| PROJECTS | | |
|--------------------------------|--------------------------|----------------------------|
| D1 | D4 | D5 |
| 4814 TRANSIT | BRADLEY EXTENSION | HARRIS HILL MIXED USE SITE |
| 2715 & 2725 CAR WASH -UNION | NEXTERA ENERGY TRANS. | 7145 TRANSIT |
| SONWIL WAREHOUSE | ANGRY BUFFALO | 6625 TRANSIT MIXED USE |
| UPSTATE NIAGARA 3300 N.AMERICA | 4106 WALDEN WAREHOUSE | WOODLAND HILLS PH 3 |
| 395 WEST AVE. | VALVOLINE OIL CHANGE | JAMES RYAN PKWY |
| | 4510 BROADWAY APARTMENTS | CREEKWOOD PUMP HOUSE |
| | 5841 GENESSE SHOP | KRAUS RD. EXTENSION |
| | WOOD SPRING EXTENSION | 5695 & 5731 TRANSIT |
| | 3825 BOWTIE PARK | PEANUT LINE INTERCEPTOR |
| | NEXTERA ENERGY TRANS. | |
| | 4412 JAGG ELECTRIC | |
| | ALDEN GROW FACILITY | |
| | | |
| | | |

| | |
|------------------------|------------------------------------|
| Plans Reviewed: | D5 - NOVA WOK 9515 CLARENCE CENTER |
| | D5-ERIE COUNTY DPW SALT ROAD |
| | |
| | |

2026 MARCH MECHANICAL ROOTCUT DISTRICT #1

| Notification | DATE | Description | Act. code text | Functional Loc. | HANDLE | L/F |
|---------------------|-------------|-------------------------|-----------------------|------------------------|---------------|------------|
| 10201418 | 03/31/2026 | TELEWISE GREGORY 8" VTP | MECHANICAL ROOT CUT | E-S-N01-C-004-SL | BB866 | 247 |

2026 MARCH MECHANICAL ROOTCUT DISTRICT #4

NONE

2026 MARCH MECHANICAL ROOTCUT DISTRICT #5

NONE

COMPLAINT SUMMARY ECSD # 1 MARCH 2026

| Notification | DATE | Description | Prob. code text | Functional Loc. |
|---------------------|-------------|---|--------------------------------|------------------------|
| 10201389 | 03/11/2026 | WATER FLOOD LT SIDE OF FNDN 102 BELLEVUE | HOMEOWNER'S PROBLEM | E-S-N01-C-001-SL |
| 10202536 | 03/31/2026 | SEWER BACKUP - 280 TOWERS BLVD, CHEEKTOW | OVERFLOW OBSERVED | E-S-N01-C-002-SL |
| 10201417 | 03/12/2026 | BACK UP - 10 GREGORY CT CHEEKTOWAGA | FLUSHED LINE/RELIEVED BLOCKAGE | E-S-N01-C-004-SL |
| 10201528 | 03/17/2026 | SEWAGE BACK UP IN BSMT 1221 COMO PARK | FLUSHED LINE/RELIEVED BLOCKAGE | E-S-N01-C-004-SL |
| 10201530 | 03/17/2026 | SINKHOLE 79 SUZETTE DR CHEEKTOWAGA | FOLLOW-UP REQUIRED | E-S-N01-C-007-SL |
| 10202421 | 03/26/2026 | BACK UP - 1291 FRENCH RD, DEPEW | MAIN SURCHARGED DUE TO WEATHER | E-S-N01-C-007-SL |
| 10202534 | 03/31/2026 | SEWER BACKUP - 63 GARY LN, CHEEKTOWAGA | MAIN SURCHARGED DUE TO WEATHER | E-S-N01-C-007-SL |
| 10202535 | 03/31/2026 | SEWER BACKUP - 1255 FRENCH RD, DEPEW | BASEMENT FACILITY | E-S-N01-C-007-SL |
| 10201289 | 03/07/2026 | BACK UP - 331 FRENCH RD, WEST SENECA | HOMEOWNER'S PROBLEM | E-S-N01-C-008-SL |
| 10201378 | 03/12/2026 | BACK UP - 2378 UNION RD, CHEEKTOWAGA | BASEMENT FACILITY | E-S-N01-C-008-SL |
| 10202440 | 03/27/2026 | BACK UP - 2336 UNION RD, CHEEKTOWAGA | BASEMENT FACILITY | E-S-N01-C-008-SL |
| 10201410 | 03/11/2026 | SEWER BACK UP - 1300 MINERAL SPRINGS | OVERFLOW OBSERVED | E-S-N01-C-010-SL |
| 10201436 | 03/13/2026 | ODOR COMPLAINT - 82 CREEKVIEW WEST SENECA | NO PROBLEM / OK | E-S-N01-C-010-SL |
| 10201529 | 03/17/2026 | SEWER BACK UP 50 DYKE RD W SENECA | HOMEOWNER'S PROBLEM | E-S-N01-C-010-SL |
| 10202450 | 03/30/2026 | BACK UP - 40 STEINER, WEST SENECA | BASEMENT FACILITY | E-S-N01-C-010-SL |

COMPLAINT SUMMARY ECSD # 4 MARCH 2026

| | | | | |
|----------|------------|---------------------------------------|---------------------|------------------|
| 10200248 | 03/19/2026 | BACK UP - 167-169 WARNER RD DEPEW | HOMEOWNER'S PROBLEM | E-S-N04-C-003-SL |
| 10202443 | 03/27/2026 | BACK UP - 7 HERITAGE DR, LANCASTER | HOMEOWNER'S PROBLEM | E-S-N04-C-003-SL |
| 10201472 | 03/15/2026 | MANHOLE - 430 CENTRAL AVE. LANCASTER | REFERRED TO OTHERS | E-S-N04-C-005-SL |
| 10201360 | 03/08/2026 | BACK UP - 91 MICHAELS WALK, LANCASTER | HOMEOWNER'S PROBLEM | E-S-N04-C-013-SL |

COMPLAINT SUMMARY ECSD # 5 MARCH 2026

| | | | | |
|----------|------------|---|---------------------|------------------|
| 10201424 | 03/11/2026 | BACK UP - 4755 MARGARET DR, CLARENCE | REFERRED TO OTHERS | E-S-N05-C |
| 10202429 | 03/30/2026 | SEWAGE BCKUP FRONT LAWN 6290 CROSSWINDS | HOMEOWNER'S PROBLEM | E-S-N05-C-003-SL |
| 10201271 | 03/02/2026 | BACK UP - 6250 HEISE RD, CLARENCE | HOMEOWNER'S PROBLEM | E-S-N05-C-004-SL |

MARCH 2026 I&I DISTRICT # 1

| Notification | DATE | Description | Act. code text | Functional Loc. | HANDLE |
|--------------|------------|--------------------------------------|----------------------------------|------------------|--------|
| 10201592 | 03/23/2026 | INSTALL INFLOW PROTECTOR @BELLEVUE | INSTALLED INFLOW PROTECTOR (4) | E-S-N01-C-001-MH | BA3F2 |
| 10201461 | 03/25/2026 | MANHOLE REPAIR @ BENNETT | INSTALLED INFLOW PROTECTOR (4) | E-S-N01-C-001-MH | BA3D0 |
| 10201415 | 03/31/2026 | PLUG 2" PIPE IN MANHOLE @ ST JUDE | REMOVED CROSS CONNECTION, SEV(5) | E-S-N01-C-006-MH | BB1F0 |
| 10202541 | 03/31/2026 | INSTALL INFLOW PROTECTOR @SPRUCEWOOD | INSTALLED INFLOW PROTECTOR (4) | E-S-N01-C-007-MH | BAD5E |
| 10202527 | 03/31/2026 | INSTALL INFLOW PROTECTOR @SPRUCEWOOD | INSTALLED INFLOW PROTECTOR (4) | E-S-N01-C-007-MH | 429 |
| 10201535 | 03/24/2026 | MANHOLE REPAIR FRENCH ESMT (BURIED) | RAISED MANHOLE(4) | E-S-N01-C-008-MH | BAE12 |
| 10200513 | 03/23/2026 | INSTALL INFLOW PROTECTOR @ ORCHARD | INSTALLED INFLOW PROTECTOR (4) | E-S-N01-C-009-MH | BB167 |
| 10196428 | 03/04/2026 | MANHOLE REPAIR @ UNION RD (ESMT) | RAISED MANHOLE(4) | E-S-N01-C-009-MH | BAF3A |

MARCH 2026 I&I DISTRICT # 4

| | | | | | |
|----------|------------|------------------------------------|------------------------------------|------------------|-------|
| 10184318 | 03/05/2026 | MANHOLE REPAIR @ 4 TRENTWOOD TRAIL | REPAIRED FRAME JOINT LEAKS, SLT(3) | E-S-N04-C-006-MH | DF00E |
| 10184428 | 03/26/2026 | MANHOLE REPAIR @ STERLING PL. | RAISED MANHOLE(4) | E-S-N04-C-006-MH | 674 |
| 10184490 | 03/30/2026 | MANHOLE REPAIR @ STERLING PL. | RAISED MANHOLE(4) | E-S-N04-C-006-MH | 657 |
| 10184429 | 03/26/2026 | MANHOLE REPAIR @ STERLING PL. | RAISED MANHOLE(4) | E-S-N04-C-006-MH | 656 |
| 10184494 | 03/30/2026 | MANHOLE REPAIR @ STERLING PL. | RAISED MANHOLE(4) | E-S-N04-C-006-MH | 1062 |

MARCH 2026 I&I DISTRICT # 5

2026 MARCH TELEVISIONING DISTRICT # 1

| Notification | DATE | Description | Act. code text | Functional Loc. | HANDLE | L/F |
|---------------------|-------------|---------------------------|-----------------------|------------------------|---------------|------------|
| 10201418 | 03/31/2026 | TELEVISION GREGORY 8" VTP | TELEVISIONED - (D) | E-S-N01-C-004-SL | BB866 | 247 |
| 10201531 | 03/31/2026 | TELEVISION SUZETTE | TELEVISIONED - (D) | E-S-N01-C-007-SL | BB925 | 097 |

2026 MARCH TELEVISIONING DISTRICT # 4

NONE

2026 MARCH TELEVISIONING DISTRICT # 5

NONE

2026 March UFPO Numbers

(By District/Region)

| | |
|-------------------------------|------|
| Total UFPO Tickets: | 2155 |
| Tickets Outside ECSD Boundary | 327 |

| | Total Tickets | APR Code | | Other APR Codes | Total % | Stakeout % |
|-----------------|---------------|----------------|-----------------|-----------------|---------|------------|
| | | 10 - All Clear | 30 - Staked Out | 31 | | |
| District 1 | 211 | 171 | 40 | | 10% | 7% |
| District 4 | 360 | 253 | 107 | | 17% | 19% |
| District 5 | 109 | 74 | 35 | | 5% | 6% |
| Total NR | 680 | 498 | 182 | | 32% | 33% |
| District 3 | 769 | 539 | 230 | | 36% | 41% |
| District 6 | 121 | 90 | 31 | | 6% | 6% |
| District 8 | 84 | 66 | 18 | | 4% | 3% |
| Total CR | 974 | 695 | 279 | | 45% | 50% |
| District 2 | 174 | 77 | 97 | | 8% | 17% |
| Total SR | 174 | 77 | 97 | | 8% | 17% |
| Totals: | 1828 | 1270 | 558 | | | |

2005 PS Flows

| Month: | MARCH 2026 | | NR Flow Summary 2026 | | | |
|-----------------------|-------------------|--------------|-----------------------------|-------|--------|--------------------|
| Station | SD | Total Hrs | Daily Avg | GPM | GPH | Tot Gal |
| Borden-Clinton | 1 | 403 | 13.0 | 200 | 12000 | 4,842,000 |
| Cayuga | 1 | 1020 | 32.9 | 1190 | 71400 | 51,836,400 |
| Clint-Tran | 1 | 209 | 6.7 | 350 | 21000 | 4,391,100 |
| Industrial Park | 1 | 347 | 11.2 | 3650 | 219000 | 77,677,110 |
| Union | 1 | 68 | 2.2 | 850 | 51000 | 3,442,500 |
| Woodlands | 1 | 27 | 0.9 | 39 | 2340 | 62,244 |
| Aurora South | 4 | 49 | 1.6 | 705 | 42300 | 2,093,850 |
| Bowmansville | 4 | 561 | 18.1 | 1600 | 96000 | 53,856,000 |
| Broadway | 4 | 12 | 0.4 | 16000 | 960000 | 11,520,000 |
| Depew | 4 | 940 | 30.3 | 11000 | 660000 | 409,612,500 |
| Forestream | 4 | 67 | 2.2 | 1050 | 63000 | 4,246,200 |
| Hall | 4 | 131 | 4.2 | 130 | 7800 | 1,021,020 |
| Haskell | 4 | 56 | 1.8 | 590 | 35400 | 1,971,780 |
| Iroquois | 4 | 629 | 20.3 | 3000 | 180000 | 113,184,000 |
| Pleasantview | 4 | 193 | 6.2 | 950 | 57000 | 10,995,300 |
| Vanderbilt | 4 | 22 | 0.7 | 8000 | 480000 | 10,560,000 |
| Warner | 4 | 564 | 18.2 | 5000 | 300000 | 169,200,000 |
| Zoeller | 4 | 232 | 7.5 | 830 | 49800 | 11,548,620 |
| Bryant | 5 | 160 | 5.2 | 600 | 36000 | 5,752,800 |
| Eastern Hills | 5 | 177 | 5.7 | 625 | 37500 | 6,633,750 |
| Forestview | 5 | 36 | 1.2 | 554 | 33240 | 1,199,964 |
| Cannonwoods | 5 | 4 | 0.1 | 173 | 10380 | 44,634 |
| Creekwood | 5 | 63 | 2.0 | 509 | 30540 | 1,908,750 |
| Pinebreeze | 5 | 61 | 2.0 | 325 | 19500 | 1,183,650 |
| Stahley | 5 | 106 | 3.4 | 720 | 43200 | 4,574,880 |
| Transit Valley | 5 | 170 | 5.5 | 450 | 27000 | 4,576,500 |
| Total NR Flow: | | | | | | 967,935,552 |

ERIE COUNTY - SEWER DISTRICT 1,4,5
3/1/2026 TO 3/31/2026
OPERATION REPORT

| INSPECTIONS | D1 | D4 | D5 | TOTAL |
|--------------------|-----------|-----------|-----------|--------------|
| Wyes | 0 | 4 | 7 | 11 |
| Taps | 0 | 0 | 0 | 0 |
| Disconnect | 0 | 1 | 0 | 1 |
| Repair | 4 | 12 | 3 | 19 |
| TOTAL | 4 | 17 | 10 | 31 |

| CONNECTIONS | D1 | D4 | D5 | TOTAL |
|------------------------|-----------|-----------|-----------|--------------|
| New Commercial (NC) | 0 | 0 | 0 | 0 |
| Exist Commercial (EC) | 0 | 0 | 0 | 0 |
| New Residential (NR) | 0 | 4 | 8 | 12 |
| Exist Residential (ER) | 0 | 0 | 0 | 0 |
| TOTAL | 0 | 4 | 8 | 12 |

| PERMITS | D1 | D4 | D5 | TOTAL |
|-------------------------------|-----------|-----------|-----------|--------------|
| New Commercial Issued (NC) | 0 | 1 | 0 | 1 |
| Exist Commercial Issued (EC) | 1 | 0 | 2 | 3 |
| New Residential Issued (NR) | 0 | 0 | 2 | 2 |
| Exist Residential Issued (ER) | 4 | 16 | 1 | 21 |
| TOTAL | 5 | 17 | 5 | 27 |

| PERMIT FEES | D1 | D4 | D5 | TOTAL |
|-----------------------------|-------------|-------------|--------------|--------------|
| New Commercial Fees (NC) | \$0 | \$2 | \$0 | \$2 |
| Exist Commercial Fees (EC) | \$2 | \$0 | \$4 | \$6 |
| New Residential Fees(NR) | \$0 | \$0 | \$704 | \$704 |
| Exist Residential Fees (ER) | \$8 | \$32 | \$2 | \$42 |
| TOTAL | \$10 | \$34 | \$710 | \$754 |

DISTRICT 1

CONNECTIONS/PERMITS

| District | Insp Date | Approval | Permit | # | Street | Town | New/Existing | Property Type | SBL | Permit Type |
|----------|--------------------|----------|-----------|------|--------------------------|-------------|--------------|---|-------------------------|-------------|
| 1 | 3/10/2026 10:00 | Final | CP0106680 | 40 | Knollwood Dr | Cheektowaga | Existing | Residential Single Unit | 125.07-2- 35 | Repair |
| 1 | 3/4/2026 11:00 | Final | CP0104463 | 104 | Martinique Dr | Cheektowaga | Existing | Residential Single Unit Non-Residential Multiple | 125.06-19- 41 | Repair |
| 1 | 3/5/2026 13:00 | Final | CP0103495 | 2920 | William St Saint Jude | Cheektowaga | Existing | Units | 113.15-1-2 125.14-1- | Repair |
| 1 | 3/10/2026 9:00 | | CP0111943 | 30 | Ter | West Seneca | New | Residential Single Unit | 42 | Connection |
| 1 | 3/26/2026 14:00 | Final | CP0111971 | 1495 | Seneca Crk Rd | West Seneca | Existing | Residential Single Unit | 126.17-2- 11 | Repair |

DISTRICT 4

CONNECTIONS/PERMITS

| District | Insp Date | Approval | Permit | # | Street | Town | New/Existing | Property Type | SBL | Permit Type |
|----------|--------------------|----------|-----------|------|----------------|---------------|--------------|----------------------------|------------------|-------------|
| 4 | 3/23/2026 9:00 | Final | CP0410131 | 176 | Buchanan St | Depew | Existing | Residential Single Unit | 103.12-2-12 | Repair |
| 4 | 3/9/2026 13:30 | Final | CP0410125 | 61 | Ledyard Ave | Depew/Chktg | New | Residential Single Unit | 103.12-13- 29 | Repair |
| 4 | 3/10/2026 14:00 | Final | CP0410126 | 47 | Mona Ct | Depew/Chktg | Existing | Residential Single Unit | 93.17-10-42 | Repair |
| 4 | 3/12/2026 13:00 | Final | CP0410128 | 25 | Sylvia Dr | Depew/Chktg | Existing | Residential Single Unit | 103.08-4-4 | Repair |
| 4 | 3/18/2026 12:30 | Final | CP0410129 | 32 | Rumford St | Depew/Lanc | Existing | Residential Single Unit | 104.38-2-5 | Repair |
| 4 | 3/31/2026 9:00 | Final | CP0401444 | 3803 | Bowen Rd | Lancaster (T) | Existing | Residential Single Unit | 116.00-2-44 | Disconnect |
| 4 | 3/20/2026 13:30 | Final | CP0410051 | 10 | Fieldstream Ln | Lancaster (T) | New | Residential Single Unit | 116.15-1-32 | Connection |
| 4 | 3/30/2026 14:00 | Final | CP0410021 | 11 | Fieldstream Ln | Lancaster (T) | New | Residential Single Unit | 116.15-1-6 | Connection |

| | | | | | | | | | | | |
|---|-----------|-------|-------|-----------|------|----------------|---------------|----------|-------------------------|----------------|------------|
| 4 | 3/27/2026 | 14:00 | Final | CP0410023 | 17 | Fieldstream Ln | Lancaster (T) | New | Residential Single Unit | 116.15-1-9 | Connection |
| 4 | 3/20/2026 | 14:00 | Final | CP0410028 | 27 | Fieldstream Ln | Lancaster (T) | New | Residential Single Unit | 116.15-1-14 | Connection |
| 4 | 3/26/2026 | 13:00 | Final | CP0407040 | 37 | Greenmeadow Dr | Lancaster (T) | Existing | Residential Single Unit | 93.18-5-13 | Repair |
| 4 | 3/3/2026 | 13:00 | Final | CP0405500 | 58 | Impala Pkwy | Lancaster (T) | Existing | Residential Single Unit | 93.19-4-10 | Repair |
| 4 | 3/9/2026 | 13:00 | Final | CP0410127 | 78 | Impala Pkwy | Lancaster (T) | Existing | Residential Single Unit | 93.19-4-5 | Repair |
| 4 | 3/31/2026 | 14:00 | Final | CP0410135 | 41 | Lombardy St | Lancaster (T) | Existing | Residential Single Unit | 115.27-4-17 | Repair |
| 4 | 3/16/2026 | 13:30 | Final | CP0403719 | 1111 | Penora St | Lancaster (T) | Existing | Residential Single Unit | 115.14-2-26.11 | Repair |
| 4 | 3/4/2026 | 14:00 | Final | CP0408338 | 170 | Aurora St | Lancaster (V) | Existing | Residential Single Unit | 115.07-10-1.1 | Repair |
| 4 | 3/23/2026 | 13:00 | Final | CP0410130 | 3523 | Walden Ave | Lancaster (V) | Existing | Residential Single Unit | 104.11-4-1 | Repair |

DISTRICT 5

CONNECTIONS/PERMITS

| District | Insp Date | Approval | Permit | # | Street | Town | New/Existing | Property Type | SBL | Permit Type |
|----------|-----------------|----------|-----------|------|---------------------|----------|--------------|-----------------------------|------------|-------------|
| 5 | 3/25/2026 11:30 | Final | CP0501645 | 8215 | Main St Oak Leaf | Clarence | Existing | Non-Residential Single Unit | 82.01-1-55 | Repair |
| 5 | 3/6/2026 10:30 | Final | CP0500759 | 8185 | Ln | Clarence | Existing | Residential Single Unit | 57.14-2-17 | Repair |
| 5 | 3/26/2026 9:30 | Partial | CP0500849 | 6343 | Transit Rd | Clarence | Existing | Non-Residential Single Unit | 43.09-4-7 | Repair |

DISTRICT 5 CLARENCE TOWN DISTRICTS

| District | CTD | Insp Date | Permit | # | Street | Town | Permit Subtype | New/Existing | Property Type | SBL | Permit Type | Tap Type |
|----------|-----|-----------------|-----------|------|----------------|----------|----------------|--------------|-------------------------|------------|-------------|----------|
| 5 | | 3/6/2026 13:00 | CP0504426 | 9497 | Deer Valley Dr | Clarence | Clarence Iss | New | Residential Single Unit | 44.11-5-27 | Connection | Wye |
| 5 | | 3/25/2026 11:00 | CP0504427 | 9518 | Deer Valley Dr | Clarence | Clarence Iss | New | Residential Single Unit | 0 | Connection | |

| | | | | | | | | | | | | |
|---|----|--------------------|-----------|------|-------------------------|----------|--------------|----------|-------------------------|------------|------------|-----|
| 5 | | 3/18/2026 13:00 | CP0504441 | 6430 | Goodrich Rd | Clarence | Clarence Iss | Existing | Residential Single Unit | 44-10-1-2 | Repair | |
| 5 | 2 | 3/10/2026 13:00 | CP0504422 | 9490 | Deer Valley Dr | Clarence | Clarence Iss | New | Residential Single Unit | 44.11-5-2 | Connection | Wye |
| 5 | 2 | 3/24/2026 13:00 | CP0504424 | 9545 | Deer Valley Dr | Clarence | Clarence Iss | New | Residential Single Unit | 44.11-5-20 | Connection | Wye |
| 5 | 4 | 3/10/2026 11:00 | CP0504417 | 9748 | Longleaf Trl | Clarence | Clarence Iss | New | Residential Single Unit | 58.16-5-9 | Connection | Wye |
| 5 | 4 | 3/9/2026 11:00 | CP0504406 | 9760 | Longleaf Trl | Clarence | Clarence Iss | New | Residential Single Unit | 58.16-5-12 | Connection | Wye |
| 5 | 4 | 3/19/2026 13:00 | CP0504423 | 9655 | Spaulding Green PkwY | Clarence | Clarence Iss | New | Residential Single Unit | 58.16-5-19 | Connection | Wye |
| 5 | 10 | 3/4/2026 13:00 | CP0504409 | 5141 | Kandefer's Trl | Clarence | Clarence Iss | New | Residential Single Unit | 57.19-7-8 | Connection | Wye |

| Location | Dist. | Description | Tank Capacity | Internal Tank Height | Gal/in | Date | Gen Hours | Gauge Level | Dip Level | Gallons Remaining | % Full | Gallons Needed | Gallons Added | Refill? | Refill Level |
|--------------------|-------|-----------------|---------------|----------------------|--------|--------|-----------|-------------|-----------|-------------------|--------|----------------|---------------|---------|--------------|
| Borden | 1 | Under Generator | 180 | 21 | 8.57 | 31-Mar | 2043 | | 17.25 | 148 | 82 | 32 | | - | 135 |
| Cayuga | 1 | Under Generator | 1300 | 33 | 39.39 | 31-Mar | 843 | | 29 | 1142 | 88 | 158 | | - | 975 |
| Clinton | 1 | Under Generator | 150 | 24 | 6.25 | 31-Mar | 1968.5 | | 20.5 | 128 | 85 | 22 | | - | 113 |
| Industrial Parkway | 1 | Under Generator | 700 | 30 | 23.33 | 31-Mar | 711.6 | | 27 | 630 | 90 | 70 | | - | 525 |
| Union | 1 | Under Generator | 400 | 26 | 15.38 | 31-Mar | 155.7 | | 25.25 | 388 | 97 | 12 | | - | 300 |
| Aurora South | 4 | Under Generator | 285 | 21 | 13.57 | 31-Mar | 1814 | | 17.75 | 241 | 85 | 44 | | - | 214 |
| Bowmansville | 4 | Under Generator | 700 | 26 | 26.92 | 31-Mar | 973 | | 23.25 | 626 | 89 | 74 | | - | 525 |
| Broadway | 4 | Above-Ground | 1000 | 36 | * | 31-Mar | 321 | | 33.25 | 796 | 80 | 204 | | - | 750 |
| Depew | 4 | Above-Ground | 3000 | 69 | * | 31-Mar | 512 | | 46 | 1986 | 66 | 1014 | | X | 2250 |
| Iroquois | 4 | Under Generator | 295 | 17 | 17.35 | 31-Mar | 1116 | | 16.25 | 282 | 96 | 13 | | - | 221 |
| Vanderbilt | 4 | Above-Ground | 1000 | 36 | * | 31-Mar | 160.6 | | 32.75 | 796 | 80 | 204 | | - | 750 |
| Warner | 4 | Under Generator | 700 | 26 | 26.92 | 31-Mar | 1909 | | 23.25 | 626 | 89 | 74 | | - | 525 |
| Zoeller | 4 | Under Generator | 680 | 32 | 21.25 | 31-Mar | 16.8 | | 24.25 | 515 | 76 | 165 | | - | 510 |
| Bryant | 5 | Under Generator | 180 | 22 | 8.18 | 31-Mar | 698.6 | | 17.5 | 143 | 80 | 37 | | - | 135 |
| Pinebreeze | 5 | Under Generator | 275 | 44 | * | 31-Mar | 1328.5 | | 44 | 275 | 100 | 0 | | - | 206 |
| Stahley | 5 | Under Generator | 150 | 25 | 6.00 | 31-Mar | 1615 | | 25 | 150 | 100 | 0 | | - | 113 |
| Transit Valley | 5 | Above Ground | 275 | 44 | * | 31-Mar | 84.1 | | 42.75 | 268 | 97 | 7 | | - | 206 |

* Calculated

Refill at: 0.75

March 2026 Maintenance

District 1

Cleaned and restocked bathrooms at Cayuga and Industrial Park.
Filled sink hole with stone in front lawn at Borden.
Repaired plowing damage to all station lawns.
Delivered new spare pump and volute to Borden for storage.
Picked up new flange for Industrial Park sump and installed on pump. Installed sump back in station and put back in service.
Swapped pump #3 at Cayuga with spare pump.
Swapped pump #4 at Industrial Park with spare pump.
Washed wet well floor at Industrial Park.
Cut up fallen dead ash trees at Cayuga.
Rebuilt Cayuga spare pump and delivered to station for storage.
Fixed hypo levels on hydro ranger at Cayuga.
Began VFD PM's
Replaced coil on Pump 1 at Borden
Replaced VFD 4 at IPP.

District 4

Cleaned and restocked bathroom at Depew.
Swapped pump #1 at Zoeller with spare.
Power washed pulled Depew muffin monster in shop.
Finished rebuilding Depew spare pump and delivered to station for storage.
Pulled and cleaned pump #1 at Bowmansville.
Pulled and cleaned pump #2 at Bowmanville 3 different times.
Repaired broken air line fitting on the back of NR47.
Repaired blown tire on portable generator.
Replaced air release on Depew pump #1.
Repaired plowing damage to lawns at Auroa South, Depew, Depew ORF, Iroquois, Warner, and Vanderbilt.
Continued painting interior walls at Depew station.
Adjusted trip point for Zoeller main breaker.
Began running for AP's at Base 4.
Rebuilt E-One Pumps at Base 4
Calibrated gas detectors Base 4.

District 5

Cleaned and restocked station bathrooms at Eastern Hills and Stahley.

Repaired fencing at Eastern Hills.

Cut up fallen dead ash trees at CRP.

Replaced motor starters at Transit Valley.

Installed HWW Float at Cannon Woods.

Cleaned out block heater hose at Bryant & Stratton

Met NYSEG at Transit Valley to verify electrical service.

Repaired transfer switch at Transit Valley.

All Districts

Checked fluids in station generators and added fuel where needed.

Completed HWW Float PM's

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
APRIL 2026 MONTHLY OPERATION REPORT**

| INSPECTIONS | D1 | D4 | D5 |
|---------------|----------|----------|----------|
| MH Connection | | | |
| Grinder | | | |
| TOTALS | 0 | 0 | 0 |
| | 0 | | |

| UFPO's | D1 | D4 | D5 |
|------------------------|------------|-----|-----|
| Responses | 308 | 565 | 147 |
| Stakeouts | 74 | 77 | 37 |
| TOTAL STAKEOUTS | 188 | | |

| Sewer Flushing (feet) | D1 | D4 | D5 | TOTAL |
|-----------------------|--------|-----|-----|---------------|
| | 11,754 | 449 | 321 | 12,524 |

| Televising (feet) | D1 | D4 | D5 | TOTALS |
|-------------------|-------|-----|----|--------------|
| By Central Maint | | | | 0 |
| By District | 3,310 | 210 | 0 | 3,520 |

| | D1 | D4 | D5 | TOTALS |
|-------------------|----|----|----|--------|
| House Inspections | | | | 0 |
| Reinspections | | | | 0 |
| Violations | | | | 0 |
| Dye Tests | | | | 0 |

| Manhole Inspections | D1 | D4 | D5 | TOTAL |
|---------------------|----|----|----|-----------|
| | 36 | 0 | 0 | 36 |

| Manhole Repairs | D1 | D4 | D5 | TOTAL |
|-----------------|----|----|----|-----------|
| | 8 | 4 | 0 | 12 |

| Root Treatment (ft) | D1 | D4 | D5 | TOTAL |
|---------------------|-------|----|----|--------------|
| Vapor Rooting | | | | 0 |
| Cutting w/ Flusher | 1,189 | 0 | 0 | 1,189 |
| Mechanical Cleaning | | | | 0 |

| | |
|----------------------------|--|
| Sewerline Repairs | |
| San. Sewer Overflow | |

| DIST #1 | DIST #4 | DIST #5 |
|--------------------------------|--------------------------|----------------------------|
| 4814 TRANSIT | BRADLEY EXTENSION | HARRIS HILL MIXED USE SITE |
| 2715 & 2725 CAR WASH -UNION | NEXTERA ENERGY TRANS. | 7145 TRANSIT |
| SONWIL WAREHOUSE | ANGRY BUFFALO | 6625 TRANSIT MIXED USE |
| UPSTATE NIAGARA 3300 N.AMERICA | 4106 WALDEN WAREHOUSE | WOODLAND HILLS PH 3 |
| 395 WEST AVE. | VALVOLINE OIL CHANGE | JAMES RYAN PKWY |
| | 4510 BROADWAY APARTMENTS | CREEKWOOD PUMP HOUSE |
| | 5841 GENESE SHOP | KRAUS RD. EXTENSION |
| | WOOD SPRING EXTENSION | 5695 & 5731 TRANSIT |
| | 3825 BOWTIE PARK | PEANUT LINE INTERCEPTOR |
| | NEXTERA ENERGY TRANS. | |
| | 4412 JAGG ELECTRIC | |
| | ALDEN GROW FACILITY | |

| | |
|------------------------|---|
| Plans Reviewed: | D1- 4400 WALDEN AVENEUE SEALING DEVICES |
| | D5- 9388 TRANSIT SMOO TEA |
| | |
| | |

2026 APRIL MECHANICAL ROOTCUT DISTRICT #1

| Notification | DATE | Description | Act. code text | Functional Loc. | HANDLE | L/F |
|---------------------|-------------|---------------------------------------|-----------------------|------------------------|---------------|------------|
| 10196557 | 04/02/2026 | TELEWISE COMO PARK 8" VTP | MECHANICAL ROOT CUT | E-S-N01-C-004-SL | BB664 | 346 |
| 10201550 | 04/07/2026 | FOLLOW UP TELEVISION @ 1249 COMO PARK | MECHANICAL ROOT CUT | E-S-N01-C-004-SL | BB663 | 347 |
| 10202652 | 04/06/2026 | TELEWISE GREGORY 8" VTP | MECHANICAL ROOT CUT | E-S-N01-C-010-SL | BC1A5 | 261 |
| 10202791 | 04/17/2026 | TELEWISE SENECA CREEK 8" ACP | MECHANICAL ROOT CUT | E-S-N01-C-010-SL | BC2E0 | 235 |

2026 APRIL MECHANICAL ROOTCUT DISTRICT #4

NONE

2026 APRIL MECHANICAL ROOTCUT DISTRICT #5

NONE

COMPLAINT SUMMARY ECSD # 1 APRIL 2026

| Notification | DATE | Description | Prob. code text | Functional Loc. |
|--------------|------------|--|--------------------------------|------------------|
| 10201327 | 04/01/2026 | MH OVERFLOWING 102 BELLEVUE AVE | OTHER (DESCRIBE IN LONG TEXT) | E-S-N01-C-001-SL |
| 10202529 | 04/01/2026 | BACK UP - 837 LOSSON RD | HOMEOWNER'S PROBLEM | E-S-N01-C-002-SL |
| 10203491 | 04/01/2026 | BACK UP STATIONARY TUB 837 LOSSON RD | HOMEOWNER'S PROBLEM | E-S-N01-C-002-SL |
| 10202547 | 04/04/2026 | SEWER BACKUP - 1255 COMO PARK BLVD, CHEE | HOMEOWNER'S PROBLEM | E-S-N01-C-004-SL |
| 10202417 | 04/30/2026 | BSMT DRAIN HAS BACK UP 65 JOHN BRIAN LN | FLUSHED LINE/RELIEVED BLOCKAGE | E-S-N01-C-007-SL |
| 10202683 | 04/15/2026 | SINKHOLE 12 FRANTZEN TER CHEEKTOWAGA | HOMEOWNER'S PROBLEM | E-S-N01-C-007-SL |
| 10202758 | 04/18/2026 | SEWER BACKUP - 108 FRENCH LEA RD, WEST S | HOMEOWNER'S PROBLEM | E-S-N01-C-007-SL |
| 10202568 | 04/02/2026 | BACK UP - 2378 UNION RD | MAIN SURCHARGED DUE TO WEATHER | E-S-N01-C-008-SL |
| 10203492 | 04/20/2026 | SEWER BACK UP 2336 UNION RD | BASEMENT FACILITY | E-S-N01-C-008-SL |
| 10203521 | 04/27/2026 | BACK UP - 2378 UNION RD, CHEEKTOW | OTHER (DESCRIBE IN LONG TEXT) | E-S-N01-C-008-SL |
| 10203495 | 04/27/2026 | SEWAGE BCKUP IN BSMT 4300 GLINTON ST | BASEMENT FACILITY | E-S-N01-C-009-SL |
| 10202549 | 04/04/2026 | SEWER BACKUP - 1 FRANK CT, WEST SENECA | FLUSHED LINE/RELIEVED BLOCKAGE | E-S-N01-C-010-SL |
| 10202566 | 04/01/2026 | BACK UP - 501 LEIN RD WEST SENECA | BASEMENT FACILITY | E-S-N01-C-010-SL |
| 10202615 | 04/07/2026 | SINKHOLE - 1045 SENECA CRK RD W SENECA | NO FURTHER WORK REQUIRED | E-S-N01-C-010-SL |
| 10202653 | 04/11/2026 | BACK UP - 276 SENECA CREEK RD, WEST SENE | HOMEOWNER'S PROBLEM | E-S-N01-C-010-SL |
| 10203532 | 04/28/2026 | SLOW SEWER 530 SENECA CREEK RD | HOMEOWNER'S PROBLEM | E-S-N01-C-010-SL |

COMPLAINT SUMMARY ECSD # 4 APRIL 2026

| | | | | |
|----------|------------|---|--------------------------|------------------|
| 10202783 | 04/20/2026 | MH COVER OFF 5651 TRANSIT RD DEPW | FOLLOW-UP REQUIRED | E-S-N04-C-008-MH |
| 10202574 | 04/06/2026 | SEWER BACK UP - 90 GRAMBO DR, LANCASTER | FLUSHED LINE/NO BLOCKAGE | E-S-N04-C-010-SL |
| 10202787 | 04/22/2026 | GREEN PIPE WATER DISCHARGE 27 BENTLEY | HOMEOWNER'S PROBLEM | E-S-N04-C-015-SL |
| 10202806 | 04/23/2026 | TOILET BUBBLING OVERFLOW 27 BENTLEY | HOMEOWNER'S PROBLEM | E-S-N04-C-015-SL |

COMPLAINT SUMMARY ECSD # 5 APRIL 2026

| | | | | |
|----------|------------|--|---------------------|------------------|
| 10203475 | 04/24/2026 | WATER COMING OUT OF PIPE 8197 FERNLEAF | HOMEOWNER'S PROBLEM | E-S-N05-C-007-SL |
|----------|------------|--|---------------------|------------------|

APRIL 2026 I&I DISTRICT # 1

| Notification | DATE | Description | Act. code text | Functional Loc. | HANDLE |
|---------------------|-------------|--|--|------------------------|---------------|
| 10203451 | 04/24/2026 | MANHOLE REPAIR @ 3150 UNION | REPAIRED CONE/BARREL JOINT LEAKS, SEV(5) | E-S-N01-C-001-MH | BA2DE |
| 10203533 | 04/27/2026 | INSTALL INFLOW PROTECTOR @ INNSBRUCK | INSTALLED INFLOW PROTECTOR (4) | E-S-N01-C-008-MH | BADFC |
| 10203481 | 04/27/2026 | INSTALL INFLOW PROTECTOR 30 INNSBRUCK | INSTALLED INFLOW PROTECTOR (4) | E-S-N01-C-008-MH | BADFD |
| 10203500 | 04/27/2026 | INSTALL INFLOW PROTECTOR @ CLINTON | INSTALLED INFLOW PROTECTOR (4) | E-S-N01-C-009-MH | BB27C |
| 10203449 | 04/27/2026 | INSTALL INFLOW PROTECTOR @ CLINTON | INSTALLED INFLOW PROTECTOR (4) | E-S-N01-C-009-MH | BB27B |
| 10202686 | 04/28/2026 | MANHOLE REPAIR @ 3875 CLINTON | REPAIRED FRAME JOINT LEAKS, SLT(3) | E-S-N01-C-009-MH | BB1F4 |
| 10202746 | 04/30/2026 | MANHOLE REPAIR @ 540 SENECA CREEK ROAD | REPAIRED FRAME/CONE JOINT LEAKS, MOD(4) | E-S-N01-C-010-MH | BBE70 |
| 10201460 | 04/27/2026 | MANHOLE REPAIR @ 2375 CLINTON | REPAIRED FRAME JOINT LEAKS, SEV(5) | E-S-N01-C-012-MH | BAA92 |

APRIL 2026 I&I DISTRICT # 4

| | | | | | |
|----------|------------|----------------------------------|---|------------------|--------|
| 10181310 | 04/20/2026 | MANHOLE REPAIR @ 16 MIDDLEBURY | RAISED MANHOLE(4) | E-S-N04-C-002-MH | 402196 |
| 10184500 | 04/02/2026 | MANHOLE REPAIR @ CHICORY LN. | RAISED MANHOLE(4) | E-S-N04-C-006-MH | 1ABAED |
| 10202467 | 04/02/2026 | MANHOLE REPAIR @ 3753 WALDEN AVE | REPAIRED FRAME JOINT LEAKS, SLT(3) | E-S-N04-C-008-MH | DF01C |
| 10202790 | 04/21/2026 | MANHOLE REPAIR @ 5651 TRANSIT | REPAIRED FRAME/CONE JOINT LEAKS, SLT(3) | E-S-N04-C-008-MH | DF09C |

APRIL 2026 I&I DISTRICT # 5

NONE

2026 APRIL TELEVISION DISTRICT # 1

| Notification | DATE | Description | Act. code text | Functional Loc. | HANDLE | L/F |
|---------------------|-------------|---------------------------------------|-----------------------|------------------------|---------------|------------|
| 10201478 | 04/08/2026 | TELEVISION BELEVUE 8" ACP | TELEVISIONED - (D) | E-S-N01-C-001-SL | BB532 | 240 |
| 10201542 | 04/10/2026 | TELEVISION BELEVUE 12" VTP | TELEVISIONED - (D) | E-S-N01-C-001-SL | BB52A | 201 |
| 10201541 | 04/09/2026 | TELEVISION BELEVUE 12" VTP | TELEVISIONED - (D) | E-S-N01-C-001-SL | BB52B | 100 |
| 10201540 | 04/09/2026 | TELEVISION BELEVUE 12" VTP | TELEVISIONED - (D) | E-S-N01-C-001-SL | BB52E | 304 |
| 10201479 | 04/08/2026 | TELEVISION BELEVUE 12" VTP | TELEVISIONED - (D) | E-S-N01-C-001-SL | BB533 | 267 |
| 10196557 | 04/02/2026 | TELEVISION COMO PARK 8" VTP | TELEVISIONED - (D) | E-S-N01-C-004-SL | BB664 | 346 |
| 10201550 | 04/07/2026 | FOLLOW UP TELEVISION @ 1249 COMO PARK | TELEVISIONED - (D) | E-S-N01-C-004-SL | BB663 | 347 |
| 10201205 | 04/10/2026 | FOLLOW UP TELEVISION @ 2345 UNION RD | TELEVISIONED - (D) | E-S-N01-C-006-SL | BBC1A | 219 |
| 10202714 | 04/06/2026 | TELEVISION KELLY DRIVE 8" VTP | TELEVISIONED - (D) | E-S-N01-C-007-SL | BBF8E | 301 |
| 10202713 | 04/06/2026 | TELEVISION KELLY DRIVE 8" PVC | TELEVISIONED - (D) | E-S-N01-C-007-SL | 13FED4 | 183 |
| 10202794 | 04/22/2026 | 2378 UNION INSPECTIONS / TELEVISION | TELEVISIONED - (D) | E-S-N01-C-008-SL | BB709 | 306 |
| 10202652 | 04/06/2026 | TELEVISION GREGORY 8" VTP | TELEVISIONED - (D) | E-S-N01-C-010-SL | BC1A5 | 261 |
| 10202791 | 04/17/2026 | TELEVISION SENECA CREEK 8" ACP | TELEVISIONED - (D) | E-S-N01-C-010-SL | BC2E0 | 235 |

2026 APRIL TELEVISION DISTRICT # 4

| | | | | | | |
|----------|------------|-------------------------------------|--------------------|------------------|-------|-----|
| 10201258 | 04/06/2026 | FOLLOW UP TELEVISION @ 580 LAKE AVE | TELEVISIONED - (D) | E-S-N04-C-015-SL | DFB83 | 210 |
|----------|------------|-------------------------------------|--------------------|------------------|-------|-----|

2026 APRIL TELEVISION DISTRICT # 5

NONE

2026 April UFPO Numbers

(By District/Region)

| | |
|-------------------------------|------|
| Total UFPO Tickets: | 2915 |
| Tickets Outside ECSD Boundary | 409 |

| | Total Tickets | APR Code | | Other APR Codes | Total % | Stakeout % |
|-----------------|---------------|----------------|-----------------|-----------------|---------|------------|
| | | 10 - All Clear | 30 - Staked Out | 31 | | |
| District 1 | 308 | 234 | 74 | | 11% | 14% |
| District 4 | 565 | 488 | 77 | | 19% | 15% |
| District 5 | 147 | 110 | 37 | | 5% | 7% |
| Total NR | 1020 | 832 | 188 | | 35% | 36% |
| District 3 | 987 | 836 | 151 | | 34% | 29% |
| District 6 | 158 | 106 | 52 | | 5% | 10% |
| District 8 | 99 | 81 | 18 | | 3% | 3% |
| Total CR | 1244 | 1023 | 221 | | 43% | 42% |
| District 2 | 242 | 124 | 118 | | 8% | 22% |
| Total SR | 242 | 124 | 118 | | 8% | 22% |
| Totals: | 2506 | 1979 | 527 | | | |

2005 PS Flows

| Month: | APRIL 2026 | | NR Flow Summary 2026 | | | |
|-----------------------|------------|--------------|----------------------|-------|--------|----------------------|
| Station | SD | Total Hrs | Daily Avg | GPM | GPH | Tot Gal |
| Borden-Clinton | 1 | 530 | 17.1 | 200 | 12000 | 6,360,000 |
| Cayuga | 1 | 1397 | 45.1 | 1190 | 71400 | 69,100,920 |
| Clint-Tran | 1 | 261 | 8.4 | 350 | 21000 | 5,481,000 |
| Industrial Park | 1 | 404 | 13.0 | 3650 | 219000 | 77,385,840 |
| Union | 1 | 88 | 2.9 | 850 | 51000 | 4,508,400 |
| Woodlands | 1 | 37 | 1.2 | 39 | 2340 | 87,048 |
| Aurora South | 4 | 64 | 2.1 | 705 | 42300 | 2,707,200 |
| Bowmansville | 4 | 798 | 25.7 | 1600 | 96000 | 76,608,000 |
| Broadway | 4 | 27 | 0.9 | 16000 | 960000 | 25,920,000 |
| Depew | 4 | 1516 | 48.9 | 11000 | 660000 | 663,300,000 |
| Forestream | 4 | 86 | 2.8 | 1050 | 63000 | 5,411,700 |
| Hall | 4 | 227 | 7.3 | 130 | 7800 | 1,769,820 |
| Haskell | 4 | 79 | 2.6 | 590 | 35400 | 2,810,760 |
| Iroquois | 4 | 778 | 25.1 | 3000 | 180000 | 140,040,000 |
| Pleasantview | 4 | 262 | 8.5 | 950 | 57000 | 14,956,800 |
| Vanderbilt | 4 | 37 | 1.2 | 8000 | 480000 | 17,760,000 |
| Warner | 4 | 734 | 23.7 | 5000 | 300000 | 220,200,000 |
| Zoeller | 4 | 329 | 10.6 | 830 | 49800 | 16,394,160 |
| Bryant | 5 | 218 | 7.0 | 600 | 36000 | 7,830,000 |
| Eastern Hills | 5 | 243 | 7.8 | 625 | 37500 | 9,093,750 |
| Forestview | 5 | 43 | 1.4 | 554 | 33240 | 1,425,996 |
| Cannonwoods | 5 | 35 | 1.1 | 173 | 10380 | 364,338 |
| Creekwood | 5 | 83 | 2.7 | 509 | 30540 | 2,537,874 |
| Pinebreeze | 5 | 80 | 2.6 | 325 | 19500 | 1,563,900 |
| Stahley | 5 | 141 | 4.5 | 720 | 43200 | 6,073,920 |
| Transit Valley | 5 | 244 | 7.9 | 450 | 27000 | 6,585,300 |
| Total NR Flow: | | | | | | 1,386,276,726 |

ERIE COUNTY - SEWER DISTRICT 1,4,5
4/1/2026 TO 4/30/2026
OPERATION REPORT

| INSPECTIONS | D1 | D4 | D5 | TOTAL |
|--------------------|-----------|-----------|-----------|--------------|
| Wyes | 0 | 2 | 6 | 8 |
| Taps | 0 | 0 | 0 | 0 |
| Disconnect | 1 | 1 | 0 | 2 |
| Repair | 6 | 12 | 2 | 20 |
| TOTAL | 7 | 15 | 8 | 30 |

| CONNECTIONS | D1 | D4 | D5 | TOTAL |
|------------------------|-----------|-----------|-----------|--------------|
| New Commercial (NC) | 0 | 0 | 0 | 0 |
| Exist Commercial (EC) | 0 | 0 | 0 | 0 |
| New Residential (NR) | 0 | 2 | 6 | 8 |
| Exist Residential (ER) | 0 | 0 | 0 | 0 |
| TOTAL | 0 | 2 | 6 | 8 |

| PERMITS | D1 | D4 | D5 | TOTAL |
|-------------------------------|-----------|-----------|-----------|--------------|
| New Commercial Issued (NC) | 0 | 0 | 0 | 0 |
| Exist Commercial Issued (EC) | 2 | 1 | 0 | 3 |
| New Residential Issued (NR) | 0 | 8 | 3 | 11 |
| Exist Residential Issued (ER) | 8 | 12 | 2 | 22 |
| TOTAL | 10 | 21 | 5 | 36 |

| PERMIT FEES | D1 | D4 | D5 | TOTAL |
|-----------------------------|----------------|----------------|------------|----------------|
| New Commercial Fees (NC) | \$0 | \$0 | \$0 | \$0 |
| Exist Commercial Fees (EC) | \$1,404 | \$2 | \$0 | \$1,406 |
| New Residential Fees(NR) | \$0 | \$4,216 | \$2 | \$4,218 |
| Exist Residential Fees (ER) | \$16 | \$24 | \$4 | \$44 |
| TOTAL | \$1,420 | \$4,242 | \$6 | \$5,668 |

DISTRICT 1

CONNECTIONS/PERMITS

| District | Insp Date | Approval | Permit | # | Street | Town | New/Existing | Property Type | SBL | Permit Type |
|----------|-----------|----------|-----------|------|--------------|-------------|--------------|---------------|---------|-------------|
| | 4/20/2026 | | | | Autumnwood | | | Residential | 125.07- | |
| 1 | 13:30 | Final | CP0100810 | 143 | Dr | Cheektowaga | Existing | Single Unit | 5-7 | Repair |
| | 4/29/2026 | | | | Castlewood | | | Residential | 125.07- | |
| 1 | 13:30 | Final | CP0102499 | 145 | Dr | Cheektowaga | Existing | Single Unit | 2-20 | Repair |
| | 4/29/2026 | | | | Como Park | | | Residential | 114.08- | |
| 1 | 13:00 | Final | CP0102904 | 1254 | Blvd | Cheektowaga | Existing | Single Unit | 2-1 | Repair |
| | 4/29/2026 | | | | | | | Residential | 125.08- | |
| 1 | 12:30 | Final | CP0105298 | 43 | Frantzen Ter | Cheektowaga | Existing | Single Unit | 11-9 | Repair |
| | 4/14/2026 | | | | | | | Residential | | |
| | 4/14/2026 | | | | | | | Multiple | 124.20- | |
| 1 | 13:00 | Final | CP0100867 | 3368 | Clinton St | West Seneca | New | Units | 11-56 | Repair |
| | 4/14/2026 | | | | | | | Residential | 124.11- | |
| 1 | 13:30 | Final | CP0111972 | 218 | French Rd | West Seneca | Existing | Single Unit | 1-5 | Disconnect |
| | 4/20/2026 | | | | | | | Residential | 124.18- | |
| 1 | 14:00 | Final | CP0109022 | 40 | Steiner Ave | West Seneca | Existing | Single Unit | 3-15 | Repair |

DISTRICT 4

CONNECTIONS/PERMITS

| District | Insp Date | Approval | Permit | # | Street | Town | New/Existing | Property Type | SBL | Permit Type | Tap Type | Demolish |
|----------|----------------|----------|-----------|----|----------------|---------------|--------------|-------------------------|------------|-------------|----------|----------|
| | 4/23/2026 | | | | | | | | 93.17-13- | | | |
| 4 | 13:30 | Final | CP0409710 | 14 | Bonita Dr | Depew/Chktg | Existing | Residential Single Unit | 16 | Repair | | |
| | | | | | | | | | 116.14-3- | | | |
| 4 | 4/8/2026 10:00 | Final | CP0405844 | 1 | Cobblestone Ct | Lancaster (T) | Existing | Residential Single Unit | 49 | Repair | | |
| | | | | | | | | | 126.10-1- | | | |
| 4 | 4/9/2026 13:00 | Final | CP0406485 | 32 | Fieldstone Ln | Lancaster (T) | Existing | Residential Single Unit | 70 | Repair | | |
| | | | | | | | | | 116.15-1- | | | |
| 4 | 4/8/2026 14:00 | Final | CP0410019 | 6 | Fieldstream Ln | Lancaster (T) | New | Residential Single Unit | 30 | Connection | Wye | |
| | 4/14/2026 | | | | | | | | | | | |
| 4 | 11:00 | Final | CP0405849 | 7 | Heritage Dr | Lancaster (T) | Existing | Residential Single Unit | 93.14-1-72 | Repair | | |
| | | | | | | | | | 104.07-6- | | | |
| 4 | 4/8/2026 11:00 | Final | CP0410137 | 23 | Katherine St | Lancaster (T) | Existing | Residential Single Unit | 17.1 | Repair | | |
| | 4/28/2026 | | | | | | | | | | | |
| 4 | 13:30 | Final | CP0409875 | 2 | Northfield Ln | Lancaster (T) | New | Residential Single Unit | 94.11-1-10 | Connection | Wye | |

| | | | | | | | | | | | |
|---|-----------------------------|-------|-----------|------|---------------------|---------------|----------|-----------------------------|---------------|------------|----------|
| 4 | 4/24/2026 13:00 | Final | CP0404854 | 430 | Pleasant View Dr | Lancaster (T) | Existing | Residential Single Unit | 93.00-2-4.2 | Repair | |
| 4 | 4/2/2026 10:30 4/10/2026 | Final | CP0403034 | 66 | Running Brook Dr | Lancaster (T) | Existing | Residential Single Unit | 126.10-1-40 | Repair | |
| 4 | 13:00 | Final | CP0402012 | 4380 | Walden Ave | Lancaster (T) | Existing | Non-Residential Single Unit | 95.00-4-6.11 | Disconnect | DEMOLISH |
| 4 | 4/6/2026 13:00 4/23/2026 | Final | CP0410136 | 55 | Wilma Dr | Lancaster (T) | Existing | Residential Single Unit | 115.07-12-29 | Repair | |
| 4 | 14:00 | Final | CP0410146 | 5521 | Broadway St | Lancaster (V) | Existing | Residential Multiple Units | 104.83-5-25.1 | Repair | |
| 4 | 4/20/2026 13:00 | Final | CP0410145 | 1887 | Como Park Blvd | Lancaster (V) | Existing | Residential Single Unit | 115.11-1-7 | Repair | |
| 4 | 4/29/2026 14:00 | Final | CP0410147 | 30 | Vandenberg Ave | Lancaster (V) | Existing | Residential Single Unit | 104.16-7-7 | Repair | |
| 4 | 4/16/2026 14:00 | Final | CP0410144 | 22 | Washington St | Lancaster (V) | Existing | Residential Single Unit | 104.84-1-23 | Repair | |

DISTRICT 5

CONNECTIONS/PERMITS

| District | Insp Date | Approval | Permit | # | Street | Town | New/Existing | Property Type | SBL | Permit Type |
|----------|--------------------|----------|-----------|------|------------------|----------|--------------|-------------------------|-------------|-------------|
| 5 | 4/28/2026 11:00 | Final | CP0500677 | 5534 | Via Marina | Clarence | Existing | Residential Single Unit | 57.14-1-37 | Repair |
| 5 | 4/17/2026 11:00 | Final | CP0500519 | 6087 | Wellesley Cmn | Clarence | Existing | Residential Single Unit | 43.17-4-8.1 | Repair |

DISTRICT 5 CLARENCE TOWN DISTRICTS

| District | CTD | Insp Date | Permit | # | Street | Town | Permit Subtype | New/Existing | Property Type | SBL | Permit Type | Tap Type |
|----------|-----|-----------------|-----------|------|-------------------|----------|----------------|--------------|-------------------------|------------|-------------|----------|
| 5 | | 4/22/2026 10:30 | CP0504430 | 9756 | Longleaf Trail | Clarence | Clarence Iss | New | Residential Single Unit | 58.16-5-11 | Connection | Wye |
| 5 | 2 | 4/21/2026 11:00 | CP0504436 | 9494 | Deer Valley Dr | Clarence | Clarence Iss | New | Residential Single Unit | 44.11-5-3 | Connection | Wye |
| 5 | 2 | 4/22/2026 11:00 | CP0504434 | 9510 | Deer Valley Dr | Clarence | Clarence Iss | New | Residential Single Unit | 44.11-5-7 | Connection | Wye |
| 5 | 2 | 4/6/2026 11:00 | CP0504425 | 9514 | Deer Valley Dr | Clarence | Clarence Iss | New | Residential Single Unit | 44.11-5-8 | Connection | Wye |
| 5 | 2 | 4/22/2026 13:00 | CP0504435 | 9530 | Deer Valley Dr | Clarence | Clarence Iss | New | Residential Single Unit | 44.11-5-12 | Connection | Wye |
| 5 | 2 | 4/30/2026 11:00 | CP0504439 | 9572 | Deer Valley Dr | Clarence | Clarence Iss | New | Residential Single Unit | 44.11-5-17 | Connection | Wye |

| Location | Dist. | Description | Tank Capacity | Internal Tank Height | Gal/in | Date | Gen Hours | Gauge Level | Dip Level | Gallons Remaining | % Full | Gallons Needed | Gallons Added | Refill? | Refill Level |
|--------------------|-------|-----------------|---------------|----------------------|--------|--------|-----------|-------------|-----------|-------------------|--------|----------------|---------------|---------|--------------|
| Borden | 1 | Under Generator | 180 | 21 | 8.57 | 30-Apr | 2049 | | 18 | 154 | 86 | 26 | | - | 135 |
| Cayuga | 1 | Under Generator | 1300 | 33 | 39.39 | 30-Apr | 843 | | 30.5 | 1202 | 92 | 98 | | - | 975 |
| Clinton | 1 | Under Generator | 150 | 24 | 6.25 | 30-Apr | 1976 | | 21 | 131 | 88 | 19 | | - | 113 |
| Industrial Parkway | 1 | Under Generator | 700 | 30 | 23.33 | 30-Apr | | | 27.5 | 642 | 92 | 58 | | - | 525 |
| Union | 1 | Under Generator | 400 | 26 | 15.38 | 30-Apr | 163.3 | | 25.25 | 388 | 97 | 12 | | - | 300 |
| Aurora South | 4 | Under Generator | 285 | 21 | 13.57 | 30-Apr | 1821 | | 15.5 | 210 | 74 | 75 | | X | 214 |
| Bowmansville | 4 | Under Generator | 700 | 26 | 26.92 | 30-Apr | 981 | | | 619 | 88 | 81 | | - | 525 |
| Broadway | 4 | Above-Ground | 1000 | 36 | * | 30-Apr | 321 | | 23.5 | 518 | 52 | 482 | | X | 750 |
| Depew | 4 | Above-Ground | 3000 | 69 | * | 30-Apr | 516 | | 52 | 2277 | 76 | 723 | | - | 2250 |
| Iroquois | 4 | Under Generator | 295 | 17 | 17.35 | 30-Apr | 1116 | | 16.5 | 286 | 97 | 9 | | - | 221 |
| Vanderbilt | 4 | Above-Ground | 1000 | 36 | * | 30-Apr | 60.8 | | 33 | 518 | 52 | 482 | | X | 750 |
| Warner | 4 | Under Generator | 700 | 26 | 26.92 | 30-Apr | 1914 | | 23.5 | 633 | 90 | 67 | | - | 525 |
| Zoeller | 4 | Under Generator | 680 | 32 | 21.25 | 30-Apr | 18 | | 24 | 510 | 75 | 170 | | - | 510 |
| Bryant | 5 | Under Generator | 180 | 22 | 8.18 | 30-Apr | 698 | | 17.5 | 143 | 80 | 37 | | - | 135 |
| Pinebreeze | 5 | Under Generator | 275 | 44 | * | 30-Apr | 1328 | | 44 | 275 | 100 | 0 | | - | 206 |
| Stahley | 5 | Under Generator | 150 | 25 | 6.00 | 30-Apr | 1622 | | 23 | 138 | 92 | 12 | | - | 113 |
| Transit Valley | 5 | Above Ground | 275 | 44 | * | 30-Apr | 91 | | 40.5 | 259 | 94 | 16 | | - | 206 |

* Calculated

Refill at: 0.75

April 2026 Maintenance

District 1

Washed Cayuga wet well twice after high wet wells at station.

Washed Industrial Park wet well after high wet well at station.

Swapped pump #2 with spare at Borden.

Disassembled spare pump for Industrial Park.

Assisted collections with CCTV of inlet line at Union.

Mowed and weed whacked 3 different times.

Reset muffin monster at Cayuga.

Reset muffin monster at Industrial Park twice.

Cut back branches from fencing at Old Cayuga.

Verified return valve operation at Cayuga.

Adjusted Basin Level Sensors at Cayuga.

Replaced VFD 4 at IPP.

Installed reset on Empire cell modem.

District 4

Washed Bowmansville wet well after a high wet well.

Repaired plowing damage to lawns at remaining stations.

Pulled and cleaned pump #1 at Bowmansville 4 different times.

Pulled and cleaned pump #2 at Bowmansville 3 different times.

Picked up and installed new companion flanges on both spare pumps at Depew.

Serviced and prepped all lawn equipment for upcoming season.

Continued painting in control room at Depew.

Mowed and weed whacked 4 different times.

Calibrated Orf outfall meter at Depew.

Installed new junction box at Warner for transducer.

Replaced batteries on Bowmansville genset.

Finished soft start controls at Warner.

Finished running Conduit for AP's at base.

Replaced contactor on RCV motor at Depew.

Fixed repairs from DEC inspection at Base 4 fuel tanks and Depew ORF.

Replaced plug on Rover X.

District 5

Repaired plowing damage to lawns at all stations.

Swapped pump #2 with spare at Transit Valley.

Repaired Transfer Switch at Transit Valley.

All Districts

Checked all fluids on station generators.

Tested all HWW Floats.

PM'd all VFD's