

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
MAY 2026 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTALS	0	0	0
	0		

UFPO's	D1	D4	D5
Responses	293	428	145
Stakeouts	50	83	35
TOTAL STAKEOUTS	168		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	15,540	984	0	16,524

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint				0
By District	3,262	0	0	3,262

	D1	D4	D5	TOTALS
House Inspections				0
Reinspections				0
Violations				0
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
	0	0	0	0

Manhole Repairs	D1	D4	D5	TOTAL
	5	1	4	10

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control				0
Mechanical Root Cut	797	0	0	797
Mechanically Cleaned				0

Sewerline Repairs	D1 MS 5- 536 FRENCH SANITARY REPAIR - ERIE COUNTY WATER
sanitary sewer overflow	D1 MS 1 -BROADWAY (BB427) - VISIONE
	3270 CLINTON

CONSTRUCTION		
DIST #1	DIST #4	DIST #5
4814 TRANSIT	BRADLEY EXTENSION	HARRIS HILL MIXED USE SITE
2715 & 2725 CAR WASH -UNION	NEXTERA ENERGY TRANS.	7145 TRANSIT
SONWIL WAREHOUSE	ANGRY BUFFALO	6625 TRANSIT MIXED USE
UPSTATE NIAGARA 3300 N.AMERICA	4106 WALDEN WAREHOUSE	WOODLAND HILLS PH 3
395 WEST AVE.	VALVOLINE OIL CHANGE	JAMES RYAN PKWY
	4510 BROADWAY APARTMENTS	CREEKWOOD PUMP HOUSE
	5841 GENESSE SHOP	KRAUS RD. EXTENSION
	WOOD SPRING EXTENSION	5695 & 5731 TRANSIT
	3825 BOWTIE PARK	PEANUT LINE INTERCEPTOR
	NEXTERA ENERGY TRANS.	9388 TRANSIT SMOO TEA
	ALDEN GROW FACILITY	ERIE COUNTY HWY 5105 SALT
		9515 CLARENCE CENTER

PLAN REVIEWS	DISTRICT 1- GALAXY AUTO ADDITION
	DISTRICT 1- UPSTATE NIAGARA EXTENSION
	DISTRICT 4- 11580 WALDEN AVE SHERIFF GARAGE
	DISTRICT 4- 9 LANCASTER PARKWAY WAREHOUSE

COMPLAINT SUMMARY ECSD # 1 MAY 2026

Notification	DATE	Description	Prob. code text	Functional Loc.
10203547	05/01/2026	WATER STANDING IN STREET 148 HILLPINE RD	NO FURTHER WORK REQUIRED	E-S-N01-C-003-SL
10203630	05/07/2026	ODOR - 77 MAYBERRY DR E, CHEEKTOWAGA	ODOR	E-S-N01-C-006-SL
10203623	05/06/2026	SEWER BACKUP - 78 LOUISE DR, CHEEKTOWAGA	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-007-SL
10203692	05/20/2026	STANDING WATER YARD/FDTN 113 RONDELAY	HOMEOWNER'S PROBLEM	E-S-N01-C-007-SL
10203682	05/13/2026	SINKHOLE 1001 MINERAL SPRINGS RD	FOLLOW-UP REQUIRED	E-S-N01-C-010-SL
10203764	05/14/2026	SINKHOLE 1045 SENECA CREEK RD W SENECA	REFERRED TO OTHERS	E-S-N01-C-010-SL

COMPLAINT SUMMARY ECSD # 4 MAY 2026

10203762	05/14/2026	SINKHOLE 255 WARNER RD LANCASTER	REFERRED TO OTHERS	E-S-N04-C-003-SL
10203763	05/14/2026	SINKHOLE 231 WARNER RD LANCASTER	REFERRED TO OTHERS	E-S-N04-C-003-SL
10204531	05/26/2026	DISCHARGE - 6375 TRANSIT RD, DEPEW	REFERRED TO OTHERS	E-S-N04-C-004-SL
10203776	05/26/2026	TRASH BAG BLOCKING MAIN 70 MARKEY AVE	BASEMENT FACILITY	E-S-N04-C-005-SL
10203819	05/28/2026	SEWER BACK UP 462 CENTRAL AVE LANCASTER	HOMEOWNER'S PROBLEM	E-S-N04-C-005-SL
10203734	05/14/2026	BSMT TUB TOILET BCKUP 1287 PENORA ST	BASEMENT FACILITY	E-S-N04-C-008-SL
10203736	05/14/2026	SIDEWALK SINKING ON 1 SIDE 23 HAMPTON CT	FOLLOW-UP REQUIRED	E-S-N04-C-015-SL

COMPLAINT SUMMARY ECSD # 5 MAY 2026

10204526	05/22/2026	MH DAMAGED BY LOADER 10780 BODINE RD	OFFSET FRAME AND COVER	E-S-N05-C-009-MH
----------	------------	--------------------------------------	------------------------	------------------

MAY 2026 I&I DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE
10196285	05/12/2026	CONTRACT 96, SEWER REPAIR, BROADWAY	PIPE REPLACED - 10"	E-S-N01-C-001-SL	BB427
10204527	05/21/2026	SEWER REPAIR @ 536 FRENCH	PIPE REPLACED - 8"	E-S-N01-C-005-SL	558
10106604	05/19/2026	INSTALL CO @ 1257 MINERAL SPRINGS	PIPE REPLACED - 8"	E-S-N01-C-010-SL	10079847
10109497	05/18/2026	INSTALL WATER TIGHT @ 2001 UNION BACKLOT	RAISED MANHOLE(4)	E-S-N01-C-010-MH	BB0DB
10198771	05/04/2026	MANHOLE REPAIR @ FRENCH ROAD BACKLOT	REPAIRED CONE/BARREL JOINT LEAKS, MOD(4)	E-S-N01-C-008-MH	BAE17
10198770	05/04/2026	MANHOLE REPAIR @ FRENCH ROAD BACKLOT	REPAIRED CONE/BARREL JOINT LEAKS, MOD(4)	E-S-N01-C-008-MH	BAE16
10203657	05/12/2026	DYE TEST MANHOLE @ CLINTON / BROADWAY ST	REPAIRED CONE/BARREL JOINT LEAKS, SEV(5)	E-S-N01-C-009-MH	BB27B
10109497	05/18/2026	INSTALL WATER TIGHT @ 2001 UNION BACKLOT	REPLACED FRAME AND COVER(5)	E-S-N01-C-010-MH	BB0DB

MAY 2026 I&I DISTRICT # 4

10201587	05/15/2026	MANHOLE REPAIR @ WALDEN	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N04-C-008-MH	17A6DE
----------	------------	-------------------------	------------------------------------	------------------	--------

MAY 2026 I&I DISTRICT # 5

10203717	05/26/2026	RAISE 6" CO'S ON CLARNEW DR	MODIFIED	E-S-N05-C-005-SL	
10121937	05/28/2026	MANHOLE REPAIR @ 8235 MILES	RAISED MANHOLE(4)	E-S-N05-C-002-MH	C09F7
10203754	05/29/2026	MANHOLE REPAIR @ COUNTY RD BACKLOT	RAISED MANHOLE(4)	E-S-N05-C-001-MH	C0726
10203754	05/29/2026	MANHOLE REPAIR @ COUNTY RD BACKLOT	REPLACED FRAME AND COVER(5)	E-S-N05-C-001-MH	C0726
10203576	05/06/2026	MANHOLE REPAIR @ 5017 TRANSIT	REPLACED FRAME AND COVER(5)	E-S-N05-C-007-MH	C0901

2026 MAY MECHANICAL ROOTCUT DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10203557	05/04/2026	TELEWISE JOHN BRIAN 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-007-SL	BBE6F	397
10203546	05/01/2026	TELEWISE JOHN BRIAN 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-007-SL	BBE70	400

2026 MAY MECHANICAL ROOTCUT DISTRICT # 4

NONE

2026 MAY MECHANICAL ROOTCUT DISTRICT # 5

NONE

2026 MAY TELEVISION DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10203628	05/11/2026	TELEVISION BROADWAY (VISION REPAIR)	TELEVISION - (D)	E-S-N01-C-001-SL	BB427	371
10196631	05/11/2026	TELEVISION JEROME 8" ACP	TELEVISION - (D)	E-S-N01-C-002-SL	BBA8F	60
10203671	05/08/2026	TELEVISION FRENCH 8" VTP	TELEVISION - (D)	E-S-N01-C-005-SL	732	117
10203673	05/07/2026	TELEVISION FRENCH 8" VTP	TELEVISION - (D)	E-S-N01-C-005-SL	497	50
10203674	05/08/2026	TELEVISION CASTLEWOOD 8" VTP	TELEVISION - (D)	E-S-N01-C-005-SL	10081530	30
10203675	05/08/2026	TELEVISION CASTLEWOOD 8" VTP	TELEVISION - (D)	E-S-N01-C-005-SL	10081531	18
10203650	05/11/2026	TELEVISION FRENCH 10" VTP	TELEVISION - (D)	E-S-N01-C-006-SL	BBF55	59
10203629	05/11/2026	TELEVISION FRENCH 10" VTP	TELEVISION - (D)	E-S-N01-C-006-SL	BBF78	327
10203597	05/07/2026	TELEVISION LOUISE 8" LINED	TELEVISION - (D)	E-S-N01-C-007-SL	BBF9E	346
10203558	05/05/2026	TELEVISION JOHN BRIAN 8" VTP	TELEVISION - (D)	E-S-N01-C-007-SL	BBE6B	195
10203557	05/04/2026	TELEVISION JOHN BRIAN 8" VTP	TELEVISION - (D)	E-S-N01-C-007-SL	BBE6F	397
10203546	05/01/2026	TELEVISION JOHN BRIAN 8" VTP	TELEVISION - (D)	E-S-N01-C-007-SL	BBE70	400
10203676	05/13/2026	TELEVISION TRANSIT 10" VTP	TELEVISION - (D)	E-S-N01-C-007-SL	BBA16	345
10203678	05/13/2026	TELEVISION FRENCH XING 15" VTP	TELEVISION - (D)	E-S-N01-C-007-SL	BBCF3	77
10203679	05/07/2026	TELEVISION FRENCH 10" ACP	TELEVISION - (D)	E-S-N01-C-007-SL	BBD0C	239
10203677	05/08/2026	TELEVISION FRENCH 8" VTP	TELEVISION - (D)	E-S-N01-C-007-SL	141C70	231

2026 MAY TELEVISION DISTRICT # 4

NONE

2026 MAY TELEVISION DISTRICT # 5

NONE

2026 May UFPO Numbers

(By District/Region)

Total UFPO Tickets:	2806
Tickets Outside ECSD Boundary	325

	Total Tickets	APR Code		Other APR Codes	Total %	Stakeout %
		10 - All Clear	30 - Staked Out	31		
District 1	293	243	50		10%	9%
District 4	428	346	83		15%	15%
District 5	145	110	35		5%	6%
Total NR	866	699	168		31%	31%

District 3	1017	886	131		36%	24%
District 6	248	102	146		9%	27%
District 8	133	122	11		5%	2%
Total CR	1398	1110	288		50%	53%

District 2	217	130	87		8%	16%
Total SR	217	130	87		8%	16%

Totals:	2481	1939	543	
---------	------	------	-----	--

ERIE COUNTY - SEWER DISTRICT 1,4,5
5/1/2026 TO 5/31/2026
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	7	9	16
Taps	0	1	0	1
Disconnect	0	0	0	0
Repair	4	9	1	14
TOTAL	4	17	10	31

CONNECTIONS	D5	TOTAL
New Commercial	0	1
Exist Commercial	0	0
New Residential	9	16
Exist Residential	0	0
TOTAL	9	17

PERMITS	D5	TOTAL
New Commercial	0	2
Exist Commercial	0	2
New Residential	1	5
Exist Residential	2	15
TOTAL	3	24

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$0	\$2,404	\$0	\$2,404
Exist Commercial Fees (EC)	\$2	\$2	\$0	\$4
New Residential Fees (NR)	\$0	\$8	\$2	\$10
Exist Residential Fees (ER)	\$6	\$20	\$4	\$30
TOTAL	\$8	\$2,434	\$6	\$2,448

May Monthly
Report!

2005 PS Flows

Month:	MAY 2026		NR Flow Summary 2026			
Station	SD	Total	Daily Avg	GPM	GPH	Tot Gal
		Hrs				
Borden-Clinton	1	403	13.0	200	12000	4,831,200
Cayuga	1	830	26.8	1190	71400	40,183,920
Clint-Tran	1	165	5.3	350	21000	3,473,400
Industrial Park	1	316	10.2	3650	219000	70,088,760
Union	1	60	1.9	850	51000	3,080,400
Woodlands	1	34	1.1	39	2340	79,560
Aurora South	4	47	1.5	705	42300	1,979,640
Bowmansville	4	616	19.9	1600	96000	59,136,000
Broadway	4	8	0.3	16000	960000	7,680,000
Depew	4	687	22.2	11000	660000	283,800,000
Forestream	4	60	1.9	1050	63000	3,792,600
Hall	4	120	3.9	130	7800	935,220
Haskell	4	46	1.5	590	35400	1,621,320
Iroquois	4	615	19.9	3000	180000	110,772,000
Pleasantview	4	178	5.7	950	57000	10,151,700
Vanderbilt	4	20	0.6	8000	480000	9,600,000
Warner	4	572	18.5	5000	300000	171,600,000
Zoeller	4	232	7.5	830	49800	11,538,660
Bryant	5	155	5.0	600	36000	5,590,800
Eastern Hills	5	166	5.4	625	37500	6,221,250
Forestview	5	30	1.0	554	33240	993,876
Cannonwoods	5	4	0.1	173	10380	43,596
Creekwood	5	61	2.0	509	30540	1,878,210
Pinebreeze	5	64	2.1	325	19500	1,246,050
Stahley	5	103	3.3	720	43200	4,466,880
Transit Valley	5	170	5.5	450	27000	4,590,000
Total NR Flow:					819,375,042	

DISTRICT 1

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
1	5/14/2026 14:00	Final	CP0101746	52	Birchwood Dr	Cheektowaga	Existing	Residential Single Unit	125.07-10-14	Repair
1	5/6/2026 13:00	Final	CP0107033	22	Louise Dr	Cheektowaga	Existing	Residential Single Unit	125.10-19-5	Repair
1	5/28/2026 8:00	Final	CP0111948	1540	Seneca Crk Rd	West Seneca	Existing	Non-Residential Multiple Units	126.17-2-22.1	Repair
1	5/18/2026 13:00	Cancelled	CP0109183	198	Tim Tam Ter	West Seneca	Existing	Residential Single Unit	125.14-3-45	Repair
1	5/20/2026 14:00	Final	CP0109183	198	Tim Tam Ter	West Seneca	Existing	Residential Single Unit	125.14-3-45	Repair
1	5/18/2026 8:00		CP0111952	2852	Transit Rd	West Seneca	Existing	Residential Multiple Units	136.09-1-33.1	Connection
1	5/18/2026 8:30		CP0111953	2852	Transit Rd	West Seneca	New	Residential Multiple Units	136.09-1-33.1	Connection
1	5/18/2026 9:00		CP0111954	2852	Transit Rd	West Seneca	New	Residential Multiple Units	136.09-1-33.1	Connection
1	5/18/2026 9:30		CP0111955	2852	Transit Rd	West Seneca	New	Residential Multiple Units	136.09-1-33.1	Connection
1	5/18/2026 10:00		CP0111956	2852	Transit Rd	West Seneca	New	Residential Multiple Units	136.09-1-33.1	Connection

DISTRICT 4

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type	Tap Type
4	5/21/2026 14:00	Final	CP0410153	91	Susan Dr	Depew/Chktg	Existing	Residential Single Unit	92.20-7-37	Repair	
4	5/14/2026 11:00	Final	CP0410132	159	Penora St	Depew/Lanc	Existing	Residential Multiple Units	115.06-2-22	Repair	
4	5/13/2026 13:00		CP0410132	159	Penora St	Depew/Lanc	Existing	Residential Multiple Units	115.06-2-22	Repair	
4	5/8/2026 14:00	Final	CP0410149	5963	Transit Rd	Depew/Lanc	Existing	Residential Multiple Units	104.22-1-27	Repair	
4	5/4/2026 14:00	Final	CP0410041	13	Juliette Dr	Lancaster	New	Residential Single Unit	82.15-1-14	Connection	Wye
4	5/11/2026 13:00	Final	CP0410121	13	Fieldstream Ln	Lancaster (T)	New	Residential Single Unit	116.15-1-7	Connection	Wye
4	5/22/2026 13:00	Final	CP0410056	22	Fieldstream Ln	Lancaster (T)	New	Residential Single Unit	116.15-1-36	Connection	Wye

4	5/8/2026 13:00	Final	CP0410052	37	Fieldstream Ln	Lancaster (T)	New	Residential Single Unit	116.15-1-19	Connection	Wye
4	5/12/2026 13:30	Final	CP0410053	7	Fieldstream Ln	Lancaster (T)	New	Residential Single Unit	116.15-1-4	Connection	Wye
4	5/21/2026 13:00	Final	CP0410020	9	Fieldstream Ln	Lancaster (T)	New	Residential Single Unit	116.15-1-5	Connection	Wye
4	5/5/2026 12:30	Final	CP0410040	1	Juliette Dr	Lancaster (T)	New	Residential Single Unit	82.15-1-20	Connection	Wye
4	5/14/2026 13:00	Final	CP0403949	3	Petersbrook Cir	Lancaster (T)	Existing	Residential Single Unit	126.06-2-16	Repair	
4	5/6/2026 14:00	Final	CP0402385	38	Stream View Ln	Lancaster (T)	Existing	Residential Single Unit	126.10-5-40	Repair	
4	5/5/2026 11:00	Final	CP0409819	50	Ward Rd Como Park	Lancaster (T)	New	Non-Residential Single Unit	95.00-4-39	Connection	Tap
4	5/5/2026 13:30	Cancelled	CP0410148	2099	Blvd Como Park	Lancaster (V)	Existing	Residential Single Unit	115.12-2-1	Repair	
4	5/6/2026 11:00	Final	CP0410148	2099	Blvd	Lancaster (V)	Existing	Residential Single Unit	115.12-2-1	Repair	
4	5/27/2026 13:00	Final	CP0410151	65	Garfield St	Lancaster (V)	Existing	Residential Single Unit	104.81-1-9	Repair	
4	5/19/2026 11:30	Final	CP0410152	36	School St Southwest	Lancaster (V)	Existing	Residential Multiple Units	104.75-6-12	Repair	
4	5/20/2026 13:00	Final	CP0410150	111	Pkwy	Lancaster (V)	Existing	Residential Single Unit	115.11-24-10	Repair	

DISTRICT 5

CONNECTIONS/PERMITS

District	CTD	Insp Date	Permit	#	Street	Town	Permit Subtype	New/Existing	Property Type	SBL	Permit Type	Tap Type	Comments
5	2	5/15/2026 11:00	CP0504440	9502	Deer Valley Dr	Clarence	Iss Clarence	New	Residential Single Unit	44.11-5-5	Connection	Wye	Clarence issued. DSM inspect
5	2	5/18/2026 11:00	CP0504454	9522	Deer Valley Dr	Clarence	Iss Clarence	New	Residential Single Unit	44.11-15-10	Connection	Wye	Clarence issued. DSM inspect
5	2	5/1/2026 11:00	CP0504437	9537	Deer Valley Dr	Clarence	Iss Clarence	New	Residential Single Unit	44.11-5-22	Connection	Wye	Clarence issued. DSM inspect
5	2	5/1/2026 13:00	CP0504432	5658	Dorothy Cir	Clarence	Iss Clarence	New	Residential Single Unit	58.10-5-4	Connection	Wye	DSM to Inspect
5	4	5/12/2026 11:00	CP0504433	9768	Longleaf Trl	Clarence	Iss Clarence	New	Residential Single Unit	58.16-5-14	Connection	Wye	Clarence issued. DSM inspect
5	4	5/29/2026 13:00	CP0504466	9771	Longleaf Trl	Clarence	Iss Clarence	New	Residential Single Unit	58.16-5-5	Connection	Wye	Clarence issued. DSM inspect
5	4	5/21/2026 11:00	CP0504392	5550	Serenity Ct Spaulding Green	Clarence	Iss Clarence	New	Residential Single Unit	58.15-10-6	Connection	Wye	Clarence issued. DSM inspect
5	4	5/27/2026 14:00	CP0504403	9644	Pkwy	Clarence	Iss Clarence	New	Residential Single Unit	58.15-11-13	Connection	Wye	Clarence issued DSM inspect
5	10	5/28/2026 11:00	CP0504450	5171	Kandefer's trl	Clarence	Iss	New	Residential Single Unit	57.19-7-5	Connection	Wye	Clarence issued. DSM inspect

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	29-May	2054		17	146	81	34		-	135
Cayuga	1	Under Generator	1300	33	39.39	29-May	844.1		29.75	1172	90	128		-	975
Clinton	1	Under Generator	150	24	6.25	29-May	1980.5		21.5	134	90	16		-	113
Industrial Parkway	1	Under Generator	700	30	23.33	29-May	714.2		26	607	87	93		-	525
Union	1	Under Generator	400	26	15.38	29-May	167.1		24.5	377	94	23		-	300
Aurora South	4	Under Generator	285	21	13.57	29-May	1826		17.25	234	82	51		-	214
Bowmansville	4	Under Generator	700	26	26.92	29-May	984		22.75	613	88	88		-	525
Broadway	4	Above-Ground	1000	36	*	29-May	321		34	821	82	179		-	750
Depew	4	Above-Ground	3000	69	*	29-May	518		51	2230	74	770		X	2250
Iroquois	4	Under Generator	295	17	17.35	29-May	1116.8		16	278	94	17		-	221
Vanderbilt	4	Above-Ground	1000	36	*	29-May	161.3		32.5	821	82	179		-	750
Warner	4	Under Generator	700	26	26.92	29-May	1915		24.5	660	94	40		-	525
Zoeller	4	Under Generator	680	32	21.25	29-May	18.7		24	510	75	170		-	510
Bryant	5	Under Generator	180	22	8.18	29-May	699.1		17.5	143	80	37		-	135
Pinebreeze	5	Under Generator	275	44	*	29-May	1328.5		43.5	272	99	3		-	206
Stahley	5	Under Generator	150	25	6.00	29-May	1626		24	144	96	6		-	113
Transit Valley	5	Above Ground	275	44	*	29-May	94.4		39.5	253	92	22		-	206

* Calculated

Refill at: 0.75

May 2026 Maintenance

District 1

Mowed and weed whacked 5 different times.
Pruned tree branches at Mineral Springs and Industrial Park.
Replaced love joy in hydraulic motor on muffin monster #2 at Cayuga.
Pulled and cleaned pump #1 at Woodlands.
Replaced block heater breaker at Cayuga.
Installed a remote reset for cell modem at Empire Drive.
Installed new transducer at Cayuga.

District 4

Mowed and weed whacked 5 different times.
Cut branches away from fencing at Depew station.
Worked on painting Depew interior 3 different times.
Topped off fuel on portable pump at Depew ORF.
Washed Bowmansville wet well floor and walls after a high wet well.
Pulled and cleaned pump #1 at Bowmansville 4 different times.
Pulled and cleaned pump #2 at Bowmansville 3 different times.
Replaced cracked fuel line on portable pump #3 at Depew ORF.
Repaired ramp on lawn trailer.
Replaced drinking fountain at NR base.
Unclogged seal water line on pump #1 at Pleasantview.
Repaired NR base radio.
Replaced thermostats on Depew generator block heaters.
Replaced broken lights at Warner.
Installed new IP speaker at NR base.
Reset HMI at Vanderbilt.

District 5

Delivered new and old spare pumps to Transit Valley.

All Districts

Checked all fluids in station generators.
Took hydraulic oil samples from station muffin monsters and sent to lab for analysis.

ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
JUNE 2026 MONTHLY OPERATION REPORT

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTALS	0	0	0
		0	

UFPO's	D1	D4	D5
Responses	354	439	193
Stakeouts	73	84	40
TOTAL STAKEOUTS	197		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	4,318	496	408	5,222

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint				0
By District	862	316	0	1,178

	D1	D4	D5	TOTALS
House Inspections				0
Reinspections				0
Violations				0
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
	0	0	0	0

Manhole Repairs	D1	D4	D5	TOTAL
	3	3	1	7

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control	0	0	0	0
Mechanical Root Cut	350	0	0	350
Mechanically Cleaned	0	0	0	0

Sewerline Repairs	D1 MS 11- SENECA CREEK - 10084094/10084095 (VISONE) CONTRACT 48
	D 1MS 11- SENECA CREEK BC3A6- PIPE PATCH
	D1 MS 12 - CASIMER - 14F094
SSO	

NONE

CONSTRUCTION		
DIST #1	DIST #4	DIST #5
4814 TRANSIT	BRADLEY EXTENSION	HARRIS HILL MIXED USE SITE
2715 & 2725 CAR WASH -UNION	NEXTERA ENERGY TRANS.	7145 TRANSIT
SONWIL WAREHOUSE	ANGRY BUFFALO	6625 TRANSIT MIXED USE
STATE NIAGARA 3300 SWR EXTENSION	4106 WALDEN WAREHOUSE	WOODLAND HILLS PH 3
395 WEST AVE.	4400 WALDEN SEALING DEVICES	JAMES RYAN PKWY
2350 UNION - GALAXY AUTO	WEHRLE/ MAPLE EXTENSION	CREEKWOOD PUMP HOUSE
3425 BROADWAY- VALLEY TIRE	5841 GENESSE SHOP	KRAUS RD. EXTENSION
	WOOD SPRING EXTENSION	5695 & 5731 TRANSIT
	3825 BOWTIE PARK	PEANUT LINE INTERCEPTOR
	NEXTERA ENERGY TRANS.	9388 TRANSIT SMOO TEA
	ALDEN GROW FACILITY	ERIE COUNTY HWY 5105 SALT
	11580 WALDEN SHERRIFF BLDG	9515 CLARENCE CENTER
PLAN REVIEWS	DISTRICT 1- VALLEY TIRE 3425 BROADWAY	
	DISTRICT 4- MAPLE / WEHRLE EXTENSION	

COMPLAINT SUMMARY ECSD # 1 JUNE 2026

Notification	DATE	Description	Prob. code text	Functional Loc.
10204877	06/14/2026	SEWER BACKUP - 131 N SEINE DR, BUFFALO	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-005-SL
10204918	06/16/2026	SEWER BACK UP - 48 E TOULON DR CHEEKTOWA	HOMEOWNER'S PROBLEM	E-S-N01-C-005-SL
10204686	06/06/2026	MANHOLE COVER MISSING - 631 FRENCH RD, C	MISSING	E-S-N01-C-007-MH
10204865	06/17/2026	SEWER BACK UP 66 LOUISE DR CHEEKTOWAGA	HOMEOWNER'S PROBLEM	E-S-N01-C-007-SL
10204917	06/16/2026	SEWER BACK UP - 57 BIRCHWOOD DR CHEEKTOW	BASEMENT FACILITY	E-S-N01-C-007-SL
10204944	06/18/2026	SEWER BACK UP 998 SENECA CRK RD	HOMEOWNER'S PROBLEM	E-S-N01-C-010-SL
10204945	06/18/2026	BAD SEWER SMELL IN HOUSE 1010 SENECA CRK	NO FURTHER WORK REQUIRED	E-S-N01-C-010-SL

COMPLAINT SUMMARY ECSD # 4 JUNE 2026

10204900	06/14/2026	SINK HOLE - COMO PARK RD/MILLER LANCASTE	REFERRED TO OTHERS	E-S-N04-C
10204596	06/03/2026	SIDEWALK/DRIVEWAY SINKING 14 LUCIA CT	HOMEOWNER'S PROBLEM	E-S-N04-C-003-SL

COMPLAINT SUMMARY ECSD # 5 JUNE 2026

10205765	06/29/2026	MH CLANKING LOUD 5070-5080 SALT RD	PUT ON LIST TO REPAIR	E-S-N05-C-009-MH
10204634	06/04/2026	MANHOLE ISSUE 5070-5080 SALT RD CLARENCE	PUT ON LIST TO REPAIR	E-S-N05-C-009-SL

JUNE 2026 I&I DISTRICT 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE
10205680	06/22/2026	INSTALL CLEANOUT @ 928 BORDEN	MODIFIED	E-S-N01-C-004-MH	10083979
10205681	06/22/2026	INSTALL CLEANOUT @ 544 BORDEN	MODIFIED	E-S-N01-C-007-MH	107C05
10204667	06/08/2026	MANHOLE REPAIR@ 631 FRENCH RD	REPLACED FRAME AND COVER(5)	E-S-N01-C-007-MH	BB2B0
10204591	06/02/2026	PIPE PATCH @ SENECA CREEK	PIPE PATCH - CROSS CONNECTION	E-S-N01-C-011-SL	BC3A6
10205887	06/12/2026	D1 CONTR.48 SENECA CREEK 10" SEWER	PIPE REPLACED - 10"	E-S-N01-C-011-SL	10084094
10205888	06/12/2026	D1 CONTR.48 SENECA CREEK 8"SEWER	PIPE REPLACED - 8"	E-S-N01-C-011-SL	10084095
10204728	06/10/2026	SEWER REPAIR @ CASIMER	REPAIRED	E-S-N01-C-012-SL	14F094

JUNE 2026 I&I DISTRICT 4

10205732	06/29/2026	MANHOLE REPAIR @ 398 STONY RD	REPAIRED FRAME JOINT LEAKS, SEV(5)	E-S-N04-C-002-MH	DE7ED
10187354	06/17/2026	MANHOLE REPAIR @ SENECA PLACE	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N04-C-005-MH	EAC19
10204566	06/17/2026	MANHOLE REPAIR @ JUNIPER BLVD	REPAIRED FRAME JOINT LEAKS, MOD(4)	E-S-N04-C-006-MH	1ABAE7

JUNE 2026 I&I DISTRICT 5

10124525	06/03/2026	MANHOLE REPAIR @ 8050 COUNTY BACKLOT	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N05-C-001-MH	C071B
----------	------------	--------------------------------------	------------------------------------	------------------	-------

2026 JUNE MECHANICAL ROOTCUT DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10204901	06/18/2026	TELEWISE N. SEINE 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-005-SL	BBD46	350

2026 JUNE MECHANICAL ROOTCUT DISTRICT # 4

NONE

2026 JUNE MECHANICAL ROOTCUT DISTRICT #5

NONE

2026 JUNE TELEVISION DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10204902	06/18/2026	TELEVISION N. SEINE 8" CIPP/VTP	TELEVISIONED - (D)	E-S-N01-C-005-SL	BBD47	356
10204901	06/18/2026	TELEVISION N. SEINE 8" VTP	TELEVISIONED - (D)	E-S-N01-C-005-SL	BBD46	350
10203672	06/22/2026	TELEVISION FRENCH 8" VTP	TELEVISIONED - (D)	E-S-N01-C-005-SL	558	156

2026 JUNE TELEVISION DISTRICT # 4

10203713	06/22/2026	TELEVISION 8" PVC @ 23 HAMPTON CT	TELEVISIONED - (D)	E-S-N04-C-015-SL	DFA6D	316
----------	------------	-----------------------------------	--------------------	------------------	-------	-----

2026 JUNE TELEVISION DISTRICT # 5

NONE

2026 June UFPO Numbers

(By District/Region)

Total UFPO Tickets:	3186
Tickets Outside ECSD Boundary	361

	Total Tickets	APR Code		Other APR Codes	Total %
		10 - All Clear	30 - Staked Out	31	
District 1	354	281	73		11%
District 4	439	355	84		14%
District 5	193	153	40		6%
Total NR	986	789	197		31%

District 3	1080	899	181		34%
District 6	303	141	162		10%
District 8	140	128	12		4%
Total CR	1523	1168	355		48%

District 2	316	209	107		10%
Total SR	316	209	107		10%

Totals:	2825	2166	659		
---------	------	------	-----	--	--

ERIE COUNTY - SEWER DISTRICT 1,4,5
6/1/2026 TO 6/30/2026
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	3	6	9
Taps	0	0	0	0
Disconnect	0	0	0	0
Repair	7	10	2	19
TOTAL	7	13	8	28

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	1	0	1
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	0	2	6	8
Exist Residential (ER)	0	0	0	0
TOTAL	0	3	6	9

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	0	0	0
Exist Commercial Issued (EC)	0	0	0	0
New Residential Issued (NR)	1	3	0	4
Exist Residential Issued (ER)	9	13	2	24
TOTAL	10	16	2	28

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$0	\$0	\$0	\$0
Exist Commercial Fees (EC)	\$0	\$0	\$0	\$0
New Residential Fees(NR)	\$2	\$706	\$0	\$708
Exist Residential Fees (ER)	\$18	\$26	\$4	\$48
TOTAL	\$20	\$732	\$4	\$756

2005 PS Flows

Month:	JUNE 2026		NR Flow Summary 2026			
Station	SD	Total	Daily Avg	GPM	GPH	Tot Gal
		Hrs				
Borden-Clinton	1	158	5.1	200	12000	1,892,400
Cayuga	1	430	13.9	1190	71400	24,033,240
Clint-Tran	1	125	4.0	350	21000	2,633,400
Industrial Park	1	265	8.5	3650	219000	47,155,080
Union	1	54	1.7	850	51000	2,748,900
Woodlands	1	41	1.3	39	2340	95,238
Aurora South	4	42	1.4	705	42300	1,780,830
Bowmansville	4	500	16.1	1600	96000	48,000,000
Broadway	4	8	0.3	16000	960000	7,680,000
Depew	4	833	26.9	11000	660000	348,975,000
Forestream	4	55	1.8	1050	63000	3,471,300
Hall	4	69	2.2	130	7800	541,320
Haskell	4	30	1.0	590	35400	1,047,840
Iroquois	4	580	18.7	3000	180000	104,346,000
Pleasantview	4	154	5.0	950	57000	8,783,700
Vanderbilt	4	10	0.3	8000	480000	4,800,000
Warner	4	511	16.5	5000	300000	153,300,000
Zoeller	4	217	7.0	830	49800	10,811,580
Bryant	5	147	4.7	600	36000	5,295,600
Eastern Hills	5	155	5.0	625	37500	5,801,250
Forestview	5	26	0.8	554	33240	864,240
Cannonwoods	5	5	0.2	173	10380	50,862
Creekwood	5	56	1.8	509	30540	1,710,240
Pinebreeze	5	62	2.0	325	19500	1,201,200
Stahley	5	102	3.3	720	43200	4,384,800
Transit Valley	5	115	3.7	450	27000	3,107,700
Total NR Flow:						794,511,720

DISTRICT 1

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
1	6/4/2026		CP010677			Cheektowag		Residential Single		
1	13:00	Final	1	136	Le Havre Dr	a	Existing	Unit	125.06-1-35	Repair
1	6/4/2026		CP010690			Cheektowag		Residential Single		
1	14:30	Final	6	71	Lille Ln	a	Existing	Unit	125.06-15-45	Repair
1	6/2/2026		CP010449			Cheektowag		Residential Single		
1	14:00	Final	2	87	Marywood Dr	a	Existing	Unit	114.07-6-2	Repair
1	6/16/2026		CP011000			Cheektowag		Residential Single		
1	13:30	Final	7	173	N Seine Dr	a	Existing	Unit	125.06-11-3	Repair
1	6/12/2026		CP011094			Cheektowag		Residential Single		
1	13:00	Final	0	228	Towers Blvd	a	Existing	Unit	114.18-2-17	Repair
1	6/26/2026	NOT	CP011198					Residential Single		
1	11:00	INSPECTED	2	45	Electric Ave	West Seneca	Existing	Unit	123.43-3-20	Repair
1	6/17/2026		CP010899	147	Seneca Crk			Residential Single		
1	11:30	Final	7	5	Rd	West Seneca	Existing	Unit	126.17-2-13.1	Repair
1	6/30/2026		CP011198		Woodbine			Residential Single		
1	13:30	Final	3	86	Ave	West Seneca	Existing	Unit	124.20-5-19	Repair

DISTRICT 4

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type	Tap Type
4	6/4/2026		CP040979	637		Cheektowaga		Non-Residential Single	93.01-1-		
4	11:00	Final	0	4	Transit Rd	(OOD)	Existing	Unit	33.112	Repair	
4	6/24/2026		CP041016								
4	13:00	Final	0	34	Bostwick Pl	Depew/Chktg	Existing	Residential Single Unit	104.09-3-15	Repair	
4	6/29/2026		CP041016								
4	14:00	Final	4	65	Cornell Dr	Depew/Chktg	Existing	Residential Single Unit	103.08-6-16	Repair	
4	6/30/2026		CP041016								
4	13:00	Final	2	10	Fairview Dr	Depew/Chktg	Existing	Residential Single Unit	93.17-12-25	Repair	
4	6/25/2026		CP041016								
4	14:00		1	131	Lee St	Depew/Chktg	Existing	Residential Single Unit	93.13-9-43	Repair	

	6/22/2026		CP040897								
4	9:00	Final	1	79	Lewan Dr	Depew/Chktg	Existing	Residential Single Unit	92.20-14-7	Repair	
	6/15/2026		CP040604								
4	13:30	Final	4	136	Colony St	Depew/Lanc	Existing	Residential Single Unit	93.18-4-32	Repair	
	6/18/2026		CP040135	360							
4	13:30	Final	5	9	Bowen Rd	Lancaster (T)	Existing	Residential Single Unit	127.06-2-14	Repair	
	6/25/2026		CP041003		Fieldstream					Connectio	
4	13:00	Final	0	25	Ln	Lancaster (T)	New	Residential Single Unit	116.15-1-13	n	Wye
	6/26/2026		CP041005		Fieldstream					Connectio	
4	14:00	Final	7	3	Ln	Lancaster (T)	New	Residential Single Unit	116.15-1-2	n	Wye
	6/9/2026		CP040291		Steinfeldt				116.05-3-		
4	14:00	Final	1	73	Rd	Lancaster (T)	Existing	Residential Single Unit	16.1	Repair	
	6/11/2026		CP041015	275				Non-Residential Multiple	82.03-2-	Connectio	
4	11:00	Final	5	3	Wehrle Dr	Lancaster (T)	New	Units	3.11	n	Wye
	6/11/2026		CP041015								
4	13:00	Final	7	65	4th Ave	Lancaster (V)	Existing	Residential Single Unit	115.11-8-20	Repair	
	6/4/2026		CP041015								
4	10:00	Final	6	117	6th Ave	Lancaster (V)	Existing	Residential Single Unit	115.11-10-5	Repair	

DISTRICT 5

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
	6/2/2026				Fairlane			Residential Single	44.19-3-	
5	11:00	Final	CP0504465	6035	Dr	Clarence	Existing	Unit	13	Repair
	6/26/2026				Jennifer			Residential Single	44.09-2-	
5	13:00	Final	CP0504474	6335	Ct	Clarence	Existing	Unit	15	Repair

DISTRICT 5 CLARENCE TOWN DISTRICTS

District	CTD	Insp Date	Permit	#	Street	Town	Permit Subtype	New/Existing	Property Type	SBL	Permit Type	Tap Type	Comments
5	2	6/12/2026 10:00	CP0504456	9498	Deer Valley Dr	Clarence	Iss	New	Residential Single Unit	44.11-5-4	Connection	Wye	Clarence issued. DSM inspected.
5	2	6/15/2026 11:00	CP0504445	9501	Deer Valley Dr	Clarence	Iss	New	Residential Single Unit	44.11-5-26	Connection	Wye	Clarence issued. DSM inspected.
5	2	6/2/2026 10:00	CP0504455	9529	Deer Valley Dr	Clarence	Iss	New	Residential Single Unit	44.11-5-24	Connection	Wye	Clarence issued. DSM inspected.
5	10	6/16/2026 13:00	CP0504448	5172	Kandefer's Trl	Clarence	Iss	New	Residential Single Unit	57.19-7-17	Connection	Wye	Clarence issued. DSM inspected.

5	10	6/9/2026 13:00	CP0504453	5181	Kandefer's Trl	Clarence	Clarence Iss	New	Residential Single Unit	57.19-7- 4	Connection	Wye	Clarence issued. DSM inspected.
5	10	6/10/2026 13:00	CP0504452	5191	Kandefer's Trl	Clarence	Clarence Iss	New	Residential Single Unit	57.19-7- 3	Connection	Wye	Clarence issued. DSM inspected.

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	30-Jun	2059		16	137	76	43		-	135
Cayuga	1	Under Generator	1300	33	39.39	30-Jun	844.3		29.75	1172	90	128		-	975
Clinton	1	Under Generator	150	24	6.25	30-Jun	1985.8		19.5	122	81	28		-	113
Industrial Parkway	1	Under Generator	700	30	23.33	30-Jun	714.7		27.75	648	93	53		-	525
Union	1	Under Generator	400	26	15.38	30-Jun	172.8		24	369	92	31		-	300
Aurora South	4	Under Generator	285	21	13.57	30-Jun	1830		17.5	238	83	48		-	214
Bowmansville	4	Under Generator	700	26	26.92	30-Jun	9880		22.5	606	87	94		-	525
Broadway	4	Above-Ground	1000	36	*	30-Jun	321		32	770	77	230		-	750
Depew	4	Above-Ground	3000	69	*	30-Jun	522		50.5	2182	73	818		X	2250
Iroquois	4	Under Generator	295	17	17.35	30-Jun	1116.7		15.5	269	91	26		-	221
Vanderbilt	4	Above-Ground	1000	36	*	30-Jun	161.3		33	770	77	230		-	750
Warner	4	Under Generator	700	26	26.92	30-Jun	1915		23	619	88	81		-	525
Zoeller	4	Under Generator	680	32	21.25	30-Jun	18.7		25.75	547	80	133		-	510
Bryant	5	Under Generator	180	22	8.18	30-Jun	699.1		17.5	143	80	37		-	135
Pinebreeze	5	Under Generator	275	44	*	30-Jun	1328.5		43.5	272	99	3		-	206
Stahley	5	Under Generator	150	25	6.00	30-Jun	1631		21.5	129	86	21		-	113
Transit Valley	5	Above Ground	275	44	*	30-Jun	98.2		39	253	92	22		-	206

* Calculated

Refill at: 0.75

June 2026 Maintenance

District 1

Mowed and weed whacked 8 different times.

Set up bypass pump at Borden, the bypass pumped the station twice while new vfd's were installed.

Pulled and cleaned pump #2 at Woodlands.

Returned pump and hoses from Borden to base.

Cleaned and restocked bathrooms at Industrial Park and Cayuga.

Drilled new holes in Cayuga Wet Well for transducers and replaced the current transducer with new one.

Installed new pump controller and vfd' s at Borden pump station.

Powered Up Spare Vfd' s at Cayuga to prevent damage to drives.

Replaced contacts in pump 1 contactor at Forestream.

District 4

Mowed and weed whacked 6 different times.

Repaired broken weed whacker.

Had vendor repair gas power washer that would not start.

Used power washer to clean bar screen at Depew.

Finished painting control room at Depew and cleaned everything up.

Unjammed Depew #1 muffin monster.

Pulled and cleaned pump #1 at Bowmansville 4 different times.

Pulled and cleaned pump #2 at Bowmansville twice.

Cleaned and restocked bathroom at Depew.

Repaired broken turret at Depew orf.

Cleaned up fallen trees with mini excavator outside fencing at Depew orf.

Used vactor to clean floatables out of wet well at Forestream.

Unjammed Prison muffin monster twice.

Repaired broken #5 air release at Depew.

Installed new patch panel and speakers in NR base garage.

Began replacing lights in Bowmansville Dry Well.

Adjusted settings on VFD 1 at Iroquois.

Replaced transducer at Depew pump station.

District 5

Cleaned and restocked bathrooms at Eastern Hills and Stahley.

All Districts

Checked all fluids in station generators and topped off fuels where needed.

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
JULY 2026 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTALS	0	0	0
		0	

UFPO's	D1	D4	D5
Responses	299	482	168
Stakeouts	75	80	38
TOTAL STAKEOUTS	193		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	5,746	983	221	6,950

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint				0
By District	5,516	0	0	5,516

	D1	D4	D5	TOTALS
House Inspections				0
Reinspections				0
Violations				0
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
	0	0	0	0

Manhole Repairs	D1	D4	D5	TOTAL
	7	3	3	13

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control				0
Mechanical Root Cut	0	0	0	0
Mechanically Cleaned				0

Sewerline Repairs	
SSO's	

CONSTRUCTION		
DIST # 1	DIST # 4	DIST # 5
4814 TRANSIT	BRADLEY EXTENSION	HARRIS HILL MIXED USE SITE
2715 & 2725 CAR WASH -UNION	4839 TRANSIT- CHIPOTLE	7145 TRANSIT
SONWIL WAREHOUSE	ANGRY BUFFALO	6625 TRANSIT MIXED USE
PSTATE NIAGARA 3300 SWR EXTENSIO	4106 WALDEN WAREHOUSE	
395 WEST AVE.	4400 WALDEN SEALING DEVICES	JAMES RYAN PKWY
2350 UNION - GALAXY AUTO	WEHRLE/ MAPLE EXTENSION	CREEKWOOD PUMP HOUSE
3425 BROADWAY- VALLEY TIRE	5841 GENESEE SHOP	KRAUS RD. EXTENSION
75 EMPIRE ROSINAS EXTENSION	WOOD SPRING EXTENSION	5695 & 5731 TRANSIT
	3825 BOWTIE PARK	PEANUT LINE INTERCEPTOR
	LANCASTER PKWY WAREHOUSE	9388 TRANSIT SMOO TEA
	ALDEN GROW FACILITY	ERIE COUNTY HWY 5105 SALT
	11580 WALDEN SHERRIFF BLDG	9515 CLARENCE CENTER

PLAN REVIEW	D1- ROSINAS EXTENSION
	D4- CHIPOTLE 4389 TRANSIT

2026 July UFPO Numbers

(By District/Region)

Total UFPO Tickets:	2917
Tickets Outside ECSD Boundary	302

	Total Tickets	APR Code		Other APR Codes	Total %
		10 - All Clear	30 - Staked Out	31	
District 1	299	224	75		10%
District 4	482	402	80		17%
District 5	168	130	38		6%
Total NR	949	756	193		33%

District 3	1054	893	161		36%
District 6	168	117	51		6%
District 8	139	122	17		5%
Total CR	1361	1132	229		47%

District 2	305	183	122		10%
Total SR	305	183	122		10%

Totals:	2615	2071	544	
---------	------	------	-----	--

2026 JULY TELEVISION DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10206273	07/17/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA93	119
10206260	07/17/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA92	49
10206272	07/16/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA94	200
10206259	07/17/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA91	203
10206261	07/17/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA90	237
10206271	07/15/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA95	216
10206262	07/21/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA8E	48
10206263	07/21/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA8D	201
10196630	07/01/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA8C	50
10206264	07/06/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA8B	72
10206270	07/10/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA98	181
10206265	07/10/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA8A	192
10206266	07/10/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA89	300
10206268	07/30/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA96	54
10206269	07/10/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA97	290
10206267	07/17/2026	TELEVISION JEROME 8" ACP	TELEVISIONED - (D)	E-S-N01-C-002-SL	BBA88	112
10150179	07/31/2026	TELEVISION AUTUMNWOOD - 8' CIPP/VTP	TELEVISIONED - (D)	E-S-N01-C-007-SL	BBB20	351
10206003	07/15/2026	TELEVISION BORDEN 8" ACP	TELEVISIONED - (D)	E-S-N01-C-011-SL	BC393	393
10133654	07/15/2026	TELEVISION BORDEN 8" ACP	TELEVISIONED - (D)	E-S-N01-C-011-SL	BC397	392
10132797	07/15/2026	TELEVISION BORDEN 8" ACP	TELEVISIONED - (D)	E-S-N01-C-011-SL	BC399	391
10206017	07/10/2026	TELEVISION UNION 24" TRUNK	TELEVISIONED - (D)	E-S-N01-C-008-SL	14B364	157
10206018	07/10/2026	TELEVISION UNION 24" TRUNK	TELEVISIONED - (D)	E-S-N01-C-008-SL	14B363	272
10206016	07/10/2026	TELEVISION UNION 24" TRUNK	TELEVISIONED - (D)	E-S-N01-C-008-SL	14B365	200
10204911	07/09/2026	TELEVISION UNION 24" RCP	TELEVISIONED - (D)	E-S-N01-C-008-SL	14B366	65
10204910	07/02/2026	TELEVISION UNION 24" RCP	TELEVISIONED - (D)	E-S-N01-C-008-SL	BB708	440
10207064	07/31/2026	BACKUP - STATIONARY TUB 29 LORDAN CHEEKT	TELEVISIONED - (D)	E-S-N01-C-006-SL	BBC6D	331

2026 JULY TELEVISION DISTRICT # 4

NONE

2026 JULY TELEVISION DISTRICT # 5

NONE

COMPLAINT SUMMARY ECSD # 1 JULY 2026

Notification	DATE	Description	Prob. code text	Functional Loc.
10206179	07/21/2026	SEWER BACKUP - 157 BRIGHT ST, CHEEKTOWAG	REFERRED TO OTHERS	E-S-N01-C
10206143	07/16/2026	OILY PUDDLING WATER 176 HILLPINE RD	REFERRED TO OTHERS	E-S-N01-C-003-SL
10207064	07/30/2026	FECES B/U STATIONARY TUB 29 LORDAN	HOMEOWNER'S PROBLEM	E-S-N01-C-006-SL

COMPLAINT SUMMARY ECSD # 4 JULY 2026

10205915	07/05/2026	GRINDER - 374 HARRIS HILL RD, LANCASTER	OTHER (DESCRIBE IN LONG TEXT)	E-S-N04-C-001-GP015
10206920	07/22/2026	STANDING WATER W/ ODOR 5407 GENESEE ST	HOMEOWNER'S PROBLEM	E-S-N04-C-001-SL
10206208	07/20/2026	WATER AT MH/EASEMENT 5 STONY BROOK DR	REFERRED TO OTHERS	E-S-N04-C-002-SL
10206145	07/17/2026	CLEAN OUT SINKING 280 MILLER ST	HOMEOWNER'S PROBLEM	E-S-N04-C-008-SL
10206926	07/23/2026	GRINDER ALARM - ERIE COUNTY PRISON	OTHER (DESCRIBE IN LONG TEXT)	E-S-N04-F-ECP-WETWL

COMPLAINT SUMMARY ECSD # 5 JULY 2026

10205768	07/01/2026	BACKUP - 9660 HIGH ST, CLARENCE	HOMEOWNER'S PROBLEM	E-S-N05-C-006-SL
10206178	07/21/2026	POTENTIAL BACKUP - 6003 WEXFORD MNR, CLA	REFERRED TO OTHERS	E-S-N05-C-006-SL
10206033	07/10/2026	SSO PRIVATE MH - 4545 TRANSIT	OVERFLOW OBSERVED	E-S-N05-C-008-SL

JULY 2026 I & I DISTRICT 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE
10200510	07/23/2026	MANHOLE REPAIR @ TIM TAM	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-009-MH	BB232
10196426	07/20/2026	MANHOLE REPAIR @ IRONDALE	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-004-MH	BA554
10195479	07/13/2026	MANHOLE REPAIR @ DENISE	REPAIRED FRAME/CONE JOINT LEAKS, MOD(4)	E-S-N01-C-005-MH	BABE2
10204729	07/27/2026	MANHOLE REPAIR @ CASIMER	REPAIRED FRAME/CONE JOINT LEAKS, SLT(3)	E-S-N01-C-012-MH	149A11
10205865	07/27/2026	MANHOLE REPAIR @ CLINTON	RAISED MANHOLE(4)	E-S-N01-C-009-MH	BB276
10206065	07/18/2026	MANHOLE REPAIR @ CLINTON / BORDEN	RAISED MANHOLE(4)	E-S-N01-C-009-MH	BA76C
10206065	07/18/2026	MANHOLE REPAIR @ CLINTON / BORDEN	REPAIRED FRAME, NOT JOINT LEAKS, SEV(5)	E-S-N01-C-009-MH	BA76C

JULY 2026 I & I DISTRICT 4

10204633	07/06/2026	MANHOLE REPAIR @ WALDEN / ELLICOTPL.	REPAIRED FRAME/CONE JOINT LEAKS, SLT(3)	E-S-N04-C-008-MH	DF052
10204633	07/06/2026	MANHOLE REPAIR @ WALDEN / ELLICOTPL.	REPLACED FRAME AND COVER(5)	E-S-N04-C-008-MH	DF052
10207007	07/30/2026	MANHOLE REPAIR @ 28 SAGEBRUSH LN	REPAIRED FRAME, NOT JOINT LEAKS, SLT(3)	E-S-N04-C-015-MH	DEC28

JULY 2026 I & I DISTRICT 5

10199026	07/31/2026	LOCATE AND RAISE MH @ 10985 MAIN STREET	RAISED MANHOLE(4)	E-S-N05-C-009-MH	1813
10205765	07/14/2026	MH CLANKING LOUD 5070-5080 SALT RD	REPLACED FRAME AND COVER(5)	E-S-N05-C-009-MH	10082011
10205765	07/14/2026	MH CLANKING LOUD 5070-5080 SALT RD	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N05-C-009-MH	10082011

2005 PS Flows

Month:	JULY 2026		NR Flow Summary 2026			
Station	SD	Total	Daily Avg	GPM	GPH	Tot Gal
		Hrs				
Borden-Clinton	1	270	8.7	200	12000	3,235,200
Cayuga	1	200	6.5	1190	71400	12,080,880
Clint-Tran	1	85	2.7	350	21000	1,774,500
Industrial Park	1	163	5.3	3650	219000	29,755,530
Union	1	49	1.6	850	51000	2,504,100
Woodlands	1	24	0.8	39	2340	55,458
Aurora South	4	39	1.2	705	42300	1,628,550
Bowmansville	4	393	12.7	1600	96000	37,728,000
Broadway	4	0	0.0	16000	960000	0
Depew	4	829	26.7	11000	660000	364,237,500
Forestream	4	49	1.6	1050	63000	3,093,300
Hall	4	88	2.9	130	7800	689,520
Haskell	4	22	0.7	590	35400	768,180
Iroquois	4	792	25.5	3000	180000	142,524,000
Pleasantview	4	135	4.3	950	57000	7,666,500
Vanderbilt	4	3	0.1	8000	480000	1,440,000
Warner	4	466	15.0	5000	300000	139,800,000
Zoeller	4	232	7.5	830	49800	11,563,560
Bryant	5	126	4.1	600	36000	4,543,200
Eastern Hills	5	136	4.4	625	37500	5,088,750
Forestview	5	25	0.8	554	33240	837,648
Cannonwoods	5	5	0.2	173	10380	53,976
Creekwood	5	62	2.0	509	30540	1,890,426
Pinebreeze	5	64	2.1	325	19500	1,255,800
Stahley	5	44	1.4	720	43200	1,892,160
Transit Valley	5	107	3.4	450	27000	2,883,600
Total NR Flow:						778,990,338

ERIE COUNTY - SEWER DISTRICT 1,4,5
7/1/2026 TO 7/31/2026
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	3	7	10
Taps	0	0	0	0
Disconnect	0	0	0	0
Repair	6	14	3	23
TOTAL	6	17	10	33

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	1	1	2
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	0	2	4	6
Exist Residential (ER)	0	0	2	2
TOTAL	0	3	7	10

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	2	0	2
Exist Commercial Issued (EC)	0	0	1	1
New Residential Issued (NR)	0	3	1	4
Exist Residential Issued (ER)	7	13	3	23
TOTAL	7	18	5	30

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$0	\$1,504	\$0	\$1,504
Exist Commercial Fees (EC)	\$0	\$0	\$2	\$2
New Residential Fees(NR)	\$0	\$706	\$2	\$708
Exist Residential Fees (ER)	\$14	\$26	\$6	\$46
TOTAL	\$14	\$2,236	\$10	\$2,260

DISTRICT 1

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
	7/6/2026								125.06-5-	
1	14:00	Final	CP0110763	48	E Toulon Dr	Cheektowaga	Existing	Residential Single Unit	12	Repair
	7/9/2026				Grand Prix				125.10-8-	
1	14:00	Final	CP0105865	5	Dr	Cheektowaga	Existing	Residential Single Unit	1	Repair
	7/17/2026								114.16-2-	
1	9:00	Final	CP0105934	79	Gregory Ct	Cheektowaga	Existing	Residential Single Unit	26	Repair
	7/8/2026								113.73-2-	
1	11:00		CP0111984	83	Jane Dr	Cheektowaga	Existing	Residential Single Unit	28	Repair
	7/31/2026				W Cavalier				125.09-6-	
1	13:00	Final	CP0104895	70	Dr	Cheektowaga	Existing	Residential Single Unit	15	Repair
	7/29/2026								135.08-2-	
1	10:00	Final	CP0100318	47	Borden Rd	West Seneca	Existing	Residential Single Unit	31	Repair
	7/27/2026							Residential Multiple	125.18-5-	
1	11:30	Final	CP0101066	4179	Clinton St	West Seneca	Existing	Units	18	Repair

DISTRICT 4

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type	Tap Type
	7/6/2026								103.08-15-		
4	13:30	Final	CP0410165	77	King Ave	Depew/Chktg	Existing	Residential Single Unit	10	Repair	
	7/2/2026										
4	12:00	Final	CP0400609	8	Anna Dr	Lancaster (T)	Existing	Residential Single Unit	82.19-1-22	Repair	
	7/27/2026										
4	11:15	Final	CP0401574	10	Broadmoor Ct	Lancaster (T)	Existing	Residential Single Unit	93.20-5-64	Repair	
	7/16/2026							Non-Residential Single	94.00-4-		
4	9:00	Final	CP0410170	700	Eastport Dr	Lancaster (T)	New	Unit	7.12	Connection	Wye
	7/27/2026										
4	13:30	Final	CP0410058	1	Fieldstream Ln	Lancaster (T)	New	Residential Single Unit	116.15-1-1	Connection	Wye
	7/16/2026										
4	13:00	Final	CP0410055	15	Fieldstream Ln	Lancaster (T)	New	Residential Single Unit	116.15-1-8	Connection	Wye
	7/9/2026										
4	11:00	Final	CP0405382	23	Kelly Ann Dr	Lancaster (T)	Existing	Residential Single Unit	94.13-2-36	Repair	

4	7/1/2026 13:00	Final	CP0404529	106	Pheasant Run Ln	Lancaster (T)	Existing	Residential Single Unit	93.15-4-29	Repair
4	7/23/2026 13:00	Final	CP0402648	139	Stony Rd	Lancaster (T)	Existing	Residential Single Unit	94.14-2-15	Repair
4	7/14/2026 13:30	Final	CP0402303	113	Stutzman Rd	Lancaster (T)	Existing	Residential Single Unit	93.06-3-13	Repair
4	7/8/2026 13:00	Final	CP0401881	3700	Walden Ave	Lancaster (T)	Existing	Residential Multiple Units	104.08-2-12.1	Repair
4	7/2/2026 13:30	Final	CP0410163	50	5th Ave	Lancaster (V)	Existing	Residential Single Unit	115.11-7-17	Repair
4	7/17/2026 11:00	Final	CP0410168	88	Court St	Lancaster (V)	Existing	Residential Single Unit	104.76-3-7	Repair
4	7/23/2026 10:30	Final	CP0410171	22	Linden Ave	Lancaster (V)	Existing	Residential Single Unit	115.07-8-6	Repair
4	7/20/2026 11:30	Final	CP0410172	29	Livingston St	Lancaster (V)	Existing	Residential Single Unit	104.16-8-22	Repair
4	7/23/2026 13:30	Final	CP0400299	4	Mount View Pl	Lancaster (V)	Existing	Residential Single Unit	104.49-3-19	Repair
4	7/27/2026 13:00	Final	CP0410173	80	Sturm St	Lancaster (V)	Existing	Residential Single Unit	104.15-12-2	Repair

DISTRICT 5

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type	Tap Type
5	7/20/2026 10:30	Final	CP050447 6	6030	Fairlane Dr	Clarence	Existing	Residential Single Unit	44.19-2-25	Repair	
5	7/8/2026 10:30	Final	CP050201 4	6160	Gott Creek Trl	Clarence	Existing	Residential Single Unit	43.14-6-1	Repair	
5	7/21/2026 13:00	Final	CP050074 4	4455	Transit Rd	Clarence	Existing	Non-Residential Single Unit	70.03-1-19	Repair	
5	7/16/2026 11:00	Final	CP050447 2	4380	Westwood Rd	Clarence	Existing	Residential Single Unit	70.18-1-6.1	Connection	Wye
5	7/24/2026 13:30	Final	CP050438 8	6831	Windsor Ln	Clarence	New	Residential Single Unit	29.18-5-8	Connection	Wye

DISTRICT 5 CLARENCE TOWN DISTRICTS

District	CTD	Insp Date	Permit	#	Street	Town	Permit Subtype	New/Existing	Property Type	SBL	Permit Type	Tap Type
----------	-----	-----------	--------	---	--------	------	----------------	--------------	---------------	-----	-------------	----------

5	2	7/7/2026 13:00	CP0504446	5613	Cannon Dr	Clarence	Clarence Iss	New	Residential Single Unit	58.10-5-40	Connection	Wye
5	2	7/6/2026 13:00	CP0504449	5664	Dorothy Cir	Clarence	Clarence Iss	New	Residential Single Unit	58.10-5-5	Connection	Wye
		7/22/2026			James Ryan		Clarence		Non-Residential Single	44.00-1-		
5	2	11:00	CP0504447	6699	Pkwy	Clarence	Clarence Iss	New	Unit	55.312	Connection	Wye
		7/23/2026					Clarence					
5	10	11:00	CP0504463	5152	Kandefer's Trl	Clarence	Clarence Iss	New	Residential Single Unit	57.19-7-15	Connection	Wye
		7/21/2026					Clarence					
5	10	11:00	CP0504460	5162	Kandefer's Trl	Clarence	Clarence Iss	Existing	Residential Single Unit	57.19-7-16	Connection	Wye

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	31-Jul	2062.8		18.5	159	88	21		-	135
Cayuga	1	Under Generator	1300	33	39.39	31-Jul	844.4		31	1221	94	79		-	975
Clinton	1	Under Generator	150	24	6.25	31-Jul	1992.8		21	131	88	19		-	113
Industrial Parkway	1	Under Generator	700	30	23.33	31-Jul	714.7		26.25	613	88	88		-	525
Union	1	Under Generator	400	26	15.38	31-Jul	179.1		24	369	92	31		-	300
Aurora South	4	Under Generator	285	21	13.57	31-Jul	1838		18	244	86	41		-	214
Bowmansville	4	Under Generator	700	26	26.92	31-Jul	994		23	619	88	81		-	525
Broadway	4	Above-Ground	1000	36	*	31-Jul	321		32	770	77	230		-	750
Depew	4	Above-Ground	3000	69	*	31-Jul	529		49.5	2134	71	866		X	2250
Iroquois	4	Under Generator	295	17	17.35	31-Jul	1116.8		16	278	94	17		-	221
Vanderbilt	4	Above-Ground	1000	36	*	31-Jul	161.3		32	770	77	230		-	750
Warner	4	Under Generator	700	26	26.92	31-Jul	1915		24	646	92	54		-	525
Zoeller	4	Under Generator	680	32	21.25	31-Jul	18.7		24.5	521	77	159		-	510
Bryant	5	Under Generator	180	22	8.18	31-Jul	701.1		17.5	143	80	37		-	135
Pinebreeze	5	Under Generator	275	44	*	31-Jul	1328.5		43.5	272	99	3		-	206
Stahley	5	Under Generator	150	25	6.00	31-Jul	1637		21	126	84	24		-	113
Transit Valley	5	Above Ground	275	44	*	31-Jul	102.9		38	248	90	27		-	206

* Calculated

Refill at: 0.75

July 2026 Maintenance

District 1

Cleaned up Borden pump station controls and pulled new alarm wires.
Shut down Cayuga Pump station 2 times to assist collections with Televising lines.
Mowed and weed whacked 7 different times.
Washed IPP wet well floor and walls.
Washed Cayuga wet well floor and walls.
Vendor repaired broken lock at Mineral Springs.
Pruned bushes at mineral springs.
Cleaned dry well at Cayuga.
Cleaned bar screen at Clinton.

District 4

Fixed check valve 1 at Depew.
Installed junction box and conduit for transducer at Pleasantview.
Installed new lights in Bowmansville Dry well.
Replaced grinder at 374 Harris Hill and cleaned out tank.
Ran new conduit at Bowmansville for transducer wires.
Replaced VFD #4 at IPP.
Replaced Pump 1 at Hall Road.
Performed annual Grinder check.
Replaced HWW float at Pleasantview.
Mowed and weed whacked 5 times.
Replaced broken sump pump in Depew dry well.
Washed floor in Depew dry well.
Cleaned brush and vines from fencing at Pleasantview.
Washed muffin monster pit at Prison.
Installed new side boards on NR47.
Repaired crack in wall at Depew Orf.
Repaired tire on lawn trailer.
Pulled and cleaned pump one at Bowmansville.
Serviced all lawn equipment.
Pulled and cleaned pump two at Bowmansville.

District 5

Installed new contacts in the motor starters at Pine breeze.
Reset Dodge Road Flowmeter.

Repaired broken airline at CRP.

Cut up fallen trees along driveway at CRP.

Cleaned brush and vines from fence at Stahley.

Cleaned brush and vines from fence at Transit Valley.

All Districts

Checked all fluids in station generators and topped off fuels where needed.

Tested all HWW floats.

COMPLAINT SUMMARY ECSD # 1 AUGUST 2026

Notification	DATE	Description	Prob. code text	Functional Loc.
10207201	08/10/2026	FLUSHING ONLY PERIODICALLY 3145 BROADWAY	HOMEOWNER'S PROBLEM	E-S-N01-C-001-SL
10207392	08/21/2026	SEWAGE BACK UP IN BSMT 87 JANE DR, CHEEK	HOMEOWNER'S PROBLEM	E-S-N01-C-001-SL
10207096	08/03/2026	BACK UP - 879 FRENCH RD, CHEEKTOWAGA	BASEMENT FACILITY	E-S-N01-C-007-SL
10207269	08/08/2026	SEWER BACKUP - 423 BORDEN RD, CHEEKTOWAG	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-007-SL
10207310	08/12/2026	SEWER BACK UP - 10 BRENTWOOD DR, CHEEKTO	FLUSHED LINE/NO BLOCKAGE	E-S-N01-C-007-SL
10207407	08/18/2026	MANHOLE - EMPIRE DR	OTHER (DESCRIBE IN LONG TEXT)	E-S-N01-C-009-MH

COMPLAINT SUMMARY ECSD #4 AUGUST 2026

10207176	08/06/2026	WATER IN BSMT 18 MEADOW LEA DR	FLUSHED LINE/NO BLOCKAGE	E-S-N04-C-005-SL
10207202	08/10/2026	ROOTS IN LATERAL NEAR MAIN 1 BISCAYNE	FOLLOW-UP REQUIRED	E-S-N04-C-005-SL
10207271	08/09/2026	SEWER BACKUP - 1 BISCAYNE DR, LANCASTER	HOMEOWNER'S PROBLEM	E-S-N04-C-005-SL
10208271	08/28/2026	MANHOLE BROKEN - WALDEN AVE & RANSOM RD,	FOLLOW-UP REQUIRED	E-S-N04-C-007-SL

COMPLAINT SUMMARY ECSD #5 AUGUST 2026

NONE

AUGUST 2026 I&I DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE
10200515	08/24/2026	MANHOLE REPAIR @ NORTH (EPOXY)	REPAIRED BARREL JOINT LEAKS, MOD(4)	E-S-N01-C-009-MH	BAA1B
10207403	08/18/2026	SEWER REPAIR @ BORDEN	PIPE REPLACED - 8"	E-S-N01-C-007-SL	BB89A
10207301	08/12/2026	MODIFY CLEANOUT @ 3945 CLINTON	REPAIRED FRAME, NOT JOINT LEAKS, SLT(3)	E-S-N01-C-009-MH	10079811

AUGUST 2026 I&I DISTRICT # 4

10184501	08/05/2026	MANHOLE REPAIR @ RED CLOVER	RAISED MANHOLE(4)	E-S-N04-C-006-MH	1ABB08
----------	------------	-----------------------------	-------------------	------------------	--------

AUGUST 2026 I&I DISTRICT # 5

10166813	08/05/2026	RESET AND RESEAL MH @ FOXTRACE/GALBRAITH	REPAIRED FRAME, NOT JOINT LEAKS, SLT(3)	E-S-N05-C-007-MH	C0F01
10206093	08/04/2026	MANHOLE REPAIR @ STAHLEY	RAISED MANHOLE(4)	E-S-N05-C-002-MH	C0731

2026 AUGUST MECHANICAL ROOTCUT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10207256	08/13/2026	TELEWISE 8" VTP/CIPP - 10 BRENTWOOD	MECHANICAL ROOT CUT	E-S-N01-C-007-SL	BBCF4	212

2026 AUGUST MECHANICAL ROOTCUT # 4

10207204	08/13/2026	TELEWISE BISCAYNE 8"CIPP/VTP	MECHANICAL ROOT CUT	E-S-N04-C-005-SL	F29F8	256
----------	------------	------------------------------	---------------------	------------------	-------	-----

2026 AUGUST MECHANICAL ROOTCUT # 5

NONE

2026 AUGUST TELEVISION DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10207256	08/13/2026	TELEVISION 8" VTP/CIPP - 10 BRENTWOOD	TELEVISIONED - (D)	E-S-N01-C-007-SL	BBCF4	212
10207206	08/11/2026	TELEVISION BORDEN 8" VTP	TELEVISIONED - (D)	E-S-N01-C-007-SL	BB89A	262
10207311	08/10/2026	TELEVISION BORDEN 8" VTP	TELEVISIONED - (D)	E-S-N01-C-007-SL	BB89B	301
10207312	08/10/2026	TELEVISION BORDEN 8" VTP	TELEVISIONED - (D)	E-S-N01-C-007-SL	BB89C	267
10203714	08/14/2026	TELEVISION 21" RCP @ 1001 MINERAL SPRINGS	TELEVISIONED - (D)	E-S-N01-C-010-SL	1A6FDB	110
10206018	08/17/2026	TELEVISION UNION 24" TRUNK	TELEVISIONED - (D)	E-S-N01-C-008-SL	14B363	272

2026 AUGUST TELEVISION DISTRICT # 4

10206066	08/03/2026	TELEVISION 21" ACP @4106 WALDEN / EASTPOR	TELEVISIONED - (D)	E-S-N04-C-007-SL	DF195	482
10206067	08/03/2026	TELEVISION 21" ACP @4106 WALDEN / EASTPORT	TELEVISIONED - (D)	E-S-N04-C-007-SL	DF19D	497
10206068	08/03/2026	TELEVISION 21" ACP @4106 WALDEN / EASTPORT	TELEVISIONED - (D)	E-S-N04-C-007-SL	DF19E	502
10207118	08/05/2026	TELEVISION WALDEN 21" RCP	TELEVISIONED - (D)	E-S-N04-C-007-SL	DF1A5	478
10207119	08/05/2026	TELEVISION WALDEN 8" PVC	TELEVISIONED - (D)	E-S-N04-C-007-SL	DF1A6	95
10207144	08/05/2026	TELEVISION WALDEN 8" PVC	TELEVISIONED - (D)	E-S-N04-C-007-SL	DF1A7	269
10207140	08/17/2026	TELEVISION WALDEN 21" RCP	TELEVISIONED - (D)	E-S-N04-C-007-SL	DF1A8	552
10207141	08/17/2026	TELEVISION WALDEN 21" RCP	TELEVISIONED - (D)	E-S-N04-C-007-SL	DF1A9	440
10207142	08/17/2026	TELEVISION WALDEN 21" RCP	TELEVISIONED - (D)	E-S-N04-C-007-SL	DF1AA	90
10207145	08/14/2026	TELEVISION WALDEN 8" PVC	TELEVISIONED - (D)	E-S-N04-C-007-SL	DF1AB	243
10207146	08/19/2026	TELEVISION WALDEN 21" RCP	TELEVISIONED - (D)	E-S-N04-C-007-SL	DF1AC	72
10207117	08/05/2026	TELEVISION WALDEN 21" RCP	TELEVISIONED - (D)	E-S-N04-C-007-SL	DF1A4	420
10207162	08/03/2026	TELEVISION WALDEN 21" RCP	TELEVISIONED - (D)	E-S-N04-C-007-SL	DF1A3	500
10207205	08/13/2026	TELEVISION BISCAYNE 8"CIPP/VTP	TELEVISIONED - (D)	E-S-N04-C-005-SL	F29F7	86
10207204	08/13/2026	TELEVISION BISCAYNE 8"CIPP/VTP	TELEVISIONED - (D)	E-S-N04-C-005-SL	F29F8	256

2026 AUGUST TELEVISION DISTRICT # 5

NONE

2026 August UFPO Numbers

(By District/Region)

Total UFPO Tickets:	2711
Tickets Outside ECSD Boundary	381

	Total Tickets	APR Code		Other APR Codes	Total %	Stakeout %
		10 - All Clear	30 - Staked Out	31		
District 1	255	183	72		9%	14%
District 4	331	255	76		12%	15%
District 5	138	105	33		5%	6%
Total NR	724	543	181		27%	35%

District 3	1048	870	178		39%	34%
District 6	159	128	31		6%	6%
District 8	138	93	45		5%	9%
Total CR	1345	1091	254		50%	49%

District 2	261	176	85		10%	16%
Total SR	261	176	85		10%	16%

Totals:	2330	1810	520	
---------	------	------	-----	--

ERIE COUNTY - SEWER DISTRICT 1,4,5
8/1/2026 TO 8/31/2026
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	1	2	6	9
Taps	0	0	0	0
Disconnect	0	0	0	0
Repair	3	9	5	17
TOTAL	4	11	11	26

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	0	0	0
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	1	2	6	9
Exist Residential (ER)	0	0	0	0
TOTAL	1	2	6	9

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	0	0	0
Exist Commercial Issued (EC)	0	0	0	0
New Residential Issued (NR)	1	4	0	5
Exist Residential Issued (ER)	7	8	5	20
TOTAL	8	12	5	25

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$0	\$0	\$0	\$0
Exist Commercial Fees (EC)	\$0	\$0	\$0	\$0
New Residential Fees(NR)	\$802	\$1,408	\$0	\$2,210
Exist Residential Fees (ER)	\$14	\$16	\$10	\$40
TOTAL	\$816	\$1,424	\$10	\$2,250

DISTRICT 1

CONNECTIONS/PERMITS

1	8/6/2026 13:30	Final	CP010551 6	84- 86	Freemont Ave	Cheektowag a	Existin g	Residential Multiple Units	114.08-5-21.1	Repair	
1	8/19/2026 13:30	Final	CP011194 1	161	Gary Rd	Cheektowag a	New	Residential Single Unit	125.08-9- 12.121	Connectio n	Wy e
1	8/31/2026 11:00	Final	CP010274 5	50	Yvette Dr	Cheektowag a	Existin g	Residential Single Unit	125.09-18-13	Repair	
1	8/10/2026 11:00	Final	CP010138 1	56	Deer Chase Rd	West Seneca g	Existin g	Residential Single Unit	124.18-1-51	Repair	
1	8/14/2026 13:00	Partia l	CP011198 5	279	Seneca Creek Rd	West Seneca	New	Residential Single Unit	135.05-1-11.2	Connectio n	

DISTRICT 4

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existin g	Property Type	SBL	Permit Type	Tap Type
4	8/18/2026 13:00	Final	CP041017 7	79	Michele Dr	Depew/Chkt g	Existing	Residential Single Unit	92.20-5-10	Repair	
4	8/10/2026 14:00	Final	CP041017 5	30	Norman Dr	Depew/Chkt g	Existing	Residential Single Unit	92.20-11- 11	Repair	
4	8/19/2026 13:00	Final	CP041017 8	11 5	Crane St	Depew/Lanc	Existing	Residential Multiple Units	104.07-1- 10.1	Repair	
4	8/25/2026 11:30	Final	CP041017 9	73	Terrell St	Depew/Lanc	Existing	Residential Single Unit	104.07-3- 15	Repair	
4	8/25/2026 13:00	Final	CP041012 0	19	Fieldstream Ln	Lancaster (T)	New	Residential Single Unit	116.15-1- 10	Connectio n	Wy e
4	8/24/2026 13:00	Final	CP041005 4	20	Fieldstream Ln	Lancaster (T)	New	Residential Single Unit	116.15-1- 35	Connectio n	Wy e
4	8/7/2026 10:00	Canceled	CP041005 4	20	Fieldstream Ln	Lancaster (T)	New	Residential Single Unit	116.15-1- 35	Connectio n	
4	8/3/2026 13:00	Final	CP040692 7	23	Grace Way	Lancaster (T)	Existing	Residential Single Unit	116.05-4- 69	Repair	

4	8/14/2026		CP040691			Lancaster		Residential Single	116.05-4-	
4	11:00	Final	4	9	Grace Way	(T)	Existing	Unit	75	Repair
4	8/26/2026		CP040300		Running Brook	Lancaster		Residential Single	126.10-1-	
4	14:00	Final	4	30	Dr	(T)	Existing	Unit	59.1	Repair
4	8/17/2026		CP040222		Walnut Creek	Lancaster		Residential Single		
4	14:00	Final	2	2	Trl	(T)	Existing	Unit	126.10-4-9	Repair
4	8/17/2026		CP041016	13		Lancaster		Residential Multiple	115.07-16-	
4	13:30	Final	6	9	Irwinwood Rd	(V)	Existing	Units	5	Repair

DISTRICT 5

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
5	8/5/2026								72.06-2-	
5	13:00	Final	CP0503684	4935	Alexander Dr	Clarence	Existing	Residential Single Unit	23	Repair
5	8/21/2026								57.14-2-	
5	11:30	Final	CP0500281	5554	Oak Dale Ln	Clarence	Existing	Residential Single Unit	10	Repair
5	8/24/2026								57.10-4-	
5	11:30	Final	CP0500284	5564	Oak Dale Ln	Clarence	Existing	Residential Single Unit	45	Repair
5	8/14/2026								44.10-2-	
5	13:30	Final	CP0504482	9420	Pinyon Ct	Clarence	Existing	Residential Single Unit	29	Repair
5	8/7/2026				Whitegate				43.17-4-	
5	13:00	Final	CP0500439	6070	Xing	Clarence	Existing	Residential Single Unit	39	Repair

DISTRICT 5 CLARENCE TOWN DISTRICTS

District	CT D	Insp Date	Permit	#	Street	Town	Permit Subtype	New/Existing	Property Type	SBL	Permit Type	Tap Type	Comments
5		8/3/2026 14:00	CP050442	961	Spaulding Green	Clarence	Clarence		Residential Single		Connection		
5	2	8/31/2026 13:00	CP050446	568	Parkway	Clarence	Clarence	New	Unit	0	Connection	Wye	
5	4	8/18/2026 13:30	CP050445	977	Dorothy Cir	Clarence	Clarence	New	Residential Single	58.10-5-9	Connection	Wye	Clarence issued. DSM inspected.
5	4	8/12/2026 13:00	CP050446	551	Longleaf Trl	Clarence	Clarence	New	Residential Single	58.16-5-4	Connection	Wye	Clarence issued. DSM inspected.
5	6	8/6/2026 13:00	CP050446	531	Serenity Ct	Clarence	Clarence	New	Unit	58.15-10-2	Connection	Wye	Clarence issued. DSM inspected.
5			2	9	Briannas Nook	Clarence	Clarence	New	Residential Single	58.17-13-2	Connection	Wye	Clarence issued. DSM inspected.

5	10	8/19/2026 11:00	CP050447 3	513 1	Kandefer's Trl	Clarenc e	Clarence Iss	New	Residential Single Unit	57.19-7- 9	Connectio n	Wye	Clarence issued. DSM inspected.
---	----	--------------------	---------------	----------	----------------	--------------	-----------------	-----	----------------------------	---------------	----------------	-----	------------------------------------

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	31-Aug	2067.5		17.75	152	85	28		-	135
Cayuga	1	Under Generator	1300	33	39.39	31-Aug	844.3		30.5	1202	92	98		-	975
Clinton	1	Under Generator	150	24	6.25	31-Aug	1997.8		20	125	83	25		-	113
Industrial Parkway	1	Under Generator	700	30	23.33	31-Aug	715.9		25	583	83	117		-	525
Union	1	Under Generator	400	26	15.38	31-Aug	183.5		23.5	362	90	38		-	300
Aurora South	4	Under Generator	285	21	13.57	31-Aug	1842		17.5	238	83	48		-	214
Bowmansville	4	Under Generator	700	26	26.92	31-Aug	996		23.5	633	90	67		-	525
Broadway	4	Above-Ground	1000	36	*	31-Aug	162.8		33	796	80	204		-	750
Depew	4	Above-Ground	3000	69	*	31-Aug	322		32.5	1264	42	1736		X	2250
Iroquois	4	Under Generator	295	17	17.35	31-Aug	1116.8		16	278	94	17		-	221
Vanderbilt	4	Above-Ground	1000	36	*	31-Aug	322		32.5	796	80	204		-	750
Warner	4	Under Generator	700	26	26.92	31-Aug	1916		23	619	88	81		-	525
Zoeller	4	Under Generator	680	32	21.25	31-Aug	20.3		21.5	457	67	223		X	510
Bryant	5	Under Generator	180	22	8.18	31-Aug	701.1		17	139	77	41		-	135
Pinebreeze	5	Under Generator	275	44	*	31-Aug	1328.5		43	272	99	3		-	206
Stahley	5	Under Generator	150	25	6.00	31-Aug	1640		19.5	117	78	33		-	113
Transit Valley	5	Above Ground	275	44	*	31-Aug	106.7		37	241	88	34		-	206

* Calculated

Refill at: 0.75

Month:	AUGUST 2026		NR Flow Summary 2026			
Station	SD	Total	Daily Avg	GPM	GPH	Tot Gal
		Hrs				
Borden-Clinton	1	337	10.9	200	12000	4,047,600
Cayuga	1	218	7.0	1190	71400	12,552,120
Clint-Tran	1	50	1.6	350	21000	1,054,200
Industrial Park	1	186	6.0	3650	219000	32,790,870
Union	1	43	1.4	850	51000	2,172,600
Woodlands	1	20	0.6	39	2340	45,864
Aurora South	4	37	1.2	705	42300	1,556,640
Bowmansville	4	344	11.1	1600	96000	33,024,000
Broadway	4	2	0.1	16000	960000	1,920,000
Depew	4	752	24.3	11000	660000	312,262,500
Forestream	4	46	1.5	1050	63000	2,923,200
Hall	4	31	1.0	130	7800	244,140
Haskell	4	17	0.6	590	35400	605,340
Iroquois	4	721	23.3	3000	180000	129,780,000
Pleasantview	4	119	3.8	950	57000	6,760,200
Vanderbilt	4	5	0.2	8000	480000	2,400,000
Warner	4	419	13.5	5000	300000	125,700,000
Zoeller	4	203	6.5	830	49800	10,104,420
Bryant	5	121	3.9	600	36000	4,341,600
Eastern Hills	5	135	4.4	625	37500	5,073,750
Forestview	5	27	0.9	554	33240	894,156
Cannonwoods	5	5	0.2	173	10380	49,824
Creekwood	5	50	1.6	509	30540	1,527,000
Pinebreeze	5	62	2.0	325	19500	1,199,250
Stahley	5	72	2.3	720	43200	3,097,440
Transit Valley	5	109	3.5	450	27000	2,937,600
Total NR Flow:						699,064,314

August 2026 Maintenance

District 1

Mowed and weed whacked 6 different times.
Cleaned and wash Industrial Park dry well.
Pulled and cleaned pump #1 at Woodlands.
Pulled and cleaned pump # 2 at Woodlands.
Installed new VFD 4 at IPP.
Finished the control upgrade at Borden.
Rebuilt boathouse pump onsite.
Replaced RTU for dry well at Cayuga.

District 4

Mowed and wed whacked 5 different times.
Pulled and cleaned pump #1 at Bowmansville 4 different times.
Pulled at cleaned pump #2 at Bowmansville once.
Removed vegetation growing on ramps at Depew ORF.
Replaced batteries on NR40.
Removed vines growing in fence around back gate at Depew ORF.
Swept up and removed garbage from station interiors at Aurora South, Depew, and Forestream.
Installed new sump pumps in dry well at Depew station.
Repaired mower deck on mower #5.
Repaired wiring at Bowmansville for Moscad.
Removed and repaired cabinet linkage for Vanderbilt breakers.
Assisted cathodic protection vendor with 5yr pm.
Repaired limit switch on Iroquois Man Lift.
Continued Soft Start replacement at Warner.
Began replacing sump pump controls at Depew pump station.
Tested all hww floats.
Replaced Rotork operator at Vanderbilt.

District 5

Removed vines from fencing and cleaned around valve pit at Eastern Hills.
Set up by pass pumping for electrical change over at Creekwood, then returned pump and hoses to base.
Tested all hww floats.

All Districts

Checked generator fluids and topped off fuels where needed on station generators.

Took vendor around to complete annual hoist inspections.

Assisted Stark with annual genset PM's.