

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
SEPTEMBER 2025 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTALS	0	0	0
	0		

UFPO's	D1	D4	D5
Responses	249	429	148
Stakeouts	75	67	33
TOTAL STAKEOUTS	175		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	10,887	834	0	11,721

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint	10,887	0	0	10,887
By District	0	0	0	0

	D1	D4	D5	TOTALS
House Inspections	41	0	0	41
Reinspections	6	2	0	8
Violations	5	0	0	5
Dye Tests	0	0	0	0

Manhole Inspections	D1	D4	D5	TOTAL
	0	0	0	0

Manhole Repairs	D1	D4	D5	TOTAL
	2	5	0	7

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control	0	0	0	0
Mechanical Root Cut	0	0	0	0
Mechanically Cleaned	0	0	0	0

Sewerline Repairs	D1 MS 1- BROADWAY (BB427) PIPE PATCH
SSO	NONE

CONSTRUCTION		
D1	D4	D5
4814 TRANSIT	BIG DITCH	HARRIS HILL MIXED USE SITE
GARY LN. 2 LOT SUB.	BRADLEY EXTENSION	7149 TRANSIT
SONWIL WAREHOUSE	NEXTERA ENERGY TRANS.	6625 TRANSIT MIXED USE
160 EMPIRE AGILE STORAGE	ANGRY BUFFALO	WOODLAND HILLS PH2
THE SPRINGS AT WS	5153 TRANSIT - THEOS PL	JAMES RYAN PKWY
2715 & 2725 CAR WASH -UNION	VALVOLINE OIL CHANGE	6260 GOOD RICH SANTORAS
UPSTATE NIAGARA 3300 N.AMERICA	4510 BROADWAY APARTMENTS	KRAUS RD. EXTENSION
	5841 GENESEE SHOP	5205 TRANSIT SHAKE SHACK
	WOOD SPRING EXTENSION	LEGACY WOODS PS
	3825 BOWTIE PARK	
	CEMETARY RD. SEIBEL	
	4106 WALDEN WAREHOUSE	
	SIEBEL MANFG.	
	NEXTERA ENERGY TRANS.	
Plans Reviewed:		
	D5- SHAKE SHACK 5205 TRANSIT	

SEPTEMBER 2025 I&I DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE
10194460	09/10/2025	MANHOLE REPAIR @ 3795 BROADWAY	REPLACED FRAME AND COVER(5)	E-S-N01-C-001-MH	BA31A
10195340	09/29/2025	PIPE PATCH @ BROADWAY	PIPE PATCHED - BROKEN	E-S-N01-C-001-SL	BB427
10188365	09/19/2025	MANHOLE REPAIR @ INDIAN CHURCH BACKLOT	REPAIRED CONE/BARREL JOINT LEAKS, MOD(4)	E-S-N01-C-010-MH	BB095

SEPTEMBER 2025 I&I DISTRICT # 4

10187308	09/08/2025	MANHOLE REPAIR @ DONNA LEA	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N04-C-005-MH	EABF6
10184503	09/03/2025	MANHOLE REPAIR @ CHICORY LN.	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N04-C-006-MH	1ABAFF
10187357	09/08/2025	MANHOLE REPAIR @ MATHEWS	REPAIRED FRAME/CONE JOINT LEAKS, SLT(3)	E-S-N04-C-005-MH	EAC0E
10194381	09/09/2025	MANHOLE REPAIR @ FIREMANS PARK	RAISED MANHOLE(4)	E-S-N04-C-008-MH	DF0F4
10194381	09/09/2025	MANHOLE REPAIR @ FIREMANS PARK	REPLACED FRAME AND COVER(5)	E-S-N04-C-008-MH	DF0F4

SEPTEMBER 2025 I&I DISTRICT # 5

NONE

2025 September UFPO Numbers

(By District/Region)

Total UFPO Tickets:	2619
Tickets Outside ECSD Boundary	341

	Total Tickets	APR Code		Other APR Codes		Total %	Stakeout %
		10 - All Clear	30 - Staked Out	31	51		
District 1	249	174	75			10%	13%
District 4	429	362	67			16%	12%
District 5	148	115	33			6%	6%
Total NR	826	651	175			32%	31%

District 3	925	707	218			35%	38%
District 6	119	56	63			5%	11%
District 8	141	131	10			5%	2%
Total CR	1185	894	291			45%	51%

District 2	267	166	101			10%	18%
Total SR	267	166	101			10%	18%

Totals:	2278	1711	567				
---------	------	------	-----	--	--	--	--

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	12-Sep	2013		13	111	62	69		X	135
Cayuga	1	Under Generator	1300	33	39.39	10-Sep	837		33	1300	100	0		-	975
Clinton	1	Under Generator	150	24	6.25	12-Sep	1935		16	100	67	50		X	113
Industrial Parkway	1	Under Generator	700	30	23.33	12-Sep	710		26	607	87	93		-	525
Union	1	Under Generator	400	26	15.38	12-Sep	115		24	369	92	31		-	300
Aurora North	4	Under Generator	325	24	13.54					0	0	325		X	244
Aurora South	4	Under Generator	285	21	13.57	12-Sep	1787		16	217	76	68		-	214
Bowmansville	4	Under Generator	700	26	26.92	15-Sep	944		21	565	81	135		-	525
Broadway	4	Above-Ground	1000	36	*	10-Sep	317		29	689	69	311		X	750
Depew	4	Above-Ground	3000	69	*	10-Sep	499		51	2230	74	770		X	2250
Iroquois	4	Under Generator	295	17	17.35	15-Sep	1113		11	191	65	104		X	221
Vanderbilt	4	Above-Ground	1000	36	*	10-Sep			31	689	69	311		X	750
Warner	4	Under Generator	700	26	26.92	15-Sep	1882		21	565	81	135		-	525
Bryant	5	Under Generator	180	22	8.18	15-Sep	698		17	139	77	41		-	135
Pinebreeze	5	Under Generator	275	44	*	15-Sep	1328		40	259	94	16		-	206
Stahley	5	Under Generator	150	25	6.00	15-Sep	1579		19	114	76	36		-	113
Transit Valley	5	Above Ground	275	44	*	15-Sep	51		37	241	88	34		-	206

* Calculated

Refill at: 0.75

Month:	September	2025	NR Flow Summary			
Station	SD	Total	Daily Avg	GPM	GPH	Tot Gal
		Hrs				
Borden-Clinton	1	438	14.6	200	12000	5,251,200
Cayuga	1	184	6.1	1190	71400	10,410,120
Clint-Tran	1	42	1.4	350	21000	875,700
Industrial Park	1	103	3.4	3650	219000	20,204,940
Union	1	42	1.4	850	51000	2,136,900
Woodlands	1	12	0.4	39	2340	26,910
Aurora South	4	35	1.2	705	42300	1,467,810
Bowmansville	4	304	10.1	1600	96000	29,184,000
Broadway	4	0	0.0	16000	960000	0
Depew	4	1245	41.5	11000	660000	513,975,000
Forestream	4	38	1.3	1050	63000	2,406,600
Hall	4	35	1.2	130	7800	269,100
Haskell	4	14	0.5	590	35400	499,140
Iroquois	4	672	22.4	3000	180000	120,906,000
Pleasantview	4	91	3.0	950	57000	5,169,900
Vanderbilt	4	0	0.0	8000	480000	0
Warner	4	362	12.1	5000	300000	108,600,000
Zoeller	4	177	5.9	830	49800	8,799,660
Bryant	5	91	3.0	600	36000	3,276,000
Eastern Hills	5	106	3.5	625	37500	3,967,500
Forestview	5	19	0.6	554	33240	648,180
Creekwood	5	39	1.3	509	30540	1,194,114
Pinebreeze	5	46	1.5	325	19500	889,200
Stahley	5	48	1.6	720	43200	2,077,920
Transit Valley	5	68	2.3	450	27000	1,841,400
Total NR Flow:					844,077,294	

DISTRICT 1

CONNECTIONS/PERMITS

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type	Tap Type
	9/11/2025				West		Residential Multiple			
1	10:30	CP0111931	1101	Carriage Ln	Seneca	New	Units	136.13-1-8	Connection	
	9/10/2025				West		Residential Multiple			
1	10:30	CP0111932	1102	Carriage Ln	Seneca	New	Units	136.13-1-8	Connection	
	9/22/2025				West		Non-Residential Single	24.20-10-		
1	13:30	CP0111942	3457	Clinton St	Seneca	Existing	Unit	12	Repair	
					West		Non-Residential Single	124.15-2-		
1	9/3/2025 12:00	CP0104387	130	Empire Rd	Seneca	New	Unit	5.1	Connection	
	9/15/2025			Seneca Creek	West			135.05-3-		
1	13:00	CP0108823	432	Road	Seneca	Existing	Residential Single Unit	36	Repair	

DISTRICT 4

CONNECTIONS/PERMITS

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type	Tap Type
	9/11/2025						Non-Residential Single			
4	13:00	CP0409845	6640	Transit Rd	Cheektowaga	New	Unit	82.03-4-16	Connection	
	9/12/2025							103.08-10-		
4	13:30	CP0409872	35	Irving Terrace	Depew	Existing	Residential Single Unit	3	Repair	
	9/16/2025							93.17-11-		
4	11:00	CP0409873	28	Mona Ct	Depew	Existing	Residential Single Unit	21	Repair	
	9/5/2025							103.08-4-		
4	13:00	CP0409867	19	Pamela Ct	Depew	Existing	Residential Single Unit	19	Repair	
	9/8/2025									
4	14:00	CP0409869	49	Regal St	Depew	Existing	Residential Single Unit	93.13-7-45	Repair	
	9/9/2025							104.30-3-		
4	13:30	CP0409870	73	Tyler St	Depew	Existing	Residential Single Unit	14	Repair	
	9/5/2025									
4	13:30	CP0409868	256	French Rd	Depew/Chktg	Existing	Residential Single Unit	92.20-4-15	Repair	
	9/8/2025									
4	13:30	CP0402624	387	Seneca Place	Lancaster	Existing	Residential Single Unit	93.20-6-30	Repair	
	9/17/2025							126.07-1-		
4	14:00	CP0407856	637	Aurora St	Lancaster (T)	Existing	Residential Single Unit	29	Repair	

4	9/25/2025 13:30	CP0405760	10	Cidermill Ct	Lancaster (T)	Existing	Residential Single Unit	126.10-2-57	Repair	
4	9/3/2025 13:00	CP0406480	27	Fieldstone Ln	Lancaster (T)	Existing	Residential Single Unit	126.10-1-86	Repair	
4	9/25/2025 13:00	CP0405146	19	Lake Forest Pkwy	Lancaster (T)	Existing	Residential Single Unit	126.07-2-22	Repair	
4	9/23/2025 11:30	CP0409764	6727	Transit Rd	Lancaster (T)	New	Non-Residential Single Unit	82.03-1-63	Connection	Tap
4	9/10/2025 13:00	CP0409871	108	Erie St	Lancaster (V)	Existing	Residential Single Unit	104.16-8-14	Repair	
4	9/30/2025 11:00	CP0409839	20	Franklin St	Lancaster (V)	Existing	Residential Single Unit	115.27-2-12	Connection	
4	9/16/2025 13:00	CP0409874	35	Roosevelt Ave	Lancaster (V)	Existing	Residential Single Unit	115.11-20-26	Repair	

DISTRICT 5

CONNECTIONS/PERMITS

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type	Tap Type
5	9/12/2025 13:00	CP0501696	8040	Lapp Rd	Clarence	Existing	Residential Single Unit	29.01-1-5	Repair	
5	9/30/2025 13:00	CP0504383	10664	Main st	Clarence	Existing	Residential Single Unit	72.06-6-18	Disconnect	
5	9/2/2025 13:30	CP0500196	8645	Millcreek Dr	Clarence	Existing	Residential Single Unit	43.15-4-18	Repair	
5	9/18/2025 11:00	CP0504378	6599	Transit Rd	Clarence	New	Non-Residential Single Unit	43.05-2-1.11	Connection	Tap
5	9/17/2025 13:00	CP0504378	6599	Transit Rd	Clarence	New	Non-Residential Single Unit	43.05-2-1.11	Connection	Tap

DISTRICT 5 CLARENCE TOWN DISTRICTS

District	CTD	Insp Date	Permit	#	Street	Town	Permit Subtype	New/Existing	Property Type	SBL	Permit Type	Tap Type	Comments
5	6	9/3/2025 13:30	CP0504358	5324	Briannas Nook	Clarence	Clarence Iss	New	Residential Single Unit	58.17-13-7	Connection	Wye	Clarence issued. DSM inspected.
5	10	9/16/2025 14:00	CP0504362	5122	Kandefer's Trail	Clarence	Clarence Iss	New	Residential Single Unit	57.19-7-12	Connection	Wye	Clarence issued. DSM inspected.
5	10	9/17/2025 14:00	CP0504363	5142	Kandefer's Trail	Clarence	Clarence Iss	New	Residential Single Unit	57.19-7-14	Connection	Wye	Clarence issued. DSM inspected.

5	10	9/15/2025 14:00	CP0504368	5182	Kandefer's Trail	Clarence	Clarence Iss	New	Residential Single Unit	57.19-7-18	Connection	Wye	Clarence issued. DSM inspected.
5	10	9/23/2025 11:00	CP0504373	8563	Shardale Dr	Williamsville	Clarence Iss	New	Residential Single Unit	70.07-8-2	Connection	Wye	Clarence issued. DSM inspected.

ERIE COUNTY - SEWER DISTRICT 1,4,5
9/1/2025 TO 9/30/2025
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	0	5	5
Taps	0	1	2	3
Disconnect	0	0	1	1
Repair	2	13	2	17
TOTAL	2	14	10	26

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	1	2	2	5
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	2	0	5	7
Exist Residential (ER)	0	1	0	1
TOTAL	3	3	7	13

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	2	0	2
Exist Commercial Issued (EC)	1	0	0	1
New Residential Issued (NR)	1	1	0	2
Exist Residential Issued (ER)	2	13	3	18
TOTAL	4	16	3	23

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$0	\$2,054	\$0	\$2,054
Exist Commercial Fees (EC)	\$2	\$0	\$0	\$2
New Residential Fees(NR)	\$702	\$702	\$0	\$1,404
Exist Residential Fees (ER)	\$4	\$376	\$6	\$386
TOTAL	\$708	\$3,132	\$6	\$3,846

September 2025 Maintenance

District 1

Mowed and weed whacked 4 different times.
Replaced rotted drain line on Borden pump #1 volute.
Repaired leaking check valve on Borden pump #1.
Bled pump #2 at Industrial Park.
Washed Industrial Park dry well floor.
Cleaned out dry well sump crocks at Industrial Park and Cayuga.
Cleaned brush out of fencing at Clinton and Borden stations.
Removed dead vegetation from rocks at Union.
Cleaned and restocked bathrooms at Cayuga and Industrial Park.
Installed new wet well lights at IPP.
Began repairing the alternator at Forestream.
Went to Cayuga 6 times to meet contractors for RTU bid.

District 4

Mowed and weed whacked 5 different times.
Pulled and cleaned pump #1 at Bowmansville 6 different times.
Prepped and painted exterior of building at Vanderbilt.
Picked up repaired mower from Landpro and returned to station.
Washed dry well floor at Depew.
Painted I beam on exterior of buildings at Warner and Bowmansville.
Cleaned out dry well sump crock at Depew.
Cleaned brush out of fencing at Aurora South and Warner.
Cleaned and restocked bathroom at Depew.
Replaced breaker on Iroquois Genset.
Installed new soft starts at Bowmansville.
Load tested battery on Haskell's genset per Penn Power's recommendation.
Replaced leaking radiator at Pleasantview.
Replaced battery and air filter on Clinton genset per Penn Power's recommendation.
Shutdown Zoeller twice for service upgrade.
Replaced switches in Depew's main room for lights.

District 5

Installed new power pack on Stahley muffin monster and put back in service.

Removed broken well pump at CRP for replacement.

Cleaned and restocked station bathrooms at Eastern Hills and Stahley.

Replaced battery and Air filter at Stahley per Penn Power's recommendation.

Replaced battery at Bryant per Penn Power's recommendation.

All Districts

Checked all fluids in station generators.

Picked up station fire extinguishers and brought to base for inspection.

2025 SEPTEMBER TELEVISION DISTRICT # 1 (CMTV)

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10195332	09/16/2025	TELEVISION BROADWAY 10" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB42A	312
10194590	09/16/2025	TELEVISION BROADWAY 10" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB42B	351
10195368	09/16/2025	TELEVISION BROADWAY 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB41A	206
10195367	09/15/2025	TELEVISION BROADWAY 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB41C	282
10195366	09/15/2025	TELEVISION BROADWAY 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB41D	271
10195365	09/15/2025	TELEVISION BROADWAY 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB41E	318
10194387	09/04/2025	TELEVISION BROADWAY 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB427	372
10194386	09/03/2025	TELEVISION BROADWAY 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB428	207
10195381	09/17/2025	TELEVISION BROADWAY 10" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB429	295
10194591	09/16/2025	TELEVISION BROADWAY 10" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB42C	259
10195380	09/17/2025	TELEVISION BROADWAY 10" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB42D	068
10194567	09/09/2025	TELEVISION BROADWAY 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB42E	094
10195333	09/11/2025	TELEVISION BROADWAY 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB439	344
10195334	09/11/2025	TELEVISION BROADWAY 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB43A	285
10195341	09/11/2025	TELEVISION BROADWAY 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB43B	279
10195342	09/11/2025	TELEVISION BROADWAY 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB43C	291
10195343	09/12/2025	TELEVISION BROADWAY 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB43D	328
10195345	09/12/2025	TELEVISION BROADWAY 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB43E	304
10194388	09/04/2025	TELEVISION BROADWAY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB43F	357
10194450	09/05/2025	TELEVISION BROADWAY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB440	272
10194451	09/05/2025	TELEVISION BROADWAY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB442	252
10194473	09/08/2025	TELEVISION BROADWAY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB443	355
10194474	09/08/2025	TELEVISION BROADWAY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB444	316
10194592	09/11/2025	TELEVISION BROADWAY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB449	307
10194557	09/09/2025	TELEVISION BROADWAY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB44A	320
10194568	09/09/2025	TELEVISION BROADWAY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB44B	160

10195364	09/15/2025	TELEVISION BROADWAY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB44F	290
10195362	09/15/2025	TELEVISION BROADWAY 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB450	312
10195361	09/12/2025	TELEVISION BROADWAY 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB451	292
10195360	09/12/2025	TELEVISION BROADWAY 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB452	355
10195377	09/23/2025	TELEVISION BROADWAY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB454	064
10195373	09/24/2025	TELEVISION UNION 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB457	090
10195374	09/24/2025	TELEVISION UNION 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB458	197
10195372	09/24/2025	TELEVISION UNION 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB459	186
10195371	09/24/2025	TELEVISION BROADWAY 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB45A	089
10195370	09/24/2025	TELEVISION BROADWAY 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB45B	228
10195379	09/18/2025	TELEVISION BROADWAY 8" PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB460	310
10195378	09/18/2025	TELEVISION BROADWAY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB461	216
10195497	09/26/2025	TELEVISION UNION 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB462	330
10195493	09/30/2025	TELEVISION UNION 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB463	338
10195492	09/30/2025	TELEVISION UNION 10" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB469	348
10195363	09/15/2025	TELEVISION BROADWAY 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	14AC5E	037

2025 SEPTEMBER TELEVISIONING DISTRICT # 4 (CMTV)

NONE

2025 SEPTEMBER TELEVISIONING DISTRICT # 5 (CMTV)

NONE

COMPLAINT SUMMARY ECSD # 1 SEPTEMBER 2025

Notification	DATE	Description	Prob. code text	Functional Loc.
10195401	09/30/2025	WATER IN BSMT 1540 SENECA CK W SENECA	FOLLOW-UP REQUIRED	E-S-N01-C-011-SL
10194400	09/03/2025	ODOR COMPLAINT - CASIMIR ST/ELECTRIC AVE	ODOR	E-S-N01-C-012-MH

COMPLAINT SUMMARY ECSD # 4 SEPTEMBER 2025

10194490	09/10/2025	ODOR COMPLAINT - MANHOLE 631 AURORA ST	ODOR	E-S-N04-C-013-SL
10194479	09/19/2025	ODOR - 150 SIEBERT RD, LANCASTER	ODOR	E-S-N04-C-015-SL
10194596	09/18/2025	ODOR COMPLAINT - MANHOLE 26 CAMBRIDGE CT	ODOR	E-S-N04-C-015-SL

COMPLAINT SUMMARY ECSD # 5 SEPTEMBER 2025

10194486	09/11/2025	ODOR COMPLAINT - 8092 STAHLEY RD	HOMEOWNER'S PROBLEM	E-S-N05-C-002-SL
----------	------------	----------------------------------	---------------------	------------------

ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
OCTOBER 2025 MONTHLY OPERATION REPORT

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTALS	0	0	0
	0		

UFPO's	D1	D4	D5
Responses	183	354	136
Stakeouts	56	64	32
TOTAL STAKEOUTS	152		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	3,712	235	1,398	5,345

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint	2,465	0	0	2,465
By District	943	0	0	943

	D1	D4	D5	TOTALS
House Inspections				0
Reinspections				0
Violations				0
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
	117	0	0	117

Manhole Repairs	D1	D4	D5	TOTAL
	6	3	0	9

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control	0	0	0	0
Mechanical Root Cut	250	0	0	250
Mechanically Cleaned	0	0	0	0

Sewerline Repairs	NONE
SSO	3270 CLINTON (DISTRICT 1)
	29 GREEN MEADOW (DISTRICT 4)

CONSTRUCTION		
D1	D4	D5
4814 TRANSIT	BIG DITCH	HARRIS HILL MIXED USE SITE
GARY LN. 2 LOT SUB.	BRADLEY EXTENSION	7149 TRANSIT
SONWIL WAREHOUSE	NEXTERA ENERGY TRANS.	6625 TRANSIT MIXED USE
160 EMPIRE AGILE STORAGE	ANGRY BUFFALO	LEGACY WOODS PS
UPSTATE NIAGARA 3300 N.AMERICA	4106 WALDEN WAREHOUSE	JAMES RYAN PKWY
2715 & 2725 CAR WASH -UNION	VALVOLINE OIL CHANGE	6260 GOOD RICH SANTORAS
UPSTATE NIAGARA 3300 N.AMERICA	4510 BROADWAY APARTMENTS	KRAUS RD. EXTENSION
	5841 GENESEE SHOP	5205 TRANSIT SHAKE SHACK
	WOOD SPRING EXTENSION	
	3825 BOWTIE PARK	
	NEXTERA ENERGY TRANS.	
Plans Reviewed:	NONE	

OCTOBER 2025 I & I DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE
10161372	10/01/2025	MANHOLE REPAIR @ 449 BORDEN RD	RAISED MANHOLE(4)	E-S-N01-C-007-MH	BA707
10195385	10/06/2025	MANHOLE REPAIR @ AUDET	REPAIRED CONE/BARREL JOINT LEAKS, SEV(5)	E-S-N01-C-005-MH	BAC57
10195382	10/06/2025	MANHOLE REPAIR @ AUDET	REPAIRED FRAME JOINT LEAKS, MOD(4)	E-S-N01-C-005-MH	BAC5F
10195513	10/08/2025	REPAIR MANHOLE @ 2735 CLINTON ST	REPAIRED FRAME JOINT LEAKS, MOD(4)	E-S-N01-C-008-MH	BAF7F
10194609	10/09/2025	MANHOLE REPAIR @ 41 DENISE	REPAIRED FRAME, NOT JOINT LEAKS, MOD(4)	E-S-N01-C-005-MH	BBD38
10161372	10/01/2025	MANHOLE REPAIR @ 449 BORDEN RD	REPLACED FRAME AND COVER(5)	E-S-N01-C-007-MH	BA707

OCTOBER 2025 I & I DISTRICT # 4

10195398	10/29/2025	MANHOLE REPAIR @ GENESEE STREET	REPLACED FRAME AND COVER(5)	E-S-N04-C-001-MH	DE554
10195582	10/23/2025	LOCATE / RAISE MANHOLE @ 17 CHESNUT COR	REPLACED FRAME AND COVER(5)	E-S-N04-C-015-MH	DEC4D
10195582	10/23/2025	LOCATE / RAISE MANHOLE @ 17 CHESNUT COR	RAISED MANHOLE(4)	E-S-N04-C-015-MH	DEC4D

OCTOBER 2025 I & I DISTRICT # 5

NONE

2025 October UFPO Numbers

(By District/Region)

Total UFPO Tickets:	2190
Tickets Outside ECSD Boundary	367

	Total Tickets	APR Code		Other APR Codes	Total %
		10 - All Clear	30 - Staked Out	31	
District 1	183	127	56		8%
District 4	354	290	64		16%
District 5	136	104	32		6%
Total NR	673	521	152		31%

District 3	712	578	134		33%
District 6	103	69	34		5%
District 8	133	123	10		6%
Total CR	948	770	178		43%

District 2	202	119	83		9%
Total SR	202	119	83		9%

Totals:	1823	1410	413	
---------	------	------	-----	--

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	17-Oct	2019		12	103	57	77		X	135
Cayuga	1	Under Generator	1300	33	39.39	15-Oct	839		33	1300	100	0		-	975
Clinton	1	Under Generator	150	24	6.25	17-Oct	1941		15	94	63	56		X	113
Industrial Parkway	1	Under Generator	700	30	23.33	17-Oct	710		26	607	87	93		-	525
Union	1	Under Generator	400	26	15.38	17-Oct	170		23	354	88	46		-	300
Aurora North	4	Under Generator	325	24	13.54					0	0	325		X	244
Aurora South	4	Under Generator	285	21	13.57	17-Oct	1791		15	204	71	81		X	214
Bowmansville	4	Under Generator	700	26	26.92	17-Oct	949		22	592	85	108		-	525
Broadway	4	Above-Ground	1000	36	*	15-Oct	317		31	743	74	257		X	750
Depew	4	Above-Ground	3000	69	*	15-Oct	499		51	2230	74	770		X	2250
Iroquois	4	Under Generator	295	17	17.35	17-Oct	1116		11	191	65	104		X	221
Vanderbilt	4	Above-Ground	1000	36	*	15-Oct			30	743	74	257		X	750
Warner	4	Under Generator	700	26	26.92	17-Oct	1888		22	592	85	108		-	525
Bryant	5	Under Generator	180	22	8.18	17-Oct	698		17	139	77	41		-	135
Pinebreeze	5	Under Generator	275	44	*	17-Oct	1328		40	259	94	16		-	206
Stahley	5	Under Generator	150	25	6.00	17-Oct	1585		19	114	76	36		-	113
Transit Valley	5	Above Ground	275	44	*	17-Oct	56		36	235	85	40		-	206

* Calculated

Refill at: 0.75

Month:	October	2025	NR NOVEMBER 2025 FLOW SUMMARY			
Station	SD	Total	Daily Avg	GPM	GPH	Tot Gal
		Hrs				
Borden-Clinton	1	598	19.3	200	12000	7,176,000
Cayuga	1	451	14.5	1190	71400	25,404,120
Clint-Tran	1	56	1.8	350	21000	1,169,700
Industrial Park	1	185	6.0	3650	219000	45,652,740
Union	1	60	1.9	850	51000	3,075,300
Woodlands	1	15	0.5	39	2340	35,100
Aurora South	4	41	1.3	705	42300	1,713,150
Bowmansville	4	355	11.5	1600	96000	34,080,000
Broadway	4	3	0.1	16000	960000	2,880,000
Depew	4	947	30.5	11000	660000	391,875,000
Forestream	4	58	1.9	1050	63000	3,635,100
Hall	4	72	2.3	130	7800	560,040
Haskell	4	21	0.7	590	35400	729,240
Iroquois	4	816	26.3	3000	180000	146,952,000
Pleasantview	4	134	4.3	950	57000	7,649,400
Vanderbilt	4	6	0.2	8000	480000	2,880,000
Warner	4	485	15.6	5000	300000	145,500,000
Zoeller	4	233	7.5	830	49800	11,618,340
Bryant	5	148	4.8	600	36000	5,335,200
Eastern Hills	5	172	5.6	625	37500	6,453,750
Forestview	5	27	0.9	554	33240	887,508
Creekwood	5	54	1.7	509	30540	1,649,160
Pinebreeze	5	52	1.7	325	19500	1,021,800
Stahley	5	67	2.2	720	43200	2,881,440
Transit Valley	5	103	3.3	450	27000	2,770,200
Total NR Flow:					853,584,288	

DISTRICT 1

CONNECTIONS/PERMITS

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
	10/29/2025								
1	13:30	CP0101869	773	Borden Rd	Cheektowaga	Existing	Residential Multiple Units	114.20-6-12.1	Repair
	10/9/2025								
1	13:30	CP0103234	28	Davidson Dr	Cheektowaga	Existing	Residential Single Unit	114.20-6-16	Repair
	10/24/2025								
1	14:00	CP0104689	63	Mayberry Dr W	Cheektowaga	Existing	Residential Single Unit	125.09-2-33	Repair
	10/9/2025								
1	11:00	CP0107835	96	Penwood Dr	Cheektowaga	New	Residential Single Unit	125.07-11-5	Connection
	10/3/2025								
1	10:30	CP0103505	2970	William St	Cheektowaga	Existing	Residential Single Unit	113.15-1-4	Repair
	10/7/2025								
1	14:00	CP0101067	4184	Clinton St	West Seneca	Existing	Residential Multiple Units	125.18-2-19.1	Repair
	10/3/2025								
1	14:00	CP0111944	160	Empire Dr	West Seneca	Existing	Non-Residential Single Unit	124.15-2-4	Repair
	10/2/2025			Indian Church					
1	13:30	CP0109615	795	Rd	West Seneca	Existing	Non-Residential Single Unit	134.06-2-27	Repair
	10/31/2025						Non-Residential Multiple		
1	12:00	CP0111948	1540	Seneca Creek Rd	West Seneca	Existing	Units	126.17-2-22.1	Repair

DISTRICT 4

CONNECTIONS/PERMITS

District	Insp Date	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
	10/29/2025								
4	13:00	CP0410039	54	Albert St	Depew/Chktg	Existing	Residential Single Unit	93.13.-9-12	Repair
	10/23/2025						Residential Multiple	319 Bellevue	
4	10:00	CP0410038	319	Bellevue Ave	Depew/Chktg	Existing	Units	Ave	Repair
	10/23/2025								
4	11:00	CP0410042	114	Morris Cir	Depew/Chktg	Existing	Residential Single Unit	103.08-7-25	Repair
	10/27/2025								
4	13:30	CP0410044	847	Sherwood Ct	Depew/Chktg	Existing	Residential Single Unit	103.07-7-29.1	Repair

4	10/24/2025	10:30	CP0410043	19	Darwin Dr	Depew/Lanc	Existing	Residential Single Unit	93.17-5-40	Repair
4	10/28/2025	10:00	CP0410045	23	Kibler Dr	Depew/Lanc	Existing	Residential Single Unit	93.13-2-28	Repair
4	10/29/2025	13:30	CP0409818	224	Cemetery Rd	Lancaster (T)	New	Non-Residential Single Unit	105.00-1-23.12	Connection
4	10/15/2025	13:30	CP0406597	17	Foxwood Row	Lancaster (T)	Existing	Residential Multiple Units	126.46-1-31	Repair
4	10/21/2025	11:00	CP0406703	5167	Genesee St	Lancaster (T)	Existing	Residential Single Unit	93.05-2-8	Repair
4	10/1/2025	10:30	CP0409860	3	Hickory Ln	Lancaster (T)	New	Residential Single Unit	116.18-1-12	Connection
4	10/27/2025	14:00	CP0409855	28	Sagebrush Ln	Lancaster (T)	New	Residential Single Unit	126.08-4-9	Connection
4	10/10/2025	13:00	CP0403103	39	Southpoint Dr	Lancaster (T)	Existing	Residential Single Unit	126.10-3-17	Repair
4	10/24/2025	13:00	CP0403105	41	Southpoint Dr	Lancaster (T)	Existing	Residential Single Unit	126.10-3-16	Repair
4	10/14/2025	11:00	CP0410022	5	Via Tripodi	Lancaster (T)	Existing	Residential Single Unit	115.14-10-15	Repair
4	10/27/2025	11:00	CP0410036	4106	Walden Ave	Lancaster (T)	New	Non-Residential Single Unit	94.00-4-7.1	Connection
4	10/6/2025	13:00	CP0409819	50	Ward Rd	Lancaster (T)	New	Non-Residential Single Unit	95.00-4-39	Connection
4	10/1/2025	13:00	CP0409277	73	6th Ave	Lancaster (V)	Existing	Residential Single Unit	115.11-7-28	Repair
4	10/8/2025	13:30	CP0409343	19	Washington St	Lancaster (V)	Existing	Residential Multiple Units	104.84-1-18	Repair
4	10/29/2025	9:30	CP0410037	15	Wayne St	Lancaster (V)	Existing	Residential Multiple Units	104.15-1-20	Repair

DISTRICT 5

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit #	Street	Town	New/Existing	Property Type	SBL	Permit Type	
5	10/1/2025 13:15	Final	CP050438 4	1066 8	Main St	Clarence	Existing	Residential Single Unit	72.06-6-18	Disconnect

5	10/8/2025		CP050016									
	11:00	Final	6	8040	Miles Rd	Clarence	Existing	Residential Single Unit	43.05-2-13	Repair		
5	10/23/2025		CP050138									
	13:30	Final	0	6192	Shamrock Ln	Clarence	Existing	Residential Single Unit	43.15-1-34	Repair		
5	10/17/2025		CP050092					Non-Residential Single Unit	29.01-1-17	Repair		
	11:00	Final	0	7041	Transit Rd	Clarence	Existing					
5	10/14/2025		CP050056		Walnut Creek							
	14:00	Final	5	6157	Ct	Clarence	Existing	Residential Single Unit	43.14-7-24	Repair		

DISTRICT 5 CLARENCE TOWN DISTRICTS

District	CT D	Insp Date	Permit	#	Street	Town	Permit Subtype	New/Existing	Property Type	SBL	Permit Type	Tap Type	Comments
5	2	10/20/2025 14:00	CP050436 5	5631	Dorothy Circle	Clarence Center	Clarence Iss	New	Residential Single Unit	58.10-5-32	Connection	Wye	Clarence issued. DSM inspected.
5	2	10/21/2025 13:00	CP050437 6	5672	Dorothy Circle	Clarence Center	Clarence Iss	New	Residential Single Unit	58.10-5-7	Connection	Wye	Clarence issued. DSM inspected.
5	2	10/23/2025 13:00	CP050437 0	5676	Dorothy Circle	Clarence Center	Clarence Iss	New	Residential Single Unit	58.10-5-8	Connection	Wye	Clarence issued. DSM inspected.
5	4	10/14/2025 13:00	CP050435 2	9712	Longleaf Trail	Clarence	Clarence Iss	New	Residential Single Unit	58.16-4-8	Connection	Wye	Clarence issued. DSM inspected.
5	4	10/16/2025 13:00	CP050436 6	9719	Longleaf Trail	Clarence	Clarence Iss	New	Residential Single Unit	58.16-4-18	Connection	Wye	Clarence issued. DSM inspected.
5	4	10/29/2025 11:00	CP050437 7	5531	Serenity Ct	Clarence	Clarence Iss	New	Residential Single Unit	58.15-10-10	Connection	Wye	Clarence issued. DSM inspected.
5	6	10/3/2025 11:00	CP050437 2	5323	Briannas Nook	Clarence	Clarence Iss	New	Residential Single Unit	58.17-13-1	Connection	Wye	Clarence issued. DSM inspected.
5	##	10/10/2025 13:30	CP050437 5	5153	Kandefers Trail	Williamsville	Clarence Iss	New	Residential Single Unit	57.19-7-7	Connection	Wye	Clarence issued. DSM inspected.

ERIE COUNTY - SEWER DISTRICT 1,4,5
10/1/2025 TO 10/31/2025
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	0	2	8	10
Taps	0	0	0	0
Disconnect	0	0	1	1
Repair	8	14	4	26
TOTAL	8	16	13	37

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	2	0	2
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	1	2	8	11
Exist Residential (ER)	0	0	0	0
TOTAL	1	4	8	13

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	2	0	2
Exist Commercial Issued (EC)	2	0	3	5
New Residential Issued (NR)	1	13	1	15
Exist Residential Issued (ER)	6	16	3	25
TOTAL	9	31	7	47

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$0	\$804	\$0	\$804
Exist Commercial Fees (EC)	\$4	\$0	\$806	\$810
New Residential Fees(NR)	\$352	\$9,126	\$702	\$10,180
Exist Residential Fees (ER)	\$12	\$32	\$6	\$50
TOTAL	\$368	\$9,962	\$1,514	\$11,844

October 2025 Maintenance

District 1

Mowed and weed whacked 3 different times.

Cleaned interior of stations at Union, Nash rd., Mineral Springs, Borden, Clinton, and Cayuga.

Cleaned up leaves where needed at stations.

Repaired leaking check valve #2 at Borden.

Replaced thermostats, alternator, and coolant on Forestream generator.

Recalibrated level sensor at Empire.

Repaired washdown/ creek pump controls at Cayuga twice.

Improved valve control at Cayuga.

District 4

Mowed and weed whacked 3 different times.

Cleaned interior of stations at Bowmansville, Pleasantview, Haskell, Warner, Iroquois, Vanderbilt, Depew, Broadway, Aurora South, and Zoeller.

Pulled and cleaned pump #1 at Bowmansville 3 different times.

Repaired mower deck on zero turn mower.

Pulled and checked pump #2 at Iroquois.

Did prep work for removing generator from building at Broadway.

Cleaned up leaves at stations where needed.

Winterized cooling tower at base.

Installed new retaining rings on fleet snowplows.

Replaced access cover on base 4 genset.

Started Zoeller pump station on new electrical service/ genset.

Replaced head gaskets on Bowmansville genset

Replaced soft starts at Bowmansville.

Wired up "Deragger" function at Bowmansville.

Repaired door switch on NR56.

Replaced all fuel injectors in Depew Genset.

Replaced transducer at Iroquois.

Improved valve control at Depew.

Replaced Phase Monitor in Warner ATS.

2025 OCTOBER TELEVISION DISTRICT #1 (CMTV)

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10195499	10/06/2025	TELEVISION WILLIAM 10" ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	EA607	388
10195560	10/06/2025	TELEVISION WILLIAM 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6B9	250
10195561	10/06/2025	TELEVISION LUDWIG 8"PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB4A3	107
10195562	10/06/2025	TELEVISION LUDWIG 8"PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB4A4	387
10195563	10/07/2025	TELEVISION LUDWIG 8"PVC	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB4A5	416
10195496	10/03/2025	TELEVISION WILLIAM 10" PVC/ ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6BE	264
10195545	10/10/2025	TELEVISION CAYUGA CREEK 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	BB6C7	333
10195498	10/03/2025	TELEVISION WILLIAM 10" ACP	TELEVISIONED - (CM)	E-S-N01-C-001-SL	EA608	070
10195526	10/10/2025	TELEVISION S. SEINE 8" VTP	TELEVISIONED - (CM)	E-S-N01-C-005-SL	BBE0E	250

2025 OCTOBER TELEVISION DISTRICT #4(CMTV)

NONE

2025 OCTOBER TELEVISION DISTRICT #5 (CMTV)

NONE

2025 OCTOBER MECHANICAL ROOTCUT DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10195526	10/10/2025	TELEWISE S. SEINE 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-005-SL	BBE0E	250

2025 OCTOBER MECHANICAL ROOTCUT DISTRICT # 4

NONE

2025 OCTOBER MECHANICAL ROOTCUT DISTRICT # 5

NONE

2025 OCTOBER TELEVISIONING DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10123462	10/01/2025	TELEVISION, BORDEN/FRENCH 8" VTP	TELEVISIONED - (D)	E-S-N01-C-007-SL	BB89A	261
10195613	10/27/2025	TELEVISION EMPIRE	TELEVISIONED - (D)	E-S-N01-C-009-SL	BC0C5	335
10195399	10/01/2025	TELEVISION BORDEN 8" ACP	TELEVISIONED - (D)	E-S-N01-C-011-SL	BC396	318
10195440	10/01/2025	TELEVISION SENECA CREEK 8" ACP	TELEVISIONED - (D)	E-S-N01-C-011-SL	1067	029

2025 OCTOBER TELEVISIONING DISTRICT # 4

NONE

2025 OCTOBER TELEVISIONING DISTRICT # 5

NONE

COMPLAINT SUMMARY ECSD # 1 OCTOBER 2025

Notification	DATE	Description	Prob. code text	Functional Loc.
10195500	10/06/2025	ODOR - MANHOLE 17 BELLEVUE AVE	ODOR	E-S-N01-C-001-MH
10195558	10/14/2025	MANHOLE LIFTED 122 BARBADOS DR	HOMEOWNER'S PROBLEM	E-S-N01-C-002-MH
10195524	10/08/2025	SEWER BACKUP UP - 64 S SEINE DR	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-005-SL
10196293	10/22/2025	SEWER BACKUP - 38 GARY LN, CHEEKTOWAGA	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-007-SL
10196363	10/31/2025	SEWER BACKUP - 202 AUTUMNWOOD, CHEEKTOWA	BASEMENT FACILITY	E-S-N01-C-007-SL
10196364	10/31/2025	SEWER BACKUP - 42 FRENCH LEA, W SENECA	BASEMENT FACILITY	E-S-N01-C-007-SL
10196294	10/22/2025	EMPIRE DR MANHOLE - EMPIRE DR	OVERFLOW	E-S-N01-C-009-MH
10195614	10/20/2025	BACK UP - 75 EMPIRE DR, WEST SENECA	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N01-C-009-SL

COMPLAINT SUMMARY ECSD # 4 OCTOBER 2025

10196500	10/27/2025	WHOLE HOUSE BLOCKAGE 5167 GENESEE	NO FURTHER WORK REQUIRED	E-S-N04-C-001-SL
10196377	10/30/2025	SEWER BACKUP - 31 GREENMEADOW, LANCASTER	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N04-C-003-SL
10196378	10/30/2025	SEWER BACKUP - 72 GREENMEADOW, LANCASTER	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N04-C-003-SL
10195633	10/21/2025	FOUL ODOR FROM MANHOLE 2 BRANCH WAY	ODOR	E-S-N04-C-015-SL

COMPLAINT SUMMARY ECSD # 5 OCTOBER 2025

10195544	10/13/2025	ODOR - MANHOLE 5885 FOREST CREEK RD	ODOR	E-S-N05-C-005-MH
----------	------------	-------------------------------------	------	------------------

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
NOVEMBER 2025 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTALS	0	0	0
	0		

UFPO's	D1	D4	D5
Responses	149	184	87
Stakeouts	46	55	15
TOTAL STAKEOUTS	116		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	796	504	7,308	8,608

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint				0
By District	521	362	237	1,120

	D1	D4	D5	TOTALS
House Inspections				0
Reinspections				0
Violations				0
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
	25	0	0	25

Manhole Repairs	D1	D4	D5	TOTAL
	8	2	0	10

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control				0
Mechanical Root Cut	358	0	0	358
Mechanically Cleaned				0

Sewerline Repairs	D4 MS 1- GENESEE-DF65F
SSO NONE	

CONSTRUCTION		
D1	D4	D5
4814 TRANSIT	BIG DITCH	HARRIS HILL MIXED USE SITE
GARY LN. 2 LOT SUB.	BRADLEY EXTENSION	7149 TRANSIT
SONWIL WAREHOUSE	NEXTERA ENERGY TRANS.	6625 TRANSIT MIXED USE
160 EMPIRE AGILE STORAGE	ANGRY BUFFALO	LEGACY WOODS PS
UPSTATE NIAGARA 3300 N.AMERICA	4106 WALDEN WAREHOUSE	JAMES RYAN PKWY
2715 & 2725 CAR WASH-UNION	VALVOLINE OIL CHANGE	6260 GOOD RICH SANTORAS
UPSTATE NIAGARA 3300 N.AMERICA	4510 BROADWAY APARTMENTS	KRAUS RD. EXTENSION
395 WEST AVE.	5841 GENESEE SHOP	5205 TRANSIT SHAKE SHACK
	WOOD SPRING EXTENSION	
	3825 BOWTIE PARK	
	NEXTERA ENERGY TRANS.	
	4412 JAGG ELECTRIC	
PLAN REVIEWS	ALDEN GROW FACILITY	

NOVEMBER 2025 I&I DISTRICT #1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE
10187339	11/14/2025	INSTALL INFLOW PROTECTOR @ CENTRAL	INSTALLED INFLOW PROTECTOR (4)	E-S-N04-C-005-MH	EABB7
10197362	11/28/2025	MANHOLE REPAIR @ 4950 CLINTON	RAISED MANHOLE(4)	E-S-N01-C-009-MH	BA776
10196393	11/21/2025	MANHOLE REPAIR @ BARBADOS	REPAIRED FRAME JOINT LEAKS, MOD(4)	E-S-N01-C-002-MH	BAB4E
10196613	11/19/2025	MANHOLE REPAIR @ CLINTON	REPAIRED FRAME JOINT LEAKS, SEV(5)	E-S-N01-C-008-MH	BAF74
10196392	11/21/2025	MANHOLE REPAIR @ JEROME	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-002-MH	BAB38
10196403	11/21/2025	MANHOLE REPAIR @ JEROME	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-002-MH	BAB37
10196402	11/21/2025	MANHOLE REPAIR @ JEROME	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-002-MH	BAB36
10195632	11/13/2025	MANHOLE REPAIR @ BORDEN	REPLACED FRAME AND COVER(5)	E-S-N01-C-009-MH	BA76B

NOVEMBER 2025 I&I DISTRICT #4

10196484	11/05/2025	CLEANOUT REPAIR @ 5167 GENESEE	PIPE REPLACED - 8"	E-S-N04-C-001-SL	DF65F
10184208	11/14/2025	MANHOLE REPAIR @ 31 TRENTWOOD	REPAIRED FRAME JOINT LEAKS, MOD(4)	E-S-N04-C-006-MH	DEFD7
10196422	11/04/2025	MANHOLE REPAIR / CLEANOT @ SENECA PL	REPAIRED FRAME JOINT LEAKS, MOD(4)	E-S-N04-C-006-MH	DEFC4

NOVEMBER 2025 I&I DISTRICT #5

NONE

COMPLAINT SUMMARY ECSD # 1 NOVEMBER 2025

Notification	DATE	Description	Prob. code text	Functional Loc.
10196419	11/02/2025	SEWER BACKUP - 62 JOEL DR, DEPEW	BASEMENT FACILITY	E-S-N01-C-004-SL
10197333	11/25/2025	BACK UP IN BSMT 63 ELECTRIC AVE	FLUSHED LINE/NO BLOCKAGE	E-S-N01-C-012-SL

COMPLAINT SUMMARY ECSD # 4 NOVEMBER 2025

10196496	11/11/2025	SEWER BACKUP - 33 CHARLTON PL, LANCASTER	BASEMENT FACILITY	E-S-N04-C-005-SL
10196539	11/12/2025	SEWER BACKUP - 3656 WALDEN AVE, LANCASTE	HOMEOWNER'S PROBLEM	E-S-N04-C-005-SL
10196522	11/07/2025	SEWER BACKUP - 2 JMUIRFIELD	HOMEOWNER'S PROBLEM	E-S-N04-C-014-SL
10196562	11/13/2025	SEWER BACKUP - 225 SIEBERT RD, LANCASTER	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N04-C-015-SL
10197332	11/25/2025	SEWAGE COMING OUT CLEAN OUT 712 AURORA	HOMEOWNER'S PROBLEM	E-S-N04-C-015-SL

COMPLAINT SUMMARY ECSD # 5 NOVEMBER 2025

NONE

2025 NOVEMBER MECHANICAL ROOTCUT DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10196424	11/7/2025	TELEWISE FRENCH LEA 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-007-SL	BBFE6	304
10196365	11/3/2025	TELEWISE FRENCH LEA 8" VTP	MECHANICAL ROOT CUT	E-S-N01-C-007-SL	140A0C	054

2025 NOVEMBER MECHANICAL ROOTCUT DISTRICT # 4

NONE

2025 NOVEMBER MECHANICAL ROOTCUT DISTRICT # 5

NONE

2025 NOVEMBER TELEVISIONING DISTRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10196423	11/03/2025	TELEVISION FRENCH LEA 8" ACP	TELEVISIONED - (D)	E-S-N01-C-007-SL	140A0D	163
10196424	11/07/2025	TELEVISION FRENCH LEA 8" VTP	TELEVISIONED - (D)	E-S-N01-C-007-SL	BBFE6	304
10196365	11/03/2025	TELEVISION FRENCH LEA 8" VTP	TELEVISIONED - (D)	E-S-N01-C-007-SL	140A0C	054

2025 NOVEMBER TELEVISIONING DISTRICT # 4

10196384	11/24/2025	COMPLAINT TELEVISIONING -31 GREENMEADOW DR	TELEVISIONED - (D)	E-S-N04-C-003-SL	DF6DB	235
10196421	11/24/2025	TELEVISION CENTRAL SIDE LOT	TELEVISIONED - (D)	E-S-N04-C-005-SL	F2976	127

2025 NOVEMBER TELEVISIONING DISTRICT # 5

10196553	11/24/2025	TELEVISION SCHURR 8" PVC	TELEVISIONED - (D)	E-S-N05-C-009-SL	10082034	237
----------	------------	--------------------------	--------------------	------------------	----------	-----

2025 November UFPO Numbers

(By District/Region)

Total UFPO Tickets:	1355
Tickets Outside ECSD Boundary	223

	Total Tickets	APR Code		Other APR Codes
		10 - All Clear	30 - Staked Out	31
District 1	149	103	46	
District 4	184	129	55	
District 5	87	72	15	
Total NR	420	304	116	
District 3	483	386	97	
District 6	71	55	16	
District 8	38	27	12	
Total CR	592	468	125	
District 2	120	57	63	
Total SR	120	57	63	
Totals:	1132	829	304	

Month:	NOVEMBER 2025		NR Flow Summary 2025			
Station	SD	Total	Daily Avg	GPM	GPH	Tot Gal
		Hrs				
Borden-Clinton	1	425	13.7	200	12000	5,100,000
Cayuga	1	425	13.7	1190	71400	23,390,640
Clint-Tran	1	52	1.7	350	21000	1,092,000
Industrial Park	1	264	8.5	3650	219000	43,659,840
Union	1	49	1.6	850	51000	2,499,000
Woodlands	1	12	0.4	39	2340	27,612
Aurora South	4	42	1.4	705	42300	1,797,750
Bowmansville	4	460	14.8	1600	96000	44,160,000
Broadway	4	0	0.0	16000	960000	0
Depew	4	745	24.0	11000	660000	308,137,500
Forestream	4	52	1.7	1050	63000	3,282,300
Hall	4	102	3.3	130	7800	792,480
Haskell	4	51	1.7	590	35400	1,816,020
Iroquois	4	613	19.8	3000	180000	110,394,000
Pleasantview	4	132	4.2	950	57000	7,506,900
Vanderbilt	4	2	0.1	8000	480000	960,000
Warner	4	520	16.8	5000	300000	156,000,000
Zoeller	4	197	6.4	830	49800	9,835,500
Bryant	5	109	3.5	600	36000	3,916,800
Eastern Hills	5	147	4.7	625	37500	5,520,000
Forestview	5	27	0.9	554	33240	914,100
Cannonwoods	5	59	1.9	173	10380	608,268
Creekwood	5	49	1.6	509	30540	1,508,676
Pinebreeze	5	53	1.7	325	19500	1,041,300
Stahley	5	68	2.2	720	43200	2,941,920
Transit Valley	5	120	3.9	450	27000	3,248,100
Total NR Flow:					740,150,706	

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	24-Nov	2025		17	146	81	34		-	135
Cayuga	1	Under Generator	1300	33	39.39	20-Nov	842		33	1300	100	0		-	975
Clinton	1	Under Generator	150	24	6.25	24-Nov	1948		20	125	83	25		-	113
Industrial Parkway	1	Under Generator	700	30	23.33	24-Nov	710		27	630	90	70		-	525
Union	1	Under Generator	400	26	15.38	24-Nov	126		25	385	96	15		-	300
Aurora North	4	Under Generator	325	24	13.54					0	0	325		X	244
Aurora South	4	Under Generator	285	21	13.57	24-Nov	1795		18	244	86	41		-	214
Bowmansville	4	Under Generator	700	26	26.92	24-Nov	955		23	619	88	81		-	525
Broadway	4	Above-Ground	1000	36	*	20-Nov	317		31	743	74	257		X	750
Depew	4	Above-Ground	3000	69	*	20-Nov	499		50	2182	73	818		X	2250
Iroquois	4	Under Generator	295	17	17.35	24-Nov	1116		16	278	94	17		-	221
Vanderbilt	4	Above-Ground	1000	36	*	20-Nov			32	743	74	257		X	750
Warner	4	Under Generator	700	26	26.92	24-Nov	1893		23	619	88	81		-	525
Bryant	5	Under Generator	180	22	8.18	24-Nov	698		17	139	77	41		-	135
Pinebreeze	5	Under Generator	275	44	*	24-Nov	1328		39	253	92	22		-	206
Stahley	5	Under Generator	150	25	6.00	24-Nov	1591		24	144	96	6		-	113
Transit Valley	5	Above Ground	275	44	*	24-Nov	60		41	264	96	11		-	206

* Calculated

Refill at: 0.75

DISTRICT 1

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
1	11/21/2025		CP011192						125.08-9-	
1	11:00	Final	8	165	Gary Ln	Cheektowaga	New	Residential Single Unit	20	Connection
1	11/10/2025		CP010670						125.07-2-	
1	13:00	Final	4	88	Knollwood Dr	Cheektowaga	Existing	Residential Single Unit	23	Repair
1	11/14/2025		CP011056						114.02-10-	
1	14:00	Final	6	236	Strasmer Road	Cheektowaga	Existing	Residential Single Unit	29	Repair
1	11/18/2025		CP011195							
1	13:00	Final	0	4884	Clinton St	West Seneca	Existing	Residential Single Unit	5.16-5-27	Connection
1	11/18/2025		CP010951						124.18-7-	
1	14:00	Final	5	38	George Drive	West Seneca	Existing	Residential Single Unit	25	Repair
1	11/7/2025		CP011194					Non-Residential Single		
1	13:00	Final	9	1515	Rd	West Seneca	Existing	Unit	126.17-2-8	Repair
1	11/6/2025		CP010878						135.05-3-	
1	13:00	Final	6	230	Rd	West Seneca	Existing	Residential Single Unit	15	Repair

DISTRICT 4

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
4	11/25/2025					Lancaster		Residential Single		
4	13:00	Final	CP0401384	3710	Bowen Rd	(T)	Existing	Unit	116.14-1-14	Repair
4	11/19/2025					Lancaster		Residential Single	126.10-2-	
4	11:00	Final	CP0405755	5	Cidermill Ct	(T)	Existing	Unit	61/A	Repair
4	11/25/2025					Lancaster		Residential Single		
4	11:00	Final	CP0405371	9	Kelly Ann Dr	(T)	Existing	Unit	94.13-1-11	Repair
4	11/24/2025					Lancaster		Residential Single		
4	14:00	Final	CP0400300	12	Muirfield Ln	(T)	Existing	Unit	116.08-1-9	Repair
4	11/19/2025					Lancaster		Residential Single		
4	13:00	Final	CP0401749	60	Tomahawk Trl	(T)	Existing	Unit	115.15-3-88	Repair
4	11/26/2025					Lancaster		Residential Single		
4	13:45		CP0401236	5302	William St	(T)	Existing	Unit	116.14-1-15	Repair

4	11/3/2025 11:00	Final	CP0410046	18	5th Ave	Lancaster (V)	Existing	Residential Single Unit	115.11-6-14	Repair
4	11/10/2025 14:00	Final	CP0410049	19	Woodlawn Ave	Lancaster (V)	Existing	Residential Single Unit	115.28-5-9	Repair
4	11/13/2025	Final	CP0409592	9	Wren Ave	Lancaster (V)	Existing	Residential Single Unit	104.50-4-1	Repair

DISTRICT 5

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
5	11/24/2025 13:00	Final	CP0504399	5005	Harris Hill Road	Clarence	New	Residential Single Unit	70.07-1-7	Connection
5	11/20/2025 13:00	Final	CP0501663	8260	Lisa Lane	Clarence	Existing	Residential Single Unit	43.14-8-19	Repair
5	11/5/2025 13:00	Final	CP0504353	9808	Longleaf Trail	Clarence	New	Residential Single Unit	58.16-4-4	Connection
5	11/3/2025 13:30	Final	CP0500787	5205	Transit Rd	Clarence	Existing	Non-Residential Single Unit	57.17-5-1.131	Connection

DISTRICT 5 CLARENCE TOWN DISTRICTS

District	CT D	Insp Date	Permit	#	Street	Town	Permit Subtype	New/Existing	Property Type	SBL	Permit Type	Tap Type	Comments
5		11/24/2025 13:00	CP050440	502	Harris Hill Road	Williamsville	Clarence Iss	New	Residential Single Unit	70.07-1-6	Connection	Wye	
4	2	11/17/2025 13:00	CP041003	951	Deer Valley Dr	Clarence Center	Clarence Iss	New	Residential Single Unit	44.11-5-25	Connection		Clarence issued. DSM inspected. Permit was issued in D4, should be D5.
5	2	11/6/2025 14:00	CP050438	952	Deer Valley Dr	Clarence Center	Clarence Iss	New	Residential Single Unit	44.11-5-11	Connection	Wye	Clarence issued. DSM inspected.
5	2	11/26/2025 13:00	CP050438	954	Deer Valley Dr	Clarence Center	Clarence Iss	New	Residential Single Unit	44.11-5-21	Connection	Wye	Clarence issued.. DSM INSPECTED.
5	4	11/19/2025 14:00	CP050437	973	Longleaf Trail	Clarence	Clarence Iss	New	Residential Single Unit	58.16-4-14	Connection		Clarence issued. DSM inspected.
5	4		CP050434	543	Waterlefe Dr	Clarence	Clarence Iss	New	Residential Single Unit	58.15-8-25	Connection	Wye	Clarence issued permit. DSM inspected.
5	10	11/26/2025 11:00	CP050438	513	Kandefer's Trail	Clarence	Clarence Iss	New	Residential Single Unit	57.19-7-13	Connection		Clarence issued. DSM inspected.
5	10	11/5/2025 11:00	CP050437	516	Kandefer's Trail	Williamsville	Clarence Iss	New	Residential Single Unit	57.19-7-6	Connection	Wye	Clarence issued. DSM inspected.

ERIE COUNTY - SEWER DISTRICT 1,4,5
11/1/2025 TO 11/30/2025
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	1	0	7	8
Taps	1	0	0	1
Disconnect	0	0	0	0
Repair	5	8	1	14
TOTAL	7	8	8	23

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	0	0	0	0
Exist Commercial (EC)	0	0	1	1
New Residential (NR)	1	1	9	11
Exist Residential (ER)	1	0	0	1
TOTAL	2	1	10	13

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	0	0	0	0
Exist Commercial Issued (EC)	2	0	0	2
New Residential Issued (NR)	5	8	3	16
Exist Residential Issued (ER)	5	10	1	16
TOTAL	12	18	4	34

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$0	\$0	\$0	\$0
Exist Commercial Fees (EC)	\$4	\$0	\$0	\$4
New Residential Fees(NR)	\$6,410	\$5,616	\$0	\$12,026
Exist Residential Fees (ER)	\$1,610	\$20	\$2	\$1,632
TOTAL	\$8,024	\$5,636	\$2	\$13,662

November 2024 Maintenance

District 1

Mowed and weed whacked 2 different times.
Installed plow stakes at stations for winter season.
Plowed and shoveled snow once.
Reset router at IPP.
Load banked IPP and Cayuga gensets.

District 4

Mowed and weed whacked 2 different times.
Pulled and cleaned pump #1 at Bowmansville 3 different times.
Repaired broken lift bracket on mower #6.
Replaced deck on zero turn mower.
Cleaned, winterized, and stored mowing equipment for the season.
Pulled and cleaned pump #2 at Bowmansville 2 different times.
Prepped plows for the winter season.
Tested bypass pumping at Pleasantview.
Tested bypass pumping at Iroquois.
Tested bypass pumping at Warner.
Installed plow stakes at stations for winter season.
Repaired broken sprinkler line drop in front garage at base.
Plowed and shoveled snow once.
Calibrated gas detectors at NR base.
Traced wiring for PA system at NR base.
Completed portable genset PM's
Began upgrading Soft Starts at Warner.
Temporarily installed WIFI routers at NR base.
Load banked and replaced batteries on Broadway genset.

District 5

Installed ladder in valve pit and changed bypass pumping fitting to bauer style at Cannon Woods.

Installed plow stakes at stations for winter season.

Plowed and shoveled snow once.

Installed reset relays at CRP.

All Districts

Checked all fluids in station generators.

Tested HWW Floats at stations.

**ERIE COUNTY NORTHERN REGION - SEWER DISTRICTS 1, 4 AND 5
DECEMBER 2025 MONTHLY OPERATION REPORT**

INSPECTIONS	D1	D4	D5
MH Connection			
Grinder			
TOTALS			

UFPO's	D1	D4	D5
Responses	122	120	62
Stakeouts	57	42	21
TOTAL STAKEOUTS	120		

Sewer Flushing (feet)	D1	D4	D5	TOTAL
	2,484	375	11,747	14,606

Televising (feet)	D1	D4	D5	TOTALS
By Central Maint	634	0	0	634
By District	0	0	0	0

	D1	D4	D5	TOTALS
House Inspections				0
Reinspections				0
Violations				0
Dye Tests				0

Manhole Inspections	D1	D4	D5	TOTAL
	59	0	0	59

Manhole Repairs	D1	D4	D5	TOTAL
	21	5	0	26

Maintenance (ft)	D1	D4	D5	TOTAL
Chemical Root Control				0
Mechanical Root Cut	0	0	0	0
Mechanically Cleaned				0

Sewerline Repairs	21 GREENMEADOW D4 MS 6 - DF6DB
Sanitary Sewer Overflow	2379 UNION RD. D1 MS 8 MH BA8ED 3254 CLINTON D1 MS 9 MH BB134

CONSTRUCTION		
DISTRICT 1	DISTRICT 4	DISTRICT 5
D1	BRADLEY EXTENSION	HARRIS HILL MIXED USE SITE
4814 TRANSIT	NEXTERA ENERGY TRANS.	7145 TRANSIT
2715 & 2725 CAR WASH -UNION	ANGRY BUFFALO	6625 TRANSIT MIXED USE
SONWIL WAREHOUSE	4106 WALDEN WAREHOUSE	LEGACY WOODS PS
UPSTATE NIAGARA 3300 N.AMERICA	VALVOLINE OIL CHANGE	JAMES RYAN PKWY
395 WEST AVE.	4510 BROADWAY APARTMENTS	6260 GOOD RICH SANTORAS
	5841 GENESSE SHOP	KRAUS RD. EXTENSION
	WOOD SPRING EXTENSION	5695 & 5731 TRANSIT
	3825 BOWTIE PARK	
	NEXTERA ENERGY TRANS.	
	4412 JAGG ELECTRIC	
	ALDEN GROW FACILITY	

Plans Reviewed:	

DECEMBER 2025 I&I DISRICT # 1

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE
10198998	12/23/2025	INSTALL INFLOW PROTECTOR @ EILEEN	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-007-MH	BB14
10198999	12/24/2025	INSTALL INFLOW PROTECTOR @ SUZETTE	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-007-MH	BB392
10199000	12/23/2025	INSTALL INFLOW PROTECTOR @ SUZETTE	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-007-MH	BB38E
10198996	12/23/2025	INSTALL INFLOW PROTECTOR @ ST JUDE	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-009-MH	BB246
10198994	12/23/2025	INSTALL INFLOW PROTECTOR @ KRON	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-009-MH	BB14E
10199001	12/26/2025	INSTALL INFLOW PROTECTOR @ SPRUCEWOOD	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-007-MH	BAD56
10199002	12/26/2025	INSTALL INFLOW PROTECTOR @ SPRUCEWOOD	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-007-MH	BAD55
10199003	12/26/2025	INSTALL INFLOW PROTECTOR @ BRONX	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-007-MH	BAD50
10199004	12/26/2025	INSTALL INFLOW PROTECTOR @ BIRCHWOOD	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-007-MH	BAD1C
10198997	12/24/2025	INSTALL INFLOW PROTECTOR @ FRADINE	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-006-MH	BAC21
10199005	12/26/2025	INSTALL INFLOW PROTECTOR @ FRENCH	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-007-MH	BA6FE
10199006	12/26/2025	INSTALL INFLOW PROTECTOR @ FRENCH	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-007-MH	BA6FA
10199007	12/26/2025	INSTALL INFLOW PROTECTOR @ DEL	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-007-MH	BA6AE
10199008	12/26/2025	INSTALL INFLOW PROTECTOR @ BORDEN	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-007-MH	BA6AA
10199009	12/26/2025	INSTALL INFLOW PROTECTOR @ BRENTWOOD	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-007-MH	1B4E75
10199010	12/26/2025	INSTALL INFLOW PROTECTOR @ BORDEN	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-007-MH	141C4F
10198995	12/23/2025	INSTALL INFLOW PROTECTOR @ CLINTON	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-009-MH	BB283
10199011	12/29/2025	INSTALL INFLOW PROTECTOR @ BRENTWOOD	INSTALLED INFLOW PROTECTOR (4)	E-S-N01-C-007-MH	1B4E74
10196390	12/02/2025	MANHOLE REPAIR @ PARK	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-002-MH	BAAFE
10196425	12/02/2025	MANHOLE REPAIR @ ZURBRICK	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N01-C-004-MH	BA4F6
10196408	12/03/2025	MANHOLE REPAIR @ CLINTON (BURIED)	RAISED MANHOLE(4)	E-S-N01-C-009-MH	14B087

DECEMBER 2025 I&I DISRICT # 4

10121753	12/24/2025	MANHOLE REPAIR @ 101 MAPLE	REPAIRED FRAME JOINT LEAKS, SEV(5)	E-S-N04-C-001-MH	DE509
10185358	12/19/2025	MANHOLE REPAIR @ PLEASANTVIEW	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N04-C-006-MH	728
10187287	12/03/2025	MANHOLE REPAIR @ BROEZEL	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N04-C-005-MH	EAC45
10185359	12/19/2025	MANHOLE REPAIR @ DENTON	REPAIRED FRAME JOINT LEAKS, SLT(3)	E-S-N04-C-006-MH	10072041
10184505	12/19/2025	MANHOLE REPAIR @ CHICORY LN.	RAISED MANHOLE(4)	E-S-N04-C-006-MH	1ABB00
10197363	12/10/2025	SEWER REPAIR @ 21 GREENMEADOW DR	PIPE REPLACED - 8"	E-S-N04-C-003-SL	DF6DB

DECEMBER 2025 I&I DISRICT # 5

NONE

COMPLAINT SUMMARY ECSD # 1 DECEMBER 2025

Notification	DATE	Description	Prob. code text	Functional Loc.
10196283	12/02/2025	STATIONARY TUB BCK UP 51 NANCY PL	HOMEOWNER'S PROBLEM	E-S-N01-C-007-SL
10198786	12/29/2025	BCKUP IN BSMT TOILET 38 GREGORY CT	BASEMENT FACILITY	E-S-N01-C-004-SL
10198794	12/22/2025	TOILETS BACKING UP 55 INNSBRUCK DR	HOMEOWNER'S PROBLEM	E-S-N01-C-008-MH
10198959	12/31/2025	BACK UP - 31 BENZ DR, DEPEW	HOMEOWNER'S PROBLEM	E-S-N01-C-004-SL
10198961	12/28/2025	SEWER BACKUP - 1291 FRENCH RD, CHEEKTOWA	BASEMENT FACILITY	E-S-N01-C-007-SL
10197799	12/19/2025	SEWER BACKUP - 106 NORTH AVE, WS	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-009-SL
10197930	12/13/2025	UFPO - 124 NORTH AVE, WEST SENECA	EMERGENCY UFPO - NOT INVOLVED	E-S-N01-C-009-SL
10198036	12/16/2025	SEWER BACKUP - 2379 UNION RD, CHEEKTOWAG	OVERFLOW OBSERVED	E-S-N01-C-008-SL
10198777	12/19/2025	SEWER BCKUP 106 NORTH AVE W SENECA	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-009-SL
10198778	12/19/2025	SEWER BACKUP - 106 NORTH AVE, WS	MAIN SURCHARGED DUE TO WEATHER	E-S-N01-C-009-SL

COMPLAINT SUMMARY ECSD # 4 DECEMBER 2025

10197461	12/02/2025	SEWER BACKUP - 225 SIEBERT RD, LANCA	FLUSHED LINE/RELIEVED BLOCKAGE	E-S-N04-C-015-SL
10197739	12/12/2025	TROUBLE CALL - 24 GREEN MEADOW DR, LANCA	NO FURTHER WORK REQUIRED	E-S-N04-C-003-SL
10198779	12/25/2025	SEWER BACKUP - 225 SIEBERT RD, LANCASTER	HOMEOWNER'S PROBLEM	E-S-N04-C-015-SL

COMPLAINT SUMMARY ECSD # 5 DECEMBER 2025

NONE

2025 DECEMBER TELEVISION DISTRICT # 1 (CM)

Notification	DATE	Description	Act. code text	Functional Loc.	HANDLE	L/F
10198071	12/17/2025	TELEVISION UNION 8" CIPP/ACP	TELEVISIONED - (CM)	E-S-N01-C-008-SL	BB70B	236
10198039	12/17/2025	TELEVISION UNION 8" CIPP/ACP	TELEVISIONED - (CM)	E-S-N01-C-008-SL	BB70C	236
10198072	12/17/2025	TELEVISION UNION 15"RCP	TELEVISIONED - (CM)	E-S-N01-C-008-SL	BB70A	85
10198070	12/17/2025	TELEVISION UNION 8" CIPP/ACP	TELEVISIONED - (CM)	E-S-N01-C-008-SL	14B0AB	77

2025 DECEMBER TELEVISION DISTRICT # 4 (CM)

NONE

2025 DECEMBER TELEVISION DISTRICT # 5 (CM)

NONE

2025 December UFPO Numbers

(By District/Region)

Total UFPO Tickets:	978
Tickets Outside ECSD Boundary	181

	Total Tickets	APR Code		Other APR Codes	
		10 - All Clear	30 - Staked Out	31	51
District 1	122	65	57		
District 4	120	78	42		
District 5	62	41	21		
Total NR	304	184	120		
District 3	288	187	101		
District 6	86	44	42		
District 8	36	27	9		
Total CR	410	258	152		
District 2	83	37	46		
Total SR	83	37	46		
Totals:	797	479	318		

2005 PS Flows

Month:	NOVEMBER 2025		NR Flow Summary 2025			
Station	SD	Total	Daily Avg	GPM	GPH	Tot Gal
		Hrs				
Borden-Clinton	1	425	13.7	200	12000	5,100,000
Cayuga	1	425	13.7	1190	71400	23,390,640
Clint-Tran	1	52	1.7	350	21000	1,092,000
Industrial Park	1	264	8.5	3650	219000	43,659,840
Union	1	49	1.6	850	51000	2,499,000
Woodlands	1	12	0.4	39	2340	27,612
Aurora South	4	42	1.4	705	42300	1,797,750
Bowmansville	4	460	14.8	1600	96000	44,160,000
Broadway	4	0	0.0	16000	960000	0
Depew	4	745	24.0	11000	660000	308,137,500
Forestream	4	52	1.7	1050	63000	3,282,300
Hall	4	102	3.3	130	7800	792,480
Haskell	4	51	1.7	590	35400	1,816,020
Iroquois	4	613	19.8	3000	180000	110,394,000
Pleasantview	4	132	4.2	950	57000	7,506,900
Vanderbilt	4	2	0.1	8000	480000	960,000
Warner	4	520	16.8	5000	300000	156,000,000
Zoeller	4	197	6.4	830	49800	9,835,500
Bryant	5	109	3.5	600	36000	3,916,800
Eastern Hills	5	147	4.7	625	37500	5,520,000
Forestview	5	27	0.9	554	33240	914,100
Cannonwoods	5	59	1.9	173	10380	608,268
Creekwood	5	49	1.6	509	30540	1,508,676
Pinebreeze	5	53	1.7	325	19500	1,041,300
Stahley	5	68	2.2	720	43200	2,941,920
Transit Valley	5	120	3.9	450	27000	3,248,100
Total NR Flow:						740,150,706

ERIE COUNTY - SEWER DISTRICT 1,4,5
12/1/2025 TO 12/31/2025
OPERATION REPORT

INSPECTIONS	D1	D4	D5	TOTAL
Wyes	1	0	1	2
Taps	0	0	0	0
Disconnect	0	0	0	0
Repair	5	18	2	25
TOTAL	6	18	3	27

CONNECTIONS	D1	D4	D5	TOTAL
New Commercial (NC)	1	0	0	1
Exist Commercial (EC)	0	0	0	0
New Residential (NR)	1	0	2	3
Exist Residential (ER)	0	0	0	0
TOTAL	2	0	2	4

PERMITS	D1	D4	D5	TOTAL
New Commercial Issued (NC)	1	0	0	1
Exist Commercial Issued (EC)	0	1	0	1
New Residential Issued (NR)	1	1	0	2
Exist Residential Issued (ER)	5	22	4	31
TOTAL	7	24	4	35

PERMIT FEES	D1	D4	D5	TOTAL
New Commercial Fees (NC)	\$2,402	\$0	\$0	\$2,402
Exist Commercial Fees (EC)	\$0	\$2	\$0	\$2
New Residential Fees(NR)	\$702	\$2	\$0	\$704
Exist Residential Fees (ER)	\$10	\$44	\$8	\$62
TOTAL	\$3,114	\$48	\$8	\$3,170

DISTRICT 1

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
1	12/5/2025 10:30	Final	CP0102874	395	Como Park Blvd	Cheektowaga	Existing	Residential Multiple Units	114.09-3-10.3	Repair
1	12/2/2025 14:00 12/26/2025	Final	CP0107275	13	Lynnette Ct	Cheektowaga	Existing	Residential Single Unit	125.16-3-3 125.10-18-	Repair
1	13:00 12/18/2025	Final	CP0111958	72	Rachelle Dr	Cheektowaga	Existing	Residential Single Unit	19	Repair
1	13:30	Final	CP0110543	111	Strasmer Rd	Cheektowaga	Existing	Residential Single Unit Non-Residential Single Unit	114.04-5-12	Repair
1	12/5/2025 11:00 12/19/2025	Final	CP0111944	160	Empire Dr	West Seneca	New	Unit	124.15-2-4	Connection
1	12:00 12/18/2025	Final	CP0104747	138	North Ave	West Seneca	Existing	Residential Single Unit	124.20-1-7	Repair
1	13:00	Final	CP0111959	27	Veronica Sr	West Seneca	New	Residential Single Unit	135.07-3-18	Connection

DISTRICT 4

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
4	12/31/2025 13:30 12/18/2025	Final	CP0410113	115	Bissell Ave	Depew/Chktg	Existing	Residential Single Unit	103.12-3-13	Repair
4	14:00 12/24/2025	Final	CP0410099	58	Vanderbilt Ave	Depew/Chktg	Existing	Residential Single Unit	103.12-13-6	Repair
4	10:00 12/31/2025	Final	CP0406177	351	Columbia Ave	Depew/Lanc	Existing	Residential Single Unit	104.24-1-1.1	Repair
4	13:00	Final	CP0410112	23	Olanta St	Depew/Lanc	Existing	Residential Single Unit	104.07-3-38	Repair
4	12/2/2025 13:00	Final	CP0401384	3710	Bowen Rd	Lancaster (T)	Existing	Residential Single Unit	116.14-1-14	Repair
4	12/5/2025 14:00	Final	CP0401810	144	Brunck Rd	Lancaster (T)	Existing	Residential Single Unit	127.06-1-78	Repair
4	12/8/2025 11:00 12/19/2025	Final	CP0405511	9	Idlebrook Ct	Lancaster (T)	Existing	Residential Single Unit	93.15-2-54	Repair
4	11:00	Final	CP0410106	38	Impala Pkwy	Lancaster (T)	Existing	Residential Single Unit	93.19-4-15	Repair

4	12/29/2025	11:00	Final	CP0405479	8	Jenny Ln	Lancaster (T)	Existing	Residential Single Unit	105.17-2-12	Repair
4	12/24/2025	13:00	Final	CP0405020	101	Maple Dr	Lancaster (T)	Existing	Residential Single Unit	82.03-3-17	Repair
4	12/19/2025	13:00	Final	CP0408739	17	Matthews Dr	Lancaster (T)	Existing	Residential Single Unit	93.19-4-45	Repair
4	12/31/2025	11:00	Final	CP0404487	37	Michael Anthony Ln	Lancaster (T)	Existing	Residential Single Unit	126.05-1-20	Repair
4	12/5/2025	13:00	Final	CP0410084	30	Ward Rd	Lancaster (T)	Existing	Non-Residential Single Unit	95.00-4-9.112	Repair
4	12/23/2025	13:00	Final	CP0410110	152	Central Ave	Lancaster (V)	Existing	Residential Multiple Units	104.15-12-18	Repair
4	12/3/2025	1:00	Final	CP0410079	73	Garfield St	Lancaster (V)	Existing	Residential Multiple Units	104.81-1-11	Repair
4	12/5/2025	11:00	Final	CP0400267	8	Highland Pl	Lancaster (V)	Existing	Residential Multiple Units	104.50-1-14	Repair
4	12/5/2025	13:30	Final	CP0410080	8	Huntley Pl	Lancaster (V)	Existing	Residential Single Unit	115.28-6-20	Repair
4	12/23/2025	13:00	Final	CP0410108	65	Madison St	Lancaster (V)	Existing	Residential Single Unit	115.07-9-10	Repair
4	12/11/2025	13:00	Final	CP0409518	79	Pleasant Ave	Lancaster (V)	Existing	Residential Single Unit	104.75-5-4	Repair

DISTRICT 5

CONNECTIONS/PERMITS

District	Insp Date	Approval	Permit	#	Street	Town	New/Existing	Property Type	SBL	Permit Type
5	12/30/2025 13:30	Final	CP0502346	5082	Eastbrook Pl	Clarence	Existing	Residential Single Unit	57.18-3-17	Repair
5	12/11/2025 14:00	Final	CP0501834	5755	Kippen Dr	Clarence	Existing	Residential Single Unit	57.10-2-16	Repair

DISTRICT 5 CLARENCE TOWN DISTRICTS

District	CTD	Insp Date	Permit	#	Street	Town	Permit Subtype	New/Existing	Property Type	SBL	Permit Type	Tap Type	Comments
5	2	12/23/2025 13:00	CP0504391	9493	Deer Valley Dr	Clarence	Iss	New	Residential Single Unit	44.11-5-28	Connection		Clarence issued. DSM inspected
5	2	1/8/2026 14:00	CP0504393	9534	Deer Valley Dr	Clarence	Iss	New	Residential Single Unit	44.11-5-13	Connection		Clarence issued. DSM inspected.

5	2	12/9/2025 13:00	CP0504390	9548	Deer Valley Dr	Clarence	Clarence Iss	New	Residential Single Unit	44.11-5- 15	Connection	Wye	Clarence issued. DSM inspected.
5	2	1/9/2026 9:00	CP0504396	9568	Deer Valley Dr	Clarence	Clarence Iss	New	Residential Single Unit	44.11-5- 16	Connection		Clarence issued. DSM inspected.

Location	Dist.	Description	Tank Capacity	Internal Tank Height	Gal/in	Date	Gen Hours	Gauge Level	Dip Level	Gallons Remaining	% Full	Gallons Needed	Gallons Added	Refill?	Refill Level
Borden	1	Under Generator	180	21	8.57	5-Dec	2027.8		17 1/4	148	82	32		-	135
Cayuga	1	Under Generator	1300	33	39.39	5-Dec	842		33	1300	100	0		-	975
Clinton	1	Under Generator	150	24	6.25	5-Dec	1951.1		20 3/8	127	85	23		-	113
Industrial Parkway	1	Under Generator	700	30	23.33	5-Dec	711.2		27 1/8	633	90	67		-	525
Union	1	Under Generator	400	26	15.38	5-Dec	129.1		25	385	96	15		-	300
Aurora North	4	Under Generator	325	24	13.54	NA				0	0	325			244
Aurora South	4	Under Generator	285	21	13.57	5-Dec	1797		18	244	86	41		-	214
Bowmansville	4	Under Generator	700	26	26.92	5-Dec	957		23	619	88	81		-	525
Broadway	4	Above-Ground	1000	36	*	5-Dec	317		31	743	74	257		X	750
Depew	4	Above-Ground	3000	69	*	5-Dec	499		50 1/2	2182	73	818		X	2250
Iroquois	4	Under Generator	295	17	17.35	5-Dec	1116		16	278	94	17		-	221
Vanderbilt	4	Above-Ground	1000	36	*	5-Dec	8-Jun		32 1/2	743	74	257		X	750
Warner	4	Under Generator	700	26	26.92	5-Dec	1895		24	646	92	54		-	525
Bryant	5	Under Generator	180	22	8.18	5-Dec	698.6		17 1/4	141	78	39		-	135
Pinebreeze	5	Under Generator	275	44	*	5-Dec	1328.5		39 1/4	253	92	22		-	206
Stahley	5	Under Generator	150	25	6.00	5-Dec	1594		23 1/4	140	93	11		-	113
Transit Valley	5	Above Ground	275	44	*	5-Dec	63.3		40 1/2	259	94	16		-	206

* Calculated

Refill at: 0.75

2026 Maintenance

District 1

Plowed and shoveled snow 4 different times.
Set up bypass pump and broke down and returned at Borden.
Replaced broken volute on pump #1 at Borden.
Began repairs on gate at Old Cayuga.
Washed wet well at Industrial Park.
Replaced battery on Empire Drive manhole monitor.
Began pulling new wires for Cayuga wash pit pumps.

District 4

Plowed and shoveled snow 4 different times.
Began prepping and painting interior walls at Depew 7 different days.
Repaired sluice gate for contact chamber at Depew ORF.
Prepped for generator removal at Broadway.
Pulled and cleaned pump #1 at Bowmansville.
Pulled and cleaned pump #2 at Bowmansville.
Washed wet well at Depew.
Washed wet well at Warner.
Began installing Soft Starts at Warner.
Replaced outfall meter and box at Depew ORF.
Troubleshoot problems with the backhoe.
Began installing WIFI routers at base.

District 5

Plowed and shoveled snow 4 different times.
Cut up 3 fallen trees at CRP.

All Districts

Checked generator fluids in all station generators.

Performed VFD inspections on all drives in NR.